



SWEDISH
STANDARDS
INSTITUTE

SVENSK STANDARD
SS-EN 1462:2004

Fastställd 2004-10-08

Utgåva 2

**Takavvattningsprodukter – Rännkrokar för
hängrännor – Krav och provning**

**Brackets for eaves gutters – Requirements
and testing**

ICS 91.060.20

Språk: engelska

Publicerad: november 2004

Europastandarden EN 1462:2004 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 1462:2004.

Denna standard ersätter SS-EN 1462, utgåva 1.

The European Standard EN 1462:2004 has the status of a Swedish Standard. This document contains the official English version of EN 1462:2004.

This standard supersedes the Swedish Standard SS-EN 1462, edition 1.

Upplysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna upplysningar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM
Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11
E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 1462

September 2004

ICS 91.060.20

Supersedes EN 1462:1997

English version

Brackets for eaves gutters - Requirements and testing

Crochets de gouttières pendantes - Exigences et méthodes
d'essai

Rinnenhalter für Hängedachrinnen - Anforderungen und
Prüfung

This European Standard was approved by CEN on 15 July 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

EN 1462:2004 (E)

Contents

	page
Foreword.....	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
4 Materials	5
5 Resistance to corrosion.....	6
6 Design	7
6.1 General.....	7
6.2 Load bearing capacity.....	7
6.3 Holes for fastenings	8
7 Designation of gutter brackets for ordering purposes	8
8 Marking	8
9 Production control.....	9
Annex A (normative) Test method to determine the corrosion resistance of plastic-coated gutter brackets	10
A.1 Principle.....	10
A.2 Apparatus	10
A.3 Procedure	10
Annex B (normative) Test method to determine the load bearing capacity of gutter brackets	12
B.1 Principle.....	12
B.2 Apparatus	12
B.3 Procedure	12

Foreword

This document (EN 1462:2004) has been prepared by Technical Committee CEN/TC 128 “Roof covering products for discontinuous laying and products for wall cladding”, the secretariat of which is held by IBN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2005, and conflicting national standards shall be withdrawn at the latest by March 2005.

This document supersedes EN 1462:1997.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

EN 1462:2004 (E)

1 Scope

This document specifies the requirements for rafter and fascia board brackets intended to support eaves gutters conforming to EN 607 or EN 612.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 485-1, *Aluminium and aluminium alloys — Sheet, strip and plate — Part 1: Technical conditions for inspection and delivery*

EN 485-2, *Aluminium and aluminium alloys — Sheet, strip and plate — Part 2: Mechanical properties*

EN 485-3, *Aluminium and aluminium alloys - Sheet, strip and plate - Part 3: Tolerances on dimensions and form for hot-rolled products*

EN 485-4, *Aluminium and aluminium alloys — Sheet, strip and plate — Part 4: Tolerances on shape and dimensions for cold-rolled products*

EN 573-3, *Aluminium and aluminium alloys — Chemical composition and form of wrought products — Part 3: Chemical composition*

EN 607, *Eaves gutters and fittings made of PVC- U — Definitions, requirements and testing*

EN 612, *Eaves, gutters and rainwater down-pipes of metal sheet — Definitions, classifications and requirements*

EN 754-1, *Aluminium and aluminium alloys — Cold drawn rod/bar and tube — Part 1: Technical conditions for inspection and delivery*

EN 755-1, *Aluminium and aluminium alloys — Extruded rod/bar, tube and profiles — Part 1: Technical conditions for inspection and delivery*

EN 1652, *Copper and copper alloys — Plate, sheet, strip and circles for general purposes*

EN 1676, *Aluminium and aluminium alloys — Alloyed ingots for remelting — Specifications*

EN 1706, *Aluminium and aluminium alloys — Castings — Chemical composition and mechanical properties*

EN 10025, *Hot rolled products of non-alloy structural steels — Technical delivery conditions*

EN 10088-2, *Stainless steels — Part 2: Technical delivery conditions for sheet/plate and strip for general purposes*

EN 10088-3, *Stainless steels — Part 3: Technical delivery conditions for semi-finished products, bars, rods and sections for general purposes*

EN 10111, *Continuously hot-rolled low carbon steel sheet and strip for cold forming — Technical delivery conditions*

EN 10142, *Continuously hot-dip zinc coated low carbon steels strip and sheet for cold forming — Technical delivery conditions*

EN 10215, *Continuously hot-dip aluminium-zinc (AZ) coated steel strip and sheet — Technical delivery conditions*

EN 10326, *Continuously hot-dip coated strip and sheet of structural steels – Technical delivery conditions*

EN 10327, *Continuously hot-dip coated strip and sheet of low carbon steels for cold forming – Technical delivery conditions*

EN ISO 1461, *Hot dip galvanized coatings on fabricated iron and steel articles — Specifications and test methods (ISO 1461:1999)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

rafter bracket

type of gutter bracket used for fixing a gutter to a rafter

3.2

fascia bracket

type of gutter bracket used for fixing a gutter to a fascia

4 Materials

Gutter brackets shall be manufactured from one of the following materials:

- mild steel conforming to EN 10025 or EN 10111;
- hot-dip zinc coated steel sheet with a minimum grade of DX 51 D and a minimum coating mass of 275 g/m², conforming to EN 10142;
- zinc-aluminium coated steel sheet with a minimum grade of DX 51 D+ZA and a minimum coating mass of 225 g/m², conforming to EN 10326 or EN 10327;
- aluminium-zinc coated steel sheet with a minimum grade of DX 51 D+AZ and a minimum coating mass of 150 g/m², conforming to EN 10215;
- stainless steel conforming to EN 10088-2 or EN 10088-3;
- copper conforming to EN 1652;
- aluminium or aluminium alloy for sheet rolled products conforming to EN 485-1, EN 485-2, EN 485-3 or EN 485-4 in any grade of the 1000, 3000, 5000 and 6000 series;
- aluminium or aluminium alloy for wrought products conforming to EN 754-1 or EN 755-1, and in composition conforming to EN 573-3 (with the exception of those alloys having a mass content of more than 0,3 % of copper or more than 3 % of magnesium);
- aluminium or aluminium alloy for castings conforming to EN 1706 and EN 1676;
- unplasticized polyvinyl chloride (PVC-U) conforming to the requirements given in EN 607 for injection moulded fittings.

EN 1462:2004 (E)

5 Resistance to corrosion

5.1 Gutter brackets of mild steel conforming to EN 10025 or EN 10111 shall be protected from corrosion by one of the following means:

- a) Hot-dip galvanising conforming to EN ISO 1461. Zinc coatings shall conform to the minimum values given in Table 1.
- b) Flexible plastic coating, $\geq 60 \mu\text{m}$ thick, over a zinc coating with an average thickness of $\geq 20 \mu\text{m}$.
- c) Flexible plastic coating, $\geq 60 \mu\text{m}$ thick, with a suitable substrate. When tested in accordance with Annex A, the plastic-coated bracket shall not exhibit any signs of rust or loosening of the coating from the steel.

Table 1 — Minimum zinc coating for mild steel brackets hot-dip galvanized after manufacture

Steel thickness of bracket α (mm)	Thickness of coating	
	Minimum single value (μm)	Average value (μm)
$\alpha > 6$	70	85
$6 \geq \alpha > 3$	55	70
$3 \geq \alpha > 1,5$	45	55

5.2 Gutter brackets of PVC-U shall meet the artificial ageing and colour-fastness requirements detailed in EN 607.

5.3 Gutter brackets shall be manufactured from corrosion-resistant materials according to whether they are intended for use in aggressive atmospheres (Class A – industrial pollution or maritime) or more benign conditions (Class B), as given in Table 2.