

**Karaktärisering av slam – Filtrerings-
egenskaper –**
Del 1: Kappilär sugtid (CST)

**Characterisation of sludges – Filtration
properties –**
Part 1: Capillary suction time (CST)

Europastandarden EN 14701-1:2006 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 14701-1:2006.

The European Standard EN 14701-1:2006 has the status of a Swedish Standard. This document contains the official English version of EN 14701-1:2006.

Uppllysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna upplysningar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM
Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11
E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 14701-1

March 2006

ICS 13.030.20

English Version

Characterisation of sludges - Filtration properties - Part 1: Capillary suction time (CST)

Caractérisation des boues - Propriétés de filtration - Partie
1: Détermination du temps de succion capillaire

Charakterisierung von Schlämmen -
Filtrationseigenschaften - Teil 1: Bestimmung der kapillaren
Fließzeit

This European Standard was approved by CEN on 3 February 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	Page
Foreword.....	3
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Principle.....	5
5 Apparatus	6
5.1 Standard apparatus	6
5.2 Filter paper	6
5.3 Beakers	6
6 Procedure	6
7 Expression of results	6
8 Precision	7
9 Test report	7
Annex A (informative) Simple automatic instrument for determining the filterability of sewage sludge	8
Annex B (informative) Relation between CST and the specific resistance to filtration	9
Annex C (informative) Relation between CST and solids content	10
Annex D (informative) Table of dynamic viscosity	11
Annex E (informative) Results of validation trials	12
Bibliography	15

Foreword

This document (EN 14701-1:2006) has been prepared by Technical Committee CEN/TC 308 "Characterisation of sludges", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2006, and conflicting national standards shall be withdrawn at the latest by September 2006.

Other parts of this European Standard are:

- Part 2: Determination of the specific resistance to filtration;
- Part 3: Determination of the compressibility.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Introduction

The capillary suction time (CST) is a fast and simple way to evaluate the sludge dewaterability by filtration.

This method gives no information on the obtainable solids content in a dewatering process.

The measurement of CST should also make possible the evaluation, although only qualitatively, of other sludge characteristics, including dewaterability by centrifugation.

1 Scope

This document specifies a method for the determination of the capillary suction time. This document is applicable to sludge and sludge suspensions from:

- storm water handling;
- urban wastewater collecting systems;
- urban wastewater treatment plants;
- treating industrial wastewater similar to urban wastewater (as defined in Directive 91/271/EEC);
- water supply treatment plants.

This method is also applicable to sludge suspensions from other origin.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12832:1999, *Characterization of sludges — Utilization and disposal of sludges — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 12832:1999 and the following apply.

3.1

filterability

property indicating the amenability of a sludge to be dewatered by a filtration process

3.2

capillary suction time (CST)

measurement of the time for a wetting front in a filter paper to travel between two fixed points

4 Principle

The principle of the method is that dewatering is achieved by the suction applied to the sludge by the capillary action of an absorbent filter paper.

A part of the absorbent paper area is exposed to the sludge, while the remaining area is free for absorbing the filtrate. The rate at which the paper becomes wetted with filtrate is a measure correlated to sludge dewaterability: it is measured by the time necessary for the filtrate to cover the space between two probes which detect the advancement of the liquid front on the paper (Annex A informative).

The CST measurements are strongly affected by many factors, such as properties of the paper, surface tension, temperature, suspended solids concentration, so they give only qualitative and comparative evaluations which can be correlated to the specific resistance to filtration (prEN 14701-2) for a given type of sludge (Annex B informative).

EN 14701-1:2006 (E)**5 Apparatus****5.1 Standard apparatus**

Device consisting of:

- a) filtration apparatus, including base for supporting the absorbent paper, sludge reservoir and probes;
- b) automatic time recording unit, including amplifier and digital electric stop-clock recording in seconds (see Annex A informative).

5.2 Filter paper

Paper suitable for chromatography with grain parallel with the longer side (for instance, Whatman n. 17 or Wickam CST Papers 7 cm x 9 cm code 868084¹⁾).

NOTE For comparable results the same filter paper type should be used.

5.3 Beakers

Conventional beakers, 50 ml minimum.

6 Procedure

- 6.1 Place a filter paper in the apparatus. The filter paper shall always be placed with the same side up.
- 6.2 Mix the sludge to be tested by pouring it off from a beaker to another for 4 times.
- 6.3 Pour immediately the mixed sludge into the reservoir until it is completely full. Great attention shall be paid in performing measurements immediately after the sludge mixing to avoid any result unreliability due to sludge settling into the beaker (especially for conditioned sludges).
- 6.4 When the clock stops, register the time which has been automatically measured.
- 6.5 Repeat steps 6.1 to 6.4 in order to have at least 3 significant values, as stated in Clause 7.

7 Expression of results

The CST value is given by arithmetically averaging the measured values. If one or more values differ of more than 20% from the calculated mean value, they must not be considered and the average shall be calculated again with remaining values: in any case valid values shall be, at least, 3.

The influence of the temperature may be evaluated through the relationship:

$$CST_1 = (\mu_1/\mu_2) CST_2 \quad (1)$$

where

μ_1 and μ_2 are the dynamic viscosities of water at the two considered temperatures.

1) This information is given for the convenience of users of this document and does not constitute an endorsement by CEN of this product. Equivalent products may be used if they can be shown to lead to the same results.