

**Vattenförsörjning – Aktiva mediafilter – Krav
på utförande, säkerhet och provning**

**Water conditioning equipment inside buildings –
Active media filters – Requirements for
performance, safety and testing**

Europastandarden EN 14898:2006 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 14898:2006.

The European Standard EN 14898:2006 has the status of a Swedish Standard. This document contains the official English version of EN 14898:2006.

Uppllysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna upplysningar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM
Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11
E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 14898

June 2006

ICS 91.140.60

English Version

Water conditioning equipment inside buildings - Active media filters - Requirements for performance, safety and testing

Appareils de conditionnement d'eau à l'intérieur des bâtiments - Filtres à média actifs - Exigences relatives aux performances, à la sécurité et aux essais

Anlagen zur Behandlung von Trinkwasser innerhalb von Gebäuden - Filter mit aktiven Substanzen - Anforderungen an Ausführung, Sicherheit und Prüfung

This European Standard was approved by CEN on 27 April 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions.....	6
4 System design requirements.....	8
4.1 Materials of construction	8
4.2 Working conditions.....	8
4.2.1 Working temperature	8
4.2.2 Working flow.....	8
4.3 Filter cartridge replacement.....	8
4.4 End connections	8
4.5 Backflow prevention	8
4.6 Exchange indicator	8
5 Performance requirements	9
5.1 Pressure strength of the filter housing	9
5.2 Dynamic pressure test of housing.....	9
5.3 Dynamic pressure test of cartridge.....	9
5.4 Pressure drop.....	9
5.5 Substance reduction performance.....	9
5.5.1 Performance claims	9
5.5.2 Chlorine reduction	9
5.5.3 Organic chemical reduction.....	9
5.5.4 Odour and flavour reduction	10
5.5.5 Inorganic chemical reduction	10
6 Test methods.....	10
6.1 Static pressure test of filter housing	10
6.1.1 Principle	10
6.1.2 Procedure	10
6.2 Dynamic water pressure test of housing	11
6.2.1 Principle	11
6.2.2 Procedure	11
6.3 Dynamic pressure test of cartridge.....	12
6.3.1 Principle	12
6.3.2 Procedure	12
6.4 Pressure drop.....	13
6.4.1 Principle	13
6.4.2 Procedure	13
6.5 Chlorine reduction	15
6.5.1 Test equipment.....	15
6.5.2 Reagents	15
6.5.3 Analytical methods	15
6.5.4 Test conditions.....	15
6.5.5 Procedure	16
6.5.6 Sampling	16
6.5.7 Acceptance criteria.....	17
6.5.8 Expression of results	17
6.6 Chemical and odour/flavour reduction.....	17
6.6.1 Test equipment.....	17
6.6.2 Reagents	17

6.6.3	Analytical methods.....	18
6.6.4	Test conditions	18
6.6.5	Procedure.....	21
6.6.6	Sampling	21
6.6.7	Acceptance criteria	21
6.6.8	Expression of results	21
7	Technical documents, marking, labelling and packaging.....	22
7.1	Technical documents.....	22
7.2	Marking	23
7.3	Labelling	23
7.3.1	Filter housing.....	23
7.3.2	Filter cartridge	23
7.4	Packaging.....	23
Annex A	(informative) Example of test rig for substance reduction testing	24
Annex B	(informative) Example test report	25
Annex C	(informative) Substance-specific reduction claims	26
Bibliography	27

EN 14898:2006 (E)

Foreword

This document (EN 14898:2006) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by décembre 2006, and conflicting national standards shall be withdrawn at the latest by décembre 2006.

With respect to potential adverse effects on the quality of water intended for human consumption caused by the product covered by this standard, the following is pointed out to the user:

- 1) This standard provides no information as to whether the product may be used without restriction in any of the Member States.
- 2) It should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulation concerning the use and/or the characteristics of this product remain in force.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

1 Scope

This European Standard specifies requirements relating to the construction, performance and methods of testing for active media filters for drinking water installations inside buildings, with a maximum working pressure of at least 1 000 kPa and a maximum working temperature of less than 30 °C. It only concerns units, which are permanently connected to the mains supply at the point of entry or point of use.

This standard applies only to filter systems comprising a housing and filter media tested together.

It includes capsule type units where both the element and its outer housing are disposable.

NOTE Products intended for use in water supply systems are to comply, when existing, with national regulations and testing arrangements that ensure fitness for contact with drinking water. The Member States relevant regulators and the EC Commission agreed on the principle of a future unique European Acceptance Scheme (EAS) which would provide a common testing and approval arrangement at European level.

If and when the EAS is adopted, European Standards on products will be amended by the addition of an Annex Z/EAS under Mandate M/136 which will contain formal references to the testing, certification and product marking requirements of the EAS. Until the EAS comes into force, the current national regulations remain applicable.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1717, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow.*

EN 12903, *Products used for treatment of water intended for human consumption — Powdered activated carbon.*

EN 12904, *Products used for treatment of water intended for human consumption — Silica sand and silica gravel.*

EN 12905, *Products used for treatment of water intended for human consumption — Expanded aluminosilicate.*

EN 12906, *Products used for treatment of water intended for human consumption — Pumice.*

EN 12907, *Products used for treatment of water intended for human consumption — Pyrolyzed coal material.*

EN 12909, *Products used for treatment of water intended for human consumption — Anthracite.*

EN 12910, *Products used for treatment of water intended for human consumption — Garnet.*

EN 12911, *Products used for treatment of water intended for human consumption — Manganese Greensand.*

EN 12912, *Products used for treatment of water intended for human consumption — Barite.*

EN 12913, *Products used for treatment of water intended for human consumption — Powdered diatomaceous earth.*

EN 12914, *Products used for treatment of water intended for human consumption — Powdered perlite.*

EN 12915-1, *Products used for treatment of water intended for human consumption — Granular activated carbon — Part 1: Virgin granular activated carbon.*

EN 13752, *Products used for treatment of water intended for human consumption — Manganese dioxide.*

EN 14898:2006 (E)

EN 13753, *Products used for treatment of water intended for human consumption — Granular activated alumina.*

EN 13754, *Products used for treatment of water intended for human consumption — Bentonite.*

EN 14368, *Products used for treatment of water intended for human consumption — Manganese dioxide coated limestone.*

EN 14369, *Products used for treatment of water intended for human consumption — Iron-coated granular activated alumina.*

EN 27888, *Water quality — Determination of electrical conductivity (ISO 7888:1985).*

EN ISO 3696, *Water for analytical laboratory use — Specification and test methods (ISO 3696:1987).*

EN ISO 7027, *Water quality — Determination of turbidity (ISO 7072:1999).*

EN ISO 7393-1, *Water quality — Determination of free chlorine and total chlorine — Part 1: Titrimetric method using N,N-diethyl-1,4-phenylenediamine (ISO 7393-1:1985).*

ISO 10523, *Water quality — Determination of pH.*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply:

3.1 active media
adsorbent, ion exchange or chemically active material that removes or significantly reduces a component from water by chemical reaction or by virtue of ionic charge or other surface activity.

3.2 capsule cartridge
sealed cartridge, designed to be used in a support housing.

NOTE For this design, the housing may not be watertight.

3.3 capsule filter
complete filter, for which the filter element and the filter housing are inseparable and the housing is discarded with the spent element.

3.4 cartridge
replaceable filter element.

NOTE This includes any other components that the manufacturer specifies should be changed when the cartridge exchange is due.

3.5 cartridge exchange indicator
means by which the need to change a cartridge is indicated.

NOTE It may work by elapsed time, throughput of water or any other suitable method of indication. This indicator can only be regarded as a guide.

3.6

identification mark

identification on the product and/or packaging that the product conforms to the requirements of this standard, e.g. "This product conforms to prEN 14898".

3.7

filter element

part of the filter that contains the active media.

3.8

filter rated capacity

volumetric capacity of the filter claimed by the manufacturer.

NOTE If more than one substance-specific reduction claim is made by the manufacturer, the filter rated capacity is the capacity for the substance with the lowest substance-specific rated capacity.

3.9

maximum working pressure

manufacturer's stipulated maximum water supply pressure above which the structural integrity of the system may be compromised.

3.10

maximum working temperature

manufacturer's stipulated maximum water supply temperature above which filter performance and/or structural integrity of the system may be compromised.

3.11

minimum reduction rate

minimum percentage reduction achieved by a filter with respect to a specified substance, as defined in the performance requirements of this standard.

3.12

minimum working pressure

manufacturer's stipulated minimum water supply pressure below which filter performance may be compromised.

3.13

minimum working temperature

manufacturer's stipulated minimum water supply temperature below which filter performance and/or structural integrity of the system may be compromised.

3.14

substance-specific rated capacity

volume of water, in litres, that the filter is capable of treating to the minimum reduction rate with respect to a specific substance.

3.15

unit volume

internal empty vessel volume of the complete system which is in contact with the drinking water.

3.16

working flow range

manufacturer's stipulated maximum and minimum flow rates outside of which the performance of the filter may be compromised.

EN 14898:2006 (E)

4 System design requirements

4.1 Materials of construction

Active media shall conform to the requirements for water extractable substances in EN 12903, EN 12904, EN 12905, EN 12906, EN 12907, EN 12909, EN 12910, EN 12911, EN 12912, EN 12913, EN 12914, EN 12915-1, EN 13752, EN 13753, EN 13754, EN 14368 or EN 14369, if and as appropriate.

4.2 Working conditions

4.2.1 Working temperature

The filter shall be designed to operate to the requirements of this standard at:

- minimum ambient air and water temperatures of not less than 5 °C;
- maximum water temperature of at least 30 °C;
- maximum ambient air temperature of at least 30 °C.

4.2.2 Working flow

Performance tests shall be performed at the maximum of the working flow range stipulated by the manufacturer.

If the filter system is not fitted with a flow regulator, the manufacturer shall provide guidance in the operating instructions for adjusting the flow such that it does not exceed the maximum of the working flow range.

4.3 Filter cartridge replacement

Any tools necessary for routine maintenance shall not come into contact with the water intended for human consumption. Any special tools shall be provided by the equipment supplier.

The system shall be designed, and suitable instructions provided, such that contamination of the treated water supply is avoided during the filter cartridge change procedure.

4.4 End connections

Any fittings supplied with the filter to connect it to existing pipework, shall conform to the requirements of the relevant European Standards, and, for point-of-entry installation, shall be minimum size DN 15.

4.5 Backflow prevention

Backflow prevention shall be provided in accordance with the national implementation of EN 1717.

4.6 Exchange indicator

An active media filter system shall incorporate a cartridge exchange indicator, which gives a guide to the remaining life of the element based on filtration capacity, along with a clear statement of the maximum period of time after which the cartridge has to be changed.

5 Performance requirements

5.1 Pressure strength of the filter housing

When subjected to a hydraulic test as defined in 6.1, there shall be no visible leakage or damage.

5.2 Dynamic pressure test of housing

While subject to a cyclic pressure test as described in 6.2, the filter housing shall show no visible signs of leakage or damage.

In the case of a capsule type filter, this test shall be omitted but the dynamic pressure test as described in 6.3 shall be completed.

5.3 Dynamic pressure test of cartridge

While subject to a cyclic pressure test as described in 6.3, the filter cartridge shall show no visible signs of leakage or damage.

5.4 Pressure drop

When subjected to the maximum of the working flow range as described in 6.4, the filter, with a clean element, shall not develop a pressure drop higher than the manufacturer's declared value.

5.5 Substance reduction performance

5.5.1 Performance claims

Any or all of the performance claims covered by this clause may be made by the filter manufacturer but where more than one substance performance claim is made, the rated capacity shall be that for the lowest substance-specific capacity.

5.5.2 Chlorine reduction

When tested in accordance with 6.5, the reduction in chlorine achieved shall be categorized as follows:

Class 1 : ≥ 90 % reduction

Class 2 : ≥ 75 % to < 90 % reduction

5.5.3 Organic chemical reduction

When tested in accordance with 6.6, the unit shall reduce the specified chemical parameter by at least 90 % from an influent concentration of 10 times the regulated value (see [1]) or the World Health Organisation (WHO) Guidelines value (see [2]). With the exception of trihalogenmethanes (THM) (for which chloroform may be used as a surrogate), tests for reduction of each specific substance, for which the manufacturer makes a claim, shall be carried out: other than for THMs, claims for reduction of generic groups (such as pesticides, polycyclic aromatic hydrocarbons (PAH), etc.) of organic chemicals cannot be claimed under this standard.

NOTE The protocols specified in 6.6 can be adapted to test the reduction of substances not specifically covered by the performance requirements of this standard (see Annex C). Claims for the reduction of such substances are clearly separated from the claims made of conformity to this standard (see 7.1).