

**Brandteknisk klassificering av byggprodukter
och byggnadselement –**

Del 1: Klassificering baserad på provningsdata från
metoder som mäter reaktion vid brandpåverkan

**Fire classification of construction products and
building elements –**

Part 1: Classification using data from reaction to fire
tests

Europastandarden EN 13501-1:2007 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 13501-1:2007.

Denna standard ersätter SS-EN 13501-1, utgåva 1.

The European Standard EN 13501-1:2007 has the status of a Swedish Standard. This document contains the official English version of EN 13501-1:2007.

This standard supersedes the Swedish Standard SS-EN 13501-1, edition 1.

Upplýsingar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna upplýsingar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM
Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11
E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD

EN 13501-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2007

ICS 13.220.50

Supersedes EN 13501-1:2002

English Version

Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests

Classification des produits et éléments de construction -
Partie 1: Classement à partir des données d'essais de
réaction au feu

Klassifizierung von Bauprodukten und Bauarten zu ihrem
Brandverhalten - Teil 1: Klassifizierung mit den
Ergebnissen aus den Prüfungen zum Brandverhalten von
Bauprodukten

This European Standard was approved by CEN on 27 November 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....	5
Introduction	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and symbols	7
3.1 Terms and definitions.....	7
3.2 Symbols and abbreviations	11
4 Classes of reaction to fire performance	12
5 Test methods	12
5.1 General.....	12
5.2 Non-combustibility test (EN ISO 1182)	13
5.3 Heat of combustion test (EN ISO 1716)	13
5.4 Single burning item test (EN 13823).....	13
5.5 Ignitability test (EN ISO 11925-2).....	13
5.6 Determination of the burning behaviour of floorings, using a radiant heat source (EN ISO 9239-1)	13
6 Principles for testing and specimen preparation	13
6.1 General requirements for specimen preparation	13
6.2 Specific requirements for non-combustibility and heat of combustion testing.....	13
6.3 Specific requirements for the single burning item test, the ignitability test and the test for the determination of the burning behaviour of floorings, using a radiant heat source	14
7 Number of tests for classification	15
8 Testing of construction products, excluding floorings (see Table 1)	16
8.1 Class E	16
8.2 Classes D, C, B.....	16
8.3 Classes A ₂ , A ₁	16
8.3.1 Homogenous products.....	16
8.3.2 Non-homogeneous products	16
8.3.3 Class A ₂ products.....	16
8.4 Additional classifications s ₁ , s ₂ , s ₃ for smoke production	16
8.5 Additional classifications d ₀ , d ₁ , d ₂ for flaming droplets/particles	16
9 Testing of floorings (see Table 2).....	17
9.1 Class E _{fi}	17
9.2 Classes D _{fi} , C _{fi} , B _{fi}	17
9.3 Classes A _{2fi} , A _{1fi}	17
9.3.1 Homogeneous products.....	17
9.3.2 Non-homogeneous products	17
9.3.3 Class A _{2fi} products	17
9.4 Additional classifications s ₁ , s ₂ for smoke production	17
10 Testing of linear pipe thermal insulation products (see Table 3)	17
10.1 Class E _L	17
10.2 Classes D _L , C _L , B _L	17
10.3 Classes A _{2L} , A _{1L}	18
10.3.1 Homogenous products.....	18
10.3.2 Non-homogeneous products.....	18

10.3.3	Class A _{2L} products	18
10.4	Additional classifications s ₁ , s ₂ , s ₃ for smoke production	18
10.5	Additional classifications d ₀ , d ₁ , d ₂ for flaming droplets/particles	18
11	Classification criteria for construction products, excluding floorings (see Table 1)	18
11.1	General	18
11.2	Class F	19
11.3	Class E	19
11.4	Class D	19
11.5	Class C	19
11.6	Class B	20
11.7	Class A ₂	20
11.7.1	General	20
11.7.2	Homogeneous products	20
11.7.3	Non-homogeneous products	20
11.8	Class A ₁	21
11.8.1	Homogeneous products	21
11.8.2	Non-homogeneous products	22
11.9	Additional classifications s ₁ , s ₂ , s ₃ for smoke production	23
11.9.1	General	23
11.9.2	s ₁	23
11.9.3	s ₂	23
11.9.4	s ₃	23
11.10	Additional classifications d ₀ , d ₁ , d ₂ for flaming droplets and/or particles	23
11.10.1	Products classified A ₂ , B, C, D	23
11.10.2	Products classified E	23
12	Classification criteria for floorings (see Table 2)	24
12.1	General	24
12.2	Class F _{fl}	24
12.3	Class E _{fl}	24
12.4	Class D _{fl}	24
12.5	Class C _{fl}	25
12.6	Class B _{fl}	25
12.7	Class A _{2fl}	25
12.7.1	General	25
12.7.2	Homogeneous products	25
12.7.3	Non-homogeneous products	26
12.8	Class A _{1fl}	26
12.8.1	Homogeneous products	26
12.8.2	Non-homogeneous products	27
12.9	Additional classifications s ₁ , s ₂ for smoke production	27
12.9.1	General	27
12.9.2	s ₁	27
12.9.3	s ₂	27
13	Classification criteria for linear pipe thermal insulation products (see Table 3)	28
13.1	General	28
13.2	Class F _L	28
13.3	Class E _L	28
13.4	Class D _L	28
13.5	Class C _L	29
13.6	Class B _L	29
13.7	Class A _{2L}	29
13.7.1	General	29
13.7.2	Homogeneous products	29
13.7.3	Non-homogeneous products	30
13.8	Class A _{1L}	31
13.8.1	Homogeneous products	31
13.8.2	Non-homogeneous products	31
13.9	Additional classifications s ₁ , s ₂ , s ₃ for smoke production	32

EN 13501-1:2007 (E)

13.9.1	General	32
13.9.2	s1	32
13.9.3	s2	32
13.9.4	s3	32
13.10	Additional classifications d0, d1, d2 for flaming droplets and/or particles	32
13.10.1	Products classified A_{2L}, B_L, C_L, D_L	32
13.10.2	Products classified E_L	33
14	Presentation of classification	33
14.1	Construction products, excluding floorings and linear pipe thermal insulation products	33
14.2	Floorings	34
14.3	Linear pipe thermal insulation products	34
15	Field of application of the classification	35
16	Classification report	35
16.1	General	35
16.2	Content and format	35
Annex A (informative)	Background information for the application of the Commission Decision of 8 February 2000 implementing Council Directive 89/106/EEC as regards the classification of the reaction to fire performance of construction products	40
A.1	General	40
A.2	Assumptions	40
A.3	Reference fire situations	41
A.4	Relationship between classes and reference fire situations	43
Annex B (normative)	Reaction to fire classification report	47
Bibliography	52

Foreword

This document (EN 13501-1:2007) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2007, and conflicting national standards shall be withdrawn at the latest by August 2007.

This document supersedes EN13501-1:2002.

In addition to editorial corrections this document includes the reaction to fire classification procedure for linear pipe thermal insulation products.

CEN, CENELEC and EOTA committees preparing technical specifications, which contain performance requirements against reaction to fire tests, should make reference to the reaction to fire classification given in this European Standard and not refer directly to any specific fire test method.

EN 13501 *Fire classification of construction products and building elements* consists of the following parts:

Part 1: *Classification using data from reaction to fire tests*

Part 2: *Classification using data from fire resistance tests, excluding ventilation services*

Part 3: *Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

Part 4: *Classification using data from fire resistance tests on components of smoke control systems*

Part 5: *Classification using data from external fire exposure to roofs tests*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

EN 13501-1:2007 (E)

Introduction

The aim of this European Standard is to define a harmonized procedure for the classification of reaction to fire of construction products. This classification is based on the test procedures listed in Clause 5.

This European Standard has been prepared in support of the second essential requirement in the EC Construction Products Directive (89/106/EEC) and as detailed in the Interpretative Document Number 2: Safety in case of fire (OJ C62 Vol. 37).

Background information on the Commission Decision regarding the classification of the reaction to fire performance of construction products is given in Annex A.

The European Commission has drawn up a list of products which, under specified conditions, can be considered to be class A1 without testing. This information is given in the Commission Decision 96/603/EC (OJ L 267 19.10.1966 p23) as amended by 2000/605/EC (OJ L 258 12.10.2000 p36) and 2003/424/EC (OJ L 144 12.6.2003 p9).

Additionally there is a procedure by which certain products can be assigned a particular fire classification without the need for testing. Such products have well established reaction to fire performance and have been agreed by the Standing Committee on Construction. Agreements relating to such products which may be 'classified without further testing' (CWFT) are published in the Official Journal of the EC and are listed on the Nando-CPD database on the EC website (<http://europa.eu.int/comm/enterprise/construction>).

Parts 2, 3 and 4 of this European Standard are concerned with classification resulting from fire resistance tests. Part 5 covers classification resulting from tests for external fire exposure to roofs.

NOTE If the classification based on the tests and criteria given in Tables 1 and 2 is not appropriate, one or more reference scenarios (representative scale tests typifying agreed hazard scenarios) can be called upon within the context of a defined procedure. This procedure is intended to be the subject of a future European Standard or Commission Decision, on the basis of an agreement between the Commission and the Member States, in consultation with CEN/GENELEC and EOTA.

1 Scope

This European Standard provides the reaction to fire classification procedure for all construction products, including products incorporated within building elements.

Products are considered in relation to their end use application.

This document applies to three categories, which are treated separately in this European Standard:

- construction products, excluding floorings and linear pipe thermal insulation products;
- floorings;
- linear pipe thermal insulation products.

NOTE The treatment of some families of products is still under review and can necessitate amendments to this European Standard (see European Commission Decision 2000/147/EC).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13823, *Reaction to fire tests for building products — Building products excluding floorings exposed to the thermal attack by a single burning item*

EN ISO 1182, *Reaction to fire tests for building products — Non-combustibility test (ISO 1182:2002)*

EN ISO 1716, *Reaction to fire tests for building products — Determination of the heat of combustion (ISO 1716:2002)*

EN ISO 9239-1, *Reaction to fire tests for floorings — Part 1: Determination of the burning behaviour using a radiant heat source (ISO 9239-1:2002)*

EN ISO 11925-2, *Reaction to fire tests — Ignitability of building products subjected to direct impingement of flame — Part 2: Single-flame source test (ISO 11925-2:2002)*

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Where the definitions are identical to those in EN ISO 13943, this is indicated.

EN 13501-1:2007 (E)

3.1.1

product

material, element or component about which information is required

3.1.2

material

single basic substance or uniformly dispersed mixture of substances, e.g. metal, stone, timber, concrete, mineral wool with uniformly dispersed binder or polymers

3.1.3

homogeneous product

product consisting of a single material, having uniform density and composition throughout the product

3.1.4

non-homogeneous product

product that does not satisfy the requirements of a homogeneous product.

NOTE It is a product composed of one or more components, substantial and/or non-substantial

3.1.5

substantial component

material that constitutes a significant part of a non-homogeneous product. A layer with a mass/unit area $\geq 1,0 \text{ kg/m}^2$ or a thickness $\geq 1,0 \text{ mm}$ is considered to be a substantial component

3.1.6

non-substantial component

material that does not constitute a significant part of a non-homogeneous product. A layer with a mass/unit area $< 1,0 \text{ kg/m}^2$ and a thickness $< 1,0 \text{ mm}$ is considered to be a non-substantial component

NOTE Two or more non-substantial layers that are adjacent to each other (i.e. with no substantial component(s) in between the layers) are regarded as one non-substantial component when they collectively comply with the requirements for a layer being a non-substantial component.

3.1.7

internal non-substantial component

non-substantial component that is covered on both sides by at least one substantial component

3.1.8

external non-substantial component

non-substantial component that is not covered on one side by a substantial component

3.1.9

flooring

upper layer(s) of a floor, comprising any surface finish with or without an attached backing and with any accompanying underlay, interlayer and adhesives

3.1.10

linear pipe thermal insulation product

length of insulation product designed to fit around pipes, with a maximum outer insulation diameter of 300 mm and not intended for use with cylindrical ducts

3.1.11

substrate

product which is used immediately beneath the product about which information is required.

NOTE For flooring, it is the floor on which it is mounted or the material which represents this floor

3.1.12

standard substrate

product which is representative of the substrate used in end-use applications

3.1.13

end use application

real application of a product, in relation to all aspects that influence the behaviour of that product under different fire situations.

NOTE It covers aspects such as its quantity, orientation, position in relation to other adjacent products, and its method of fixing

3.1.14

fire performance

response of an item when exposed to a specific fire (EN ISO 13943)

3.1.15

reaction to fire

response of a product in contributing by its own decomposition to a fire to which it is exposed, under specified conditions

3.1.16

fire scenario

detailed description of conditions, including environmental, of one or more stages from before ignition to after completion of combustion at a specific location or in a real scale simulation (EN ISO 13943)

3.1.17

reference scenario

hazard situation used as a reference for a given test method or classification system

3.1.18

fire situation

stage in the development of a fire, characterised by the nature, severity and size of the thermal attack on the products involved

3.1.19

combustion

exothermic reaction of a substance with an oxidizer (EN ISO 13943)

NOTE Combustion generally emits effluent accompanied by flames and/or visible light.

3.1.20

heat of combustion

thermal energy produced by combustion of unit of mass of a given substance (EN ISO 13943)

NOTE It is expressed in joules per kilogram.

3.1.21

gross heat of combustion (PCS)

heat of combustion of a substance when the combustion is complete and any produced water is entirely condensed under specified conditions (EN ISO 13943)

3.1.22

net heat of combustion (PCI)

heat of combustion of a substance when the combustion is complete and any produced water is in the vapour state under specified conditions (EN ISO 13943)

NOTE The net heat of combustion may be calculated from the gross heat of combustion.