



SWEDISH
STANDARDS
INSTITUTE

SVENSK STANDARD SS-EN 14652:2005+A1:2007

Fastställd 2007-07-02

Utgåva 1

Vattenförsörjning – Konditioneringsutrustning inomhus – Membranseparering – Krav och provning

Water conditioning equipment inside buildings – Membrane separation devices – Requirements for performance, safety and testing

ICS 91.140.60

Språk: engelska

Publicerad: augusti 2007

Europastandarden EN 14652:2005+A1:2007 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 14652:2005+A1:2007.

Denna standard ersätter SS-EN 14652:2005, utgåva 1.

The European Standard EN 14652:2005+A1:2007 has the status of a Swedish Standard. This document contains the official English version of EN 14652:2005+A1:2007.

This standard supersedes the Swedish Standard SS-EN 14652:2005, edition 1.

Upplysningar om **sakinnehållet** i standarden lämnas av SIS, Swedish Standards Institute, telefon 08 - 555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar **allmänna upplysningar** om svensk och utländsk standard.

Postadress: SIS Förlag AB, 118 80 STOCKHOLM

Telefon: 08 - 555 523 10. *Telefax:* 08 - 555 523 11

E-post: sis.sales@sis.se. *Internet:* www.sis.se

EUROPEAN STANDARD

EN 14652:2005+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2007

ICS 13.060.20; 91.140.60

Supersedes EN 14652:2005

English Version

Water conditioning equipment inside buildings - Membrane separation devices - Requirements for performance, safety and testing

Appareils de traitement d'eau à l'intérieur des bâtiments -
Dispositifs de séparation membranaire - Exigences de
performance, de sécurité et essais

Anlagen zur Behandlung von Trinkwasser innerhalb von
Gebäuden - Membranfilteranlagen - Anforderungen an
Funktion, Sicherheit und Prüfung

This European Standard was approved by CEN on 8 July 2005 and includes Amendment 1 approved by CEN on 10 May 2007.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.


This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Classification.....	11
5 Symbols and abbreviations	12
6 Construction requirements.....	13
6.1 General.....	13
6.2 Materials	13
6.3 Resistance to temperature.....	13
6.4 Resistance to hydrostatic pressure.....	13
6.5 Resistance to cyclic pressure	13
6.6 Backflow prevention.....	13
6.7 Electrical safety.....	13
6.8 Noise level	14
6.9 Air vent.....	14
6.10 End connections	14
6.11 Drain connections.....	14
6.12 Component replacement.....	14
6.13 Back-washable modules (MF and UF)	14
7 Performance requirements	14
7.1 General.....	14
7.2 Hydraulic performance (applicable to MF, UF).....	14
7.3 Mechanical performance.....	15
7.4 Functional performance	15
8 Instruction and information	17
8.1 Installation, operation and maintenance instructions – Instruction manual.....	17
8.2 Marking and data plate	17
8.3 Performance data sheet	18
Annex A (normative) Test methods.....	19
Annex B (informative) Types of membrane	49
Annex C (informative) Typical test reports	51
Annex D (normative)  Installation, operation and maintenance	56
Bibliography	61



Foreword

This European Standard (EN 14652:2005+A1:2007) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This document shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2007 and conflicting national standards shall be withdrawn at the latest by December 2007.

This document includes Amendment 1, approved by CEN on 2007-05-10.

This document supersedes EN 14652:2005.

The start and finish of text introduced or altered by amendment is indicated in the text by tags  .

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

EN 14652:2005+A1:2007 (E)

Introduction

With respect of potential adverse effects on the quality of water intended for human consumption caused by the product covered by this European Standard, the following is pointed out to the user of this European Standard:

- 1) this European Standard provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- 2) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

1 Scope

This European Standard specifies requirements relating to the construction, performance and methods of testing for membrane separation systems with a particle rating below 1 µm, namely microfiltration (MF), ultrafiltration (UF), nanofiltration (NF) and reverse osmosis (RO) for drinking water installations inside buildings, intended to remove from the drinking water marginal concentrations of suspended and colloidal solids, microorganisms, organic molecules and/or to reduce the dissolved solids concentration and applies to systems with a minimum pressure of PN 10, connections between DN 15 and DN 100 and a maximum working temperature of at least 30 °C.

This European Standard applies to membrane separation systems, whose elements may be partly or entirely cleanable or disposable in accordance with the type of system. It only concerns units which are permanently connected to the mains supply at the point-of-entry or the point-of-use.

A membrane separation system may include, together with the separation device pre- and /or post-treatment devices.

For the scope of this European Standard:

- separation device shall comply with this European Standard, i.e. without pre-and/or post-treatments;
- where pre-and/or post-treatment devices are incorporated in the system, each of them shall conform to the relevant standard. If this is the case, the complete system shall be considered as conforming as a whole.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1092-1, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 1: Steel flanges*

EN 1092-2, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 2: Cast iron flanges*

EN 1254-1, *Copper and copper alloys — Plumbing fittings — Part 1: Fittings with ends for capillary soldering or capillary brazing to copper tubes*

EN 1567, *Building valves — Water pressure reducing valves and combination water pressure reducing valves — Requirements and tests*

EN 1717:2000, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow*

EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation (ISO 228-1:2000)*

EN ISO 3696, *Water for analytical laboratory use — Specification and test methods (ISO 3696:1987)*

EN ISO 3822 (all parts), *Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations*

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

EN 14652:2005+A1:2007 (E)

ISO 304, *Surface active agents — Determination of surface tension by drawing up liquid films*

ISO 1219-1, *Fluid power systems and components — Graphic symbols and circuit diagrams — Part 1: Graphic symbols*

ISO 12103-1, *Road vehicles — Test dust for filter evaluation — Part 1: Arizona test dust*

3 Terms and definitions

For the purposes of this European Standard, the following terms and definitions apply.

3.1

accessible

fabricated to be exposed for cleaning and inspection using standard available tools if necessary (e.g., screwdriver, pliers, open-end spanner)

3.2

air gap (drain system)

unobstructed vertical distance through the free atmosphere between the outlet of the concentrated discharge pipe and the flood level rim of the receptacle into which it is discharging

3.3

air gap (water distribution system)

unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet to a tank, plumbing fixture or other device, and the flood level rim of the receptacle

3.4

bubble point

minimum pressure required to overcome the surface tension of the water filling the pores of the membrane

3.5

component

separate or distinct part of a drinking water treatment system including, but not limited to, appurtenant accessories such as membranes, filters, housing, tubing, storage tanks, taps, valves, connectors to the feed water supply and connectors to the waste discharge line

3.6

contaminant

any undesirable chemical or microbiological substance or parameter in drinking water

3.7

cross-flow filtration

mode of operation by which part of the water passes through the membrane (product water) and the remaining part is rejected (reject water)

NOTE 1 The reject water, which can be wasted or partly recycled, plays the major role of keeping the membrane surface clean.

NOTE 2 Term "tangential flow" has the same technical meaning.

3.8

daily production

volume of product water produced by the system per day

3.9

dead-end filtration

mode of operation in which all the water feed passes through the membrane (no reject water). Depending on the rate of fouling/clogging of the membrane due to the retained substances, this filtration method is subject to declining rate of flow due to build up of retained matter. The membrane should be cleanable or disposable

3.10

device

complete, assembled, functional system

3.11

disposable component

component that requires periodic replacement

3.12

drinking water

water intended for human consumption as defined in Directive 98/83/EC

3.13

filtrate

water which is obtained by passage through microporous membranes (MF, UF)

3.14

flow controller

device for regulating the flow rate of water

3.15

grade of filtration

minimum membrane particle or dissolved substances rating which expresses the ability of the membrane to retain dissolved or un-dissolved solids of a given size range under normal working conditions irrespective of the nature of the membrane material

3.16

manufacturer

enterprise submitting the membrane module or the device for testing the compliance of that product to this European Standard

3.17

membrane

structure intervening for separating two phases and/or acting as a selective barrier to the transport of matter between the phases adjacent to it

NOTE

It is categorised as membrane for MF, UF, NF or for RO in accordance with its construction and performance (see Annex B).

3.18

membrane flux

flow rate characteristics through the membrane that are dependant upon applied pressure and water temperature expressed in volume of product water per surface area unit of membrane and time

3.19

membrane material

material used for manufacturing membranes including organic (polymeric) and inorganic (ceramics, sintered metals or others) materials

3.20

membrane separation system

water treatment system which includes membrane, pressure vessel, fittings, gauges and ancillaries and which may include pre- and post-treatment components

3.21

microfiltration

process which removes particles of a size down to a given rating or a given molecular weight cut-off (MWCO)

NOTE

Annex B gives information on each type of membrane.

EN 14652:2005+A1:2007 (E)

3.22

module

smallest practical membrane unit which can be directly manifolded to feed streams to separate a feed stream into a reject and a permeate stream once placed in an appropriate housing

3.23

module housing

pressure vessel in which the module is accommodated

NOTE The membrane is usually tested in its final configuration (module) inside its housing specified by the manufacturer.

3.24

nanofiltration

process similar to reverse osmosis where the membrane has a looser structure thus reducing the rejection of monovalent ion

3.25

nominal flow rate

flow rate of water produced, in litres per hour, expressed in relation to the parameters indicated by the manufacturer (namely operating pressure and pressure drop)

NOTE In relation to the cross-flow mode of filtration it is also referred to as product or permeate flow rate.

3.26

operating pressure

pressure specified by the equipment manufacturer to ensure the expected performance

3.27

permeability

for a given fluid at given temperature (viscosity), it represents the flux of the given membrane as a function of the transmembrane driving force

NOTE The permeability coefficient is defined by Darcy's law.

3.28

permeate

water which has passed through the membranes

NOTE The term is currently used in general for membranes operating in the cross-flow mode, sometimes even MF and UF.

3.29

permanent pressure vessel

vessel that contains the cartridge, membrane or media which may be replaced or regenerated at the end of each rated service cycle and has an estimated service life greater than one year

3.30

point-of-entry device

water treatment system installed to treat the drinking water for the majority of the distribution system within the premises

3.31

point-of-use device

water treatment system used to treat the drinking water at a single tap or multiple taps but not for the majority of the facility

3.32

post-membrane treatment

additional treatment of the water subsequent to passage through the membrane(s)

3.33**pre-membrane treatment**

any pre-treatment intended to protect the membrane in order to improve its performance and/or to prolong its lifetime

3.34**product water**

water that has been treated by the system after blending with untreated water, if applicable

3.35**recovery rate**

percentage measure of the amount of influent water which is delivered as permeate with open permeate discharge applicable to cross-flow mode

The recovery rate is calculated by measuring the flow rate of the influent water and the product water (permeate) in accordance with Equation (1):

$$Y = \frac{Q_p}{Q_f} \times 100 \quad (1)$$

where

Y is the recovery rate, in %;

Q_p is the product water flow rate, in m³/h;

Q_f is the influent water flow rate, in m³/h.

3.36**rejection rate**

mean percentage of the un-dissolved particles and of the ionic and molecular (organic) substances removed by the membrane depending on the operating condition as well as on the type of membrane used

The rejection rate is calculated in accordance with Equation (2):

$$R = \left(1 - \frac{C_p}{C_f} \right) 100 \quad (2)$$

where

R is the rejection rate, in %;

C_f is the feed solution concentration of the considered substance;

C_p is the filtrate/permeate solution concentration of the considered substance.

3.37**reject water**

portion of the influent water which is drained to waste

3.38**reference filtration rating**

dimension, in micrometers, of particles at which the overall average cumulative filtration efficiency of a membrane module tested in accordance with the procedure described in A.3.1, is greater than or equal to 99,8 %