

SVENSK STANDARD

SS-EN 15001-2:2008

Fastställt/Approved: 2008-11-24

Publicerad/Published: 2008-12-18

Utgåva/Edition: 1

Språk/Language: engelska/English

ICS: 23.040.01; 91.140.40

**Gasinfrastruktur – Rörnättsinstallation med ett arbetstryck över 0,5 bar för industriella installationer och över 5 bar för industriella och ej industriella installationer –
Del 2: Detaljerad funktionskrav för driftsättning, drift och underhåll**

**Gas infrastructure – Gas installation pipework with an operating pressure greater than 0.5 bar for industrial installations and greater than 5 bar for industrial and nonindustrial installations –
Part 2: Detailed functional requirements for commissioning, operation and maintenance**

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-68235>

Hitta rätt produkt och ett leveranssätt som passar dig

Standarder

Genom att följa gällande standard både effektiviserar och säkrar du ditt arbete. Många standarder ingår dessutom ofta i paket.

Tjänster

Abonnemang är tjänsten där vi uppdaterar dig med aktuella standarder när förändringar sker på dem du valt att abonnera på. På så sätt är du säker på att du alltid arbetar efter rätt utgåva.

e-nav är vår online-tjänst som ger dig och dina kollegor tillgång till standarder ni valt att abonnera på dygnet runt. Med e-nav kan samma standard användas av flera personer samtidigt.

Leveranssätt

Du väljer hur du vill ha dina standarder levererade. Vi kan erbjuda dig dem på papper och som pdf.

Andra produkter

Vi har böcker som underlättar arbetet att följa en standard. Med våra böcker får du ökad förståelse för hur standarder ska följas och vilka fördelar den ger dig i ditt arbete. Vi tar fram många egna publikationer och fungerar även som återförsäljare. Det gör att du hos oss kan hitta över 500 unika titlar. Vi har även tekniska rapporter, specifikationer och "workshop agreement".

Matriser är en översikt på standarder och handböcker som bör läsas tillsammans. De finns på sis.se och ger dig en bra bild över hur olika produkter hör ihop.

Standardiseringsprojekt

Du kan påverka innehållet i framtida standarder genom att delta i någon av SIS ca 400 Tekniska Kommittéer.

Find the right product and the type of delivery that suits you

Standards

By complying with current standards, you can make your work more efficient and ensure reliability. Also, several of the standards are often supplied in packages.

Services

Subscription is the service that keeps you up to date with current standards when changes occur in the ones you have chosen to subscribe to. This ensures that you are always working with the right edition.

e-nav is our online service that gives you and your colleagues access to the standards you subscribe to 24 hours a day. With e-nav, the same standards can be used by several people at once.

Type of delivery

You choose how you want your standards delivered. We can supply them both on paper and as PDF files.

Other products

We have books that facilitate standards compliance. They make it easier to understand how compliance works and how this benefits you in your operation. We produce many publications of our own, and also act as retailers. This means that we have more than 500 unique titles for you to choose from. We also have technical reports, specifications and workshop agreements.

Matrices, listed at sis.se, provide an overview of which publications belong together.

Standardisation project

You can influence the content of future standards by taking part in one or other of SIS's 400 or so Technical Committees.

Europastandarden EN 15001-2:2008 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 15001-2:2008.

The European Standard EN 15001-2:2008 has the status of a Swedish Standard. This document contains the official English version of EN 15001-2:2008.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), tel +46 8 555 520 00.

Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

SIS Förlag AB, SE 118 80 Stockholm, Sweden. Tel: +46 8 555 523 10. Fax: +46 8 555 523 11.

E-mail: sis.sales@sis.se Internet: www.sis.se

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 15001-2

November 2008

ICS 23.040.01; 91.140.40

English Version

Gas infrastructure - Gas installation pipework with an operating pressure greater than 0,5 bar for industrial installations and greater than 5 bar for industrial and non-industrial installations - Part 2: Detailed functional requirements for commissioning, operation and maintenance

Systèmes d'alimentation en gaz - Canalisations d'installation de gaz avec une pression de service supérieure à 0,5 bar pour les installations industrielles et supérieure à 5 bar pour les installations industrielles et non industrielles - Partie 2: Exigences fonctionnelles détaillées pour la mise en service, l'exploitation et la maintenance

Gasversorgungssysteme - Gas-Leitungsanlagen mit einem Betriebsdruck größer 0.5 bar für industrielle Installationen und größer 5 bar für industrielle und nicht-industrielle Installationen - Teil 2: Detaillierte funktionale Anforderungen an Inbetriebnahme, Betrieb und Instandhaltung

This European Standard was approved by CEN on 11 October 2008.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
3.1 Definitions relating to pressure.....	5
3.2 Definitions relating to the gas installation	5
3.3 Definitions relating to means of isolation	6
3.4 Definitions relating to components	6
3.5 Definitions relating to tests	7
3.6 Definitions relating to commissioning, operation and maintenance	7
3.7 Definitions relating to pressure regulating and metering	8
4 General.....	8
4.1 Technical file	8
4.2 Changes affecting an existing installation.....	9
4.3 Quality system	9
4.4 Protection against hazards.....	9
4.5 Protection against adverse influences.....	10
5 Commissioning	10
5.1 General.....	10
5.2 Purging	10
6 Operation and maintenance	11
6.1 Requirements involving operation and maintenance.....	11
6.2 Operation	12
6.3 Maintenance	14
Bibliography	21

Foreword

This document (EN 15001-2:2008) has been prepared by Technical Committee CEN/TC 234 “Gas supply”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2009, and conflicting national standards shall be withdrawn at the latest by May 2009.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

There is a complete suite of functional standards prepared by CEN/TC 234 “Gas infrastructure” to cover all parts of the gas supply system from the input of gas to the transmission system up to the inlet connection of the gas appliances, whether for domestic, commercial or industrial purposes.

In preparing this standard, a basic understanding of gas supply by the user has been assumed.

In the event of conflicts in terms of more restrictive requirements in national legislation/regulation with the requirements of this standard, national legislation/regulation takes precedence as illustrated in CEN /TR 13737.

NOTE CEN/TR 13737 contains:
- clarification of relevant legislation/regulations applicable in a country;
- if appropriate, more restrictive national requirements;
- national contact point for the latest information.

Gas supply systems are complex and the importance on safety of their construction and use has led to the development of very detailed codes of practice and operating manuals in the member countries. These detailed statements embrace recognised standards of gas engineering and the specific requirements imposed by the legal structures of the member countries.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

SS-EN 15001-2:2008 (E)

1 Scope

This European Standard specifies detailed functional requirements for the commissioning, operation and maintenance of

- industrial gas installations and assemblies with an operating pressure greater than 0,5 bar and of
- non-industrial gas installations (residential and commercial) with an operating pressure greater than 5 bar,

starting from the outlet of the network operator's point of delivery up to the inlet connection to the gas appliance; normally the inlet isolation valve. This European Standard also covers the inlet connection to the gas appliance comprising of the pipework that does not fall within the scope of the appliance standard.

This standard applies to gas installations operating at ambient temperatures between $-20\text{ }^{\circ}\text{C}$ and $40\text{ }^{\circ}\text{C}$ and operating pressures up to and including 60 bar. For operating conditions outside these limitations, reference should additionally be made to EN 13480 for metallic pipework.

For industrial gas installations up to and including 0,5 bar and for non-industrial (residential and commercial) gas installations up to and including 5 bar EN 1775 applies.

For gas installations that do not fall within the scope of EN 1775 or other European Standards, this European Standard applies.

In this European Standard, the term "gas" refers to combustible gases, which are gaseous at $15\text{ }^{\circ}\text{C}$ and 1 013 mbar absolute atmospheric pressure. These gases are commonly referred to as manufactured gas, natural gas or Liquefied Petroleum Gas (LPG). They are also referred to as first, second or third family gases (see table 1 of EN 437:2003).

LPG storage vessels (including all ancillaries fitted directly to storage vessels) are excluded. Also excluded are LPG installations and sections of LPG installations operating at vapour pressure (e.g. between the storage vessel and its pressure regulator).

In this European Standard, all pressures are gauge pressures unless otherwise stated.

For gas installations within the scope of this standard, national legislation and regulations have to be taken into account.

Functional requirements for design, selection of materials, construction, inspection and testing of industrial gas installations and assemblies with an operating pressure greater than 0,5 bar and of gas installations greater than 5 bar in buildings and areas intended for residential, commercial, public and mixed uses are described in prEN 15001-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12954, *Cathodic protection of buried or immersed metallic structures — General principles and application for pipelines*

prEN 15001-1, *Gas installation pipework with an OP greater than 05 bar for industrial installations and greater than 5 bar for industrial and non-industrial installations — Part 1: Detailed functional requirements for design, materials, construction, inspection and testing*

EN 60079-10, *Electrical apparatus for explosive gas atmospheres — Part 10: Classification of hazardous areas (IEC 60079-10:2002)*

EN 60079-14, *Electrical apparatus for explosive gas atmospheres — Part 14: Electrical installations in hazardous areas (other than mines) (IEC 60079-14:2002)*

EN 60079-17, *Explosive atmospheres — Part 17: Electrical installations inspection and maintenance (IEC 60079-17:2007)*

EN 60079-29-1, *Explosive atmospheres — Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases (IEC 60079-21-1:2007, modified)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 Definitions relating to pressure

3.1.1

pressure

gauge pressure of the fluid inside the system, measured in static conditions

3.1.2

design pressure (DP)

pressure at which the design calculations are based; this is equivalent to the maximum allowable pressure (PS) as given in the PED

3.1.3

operating pressure (OP)

pressure which occurs within pipework under normal operating conditions

3.1.4

maximum incidental pressure (MIP)

maximum pressure which pipework can experience during a short time, limited by the safety devices

3.2 Definitions relating to the gas installation

3.2.1

pipework

assembly of pipes and fittings

3.2.2

components

any item from which a gas supply system or installation is constructed. A distinction is drawn between the following groups of components:

- ancillaries (for example pressure regulators, valves, safety devices, expansion joints, and insulating joints);
- pipes, including bends made from pipe;
- instrumentation pipework;
- fittings (for example reducers, tees, factory-made elbows, flanges, dome ends, welding stubs, and mechanical joints)

SS-EN 15001-2:2008 (E)

3.2.3

point of delivery

point where the gas is transferred to the user.

NOTE This can be at a means of isolation or at the meter outlet connection and is normally at the point of transfer of ownership.

3.2.4

user(s)

person(s) responsible for the safety of the gas installation and associated risks on a site

NOTE Normally the user will be the site occupier or owner. It should be assumed that every user has a responsibility for work performed on their site, whether or not the work is performed directly for the user or not. This does not mean that they cannot take advice from an independent specialist.

3.2.5

installation pipework

pipework including components and stations downstream of the point of delivery terminating at the appliance inlet connection

NOTE This pipework is normally the property of the customer

3.2.6

ventilated space

space where the air is continuously changed by natural or mechanical means

3.2.7

duct

space specifically designed and constructed for the passage of building services

EXAMPLE Building services include gas pipework, water systems, power and telecommunication cables

3.2.8

ventilation duct

duct forming part of the structure of the building and intended exclusively for ventilation purposes

3.3 Definitions relating to means of isolation

3.3.1

means of isolation

device that is intended to interrupt the gas flow in pipework

EXAMPLE a manually operable valve

3.4 Definitions relating to components

3.4.1

regulator

device which reduces the gas pressure to a set value and maintains it within prescribed limits

3.4.2

insulating joint

fitting installed to insulate electrically one section of pipework from another

3.4.3

sleeve

protective pipe through which a gas pipe passes

3.4.4

vent pipe

pipework connected to a safety or control device to release gas at a safe location

3.4.5

creep relief valve

device designed to release a limited flow of gas in the event of an unacceptable pressure being detected within the system it protects

3.4.6

instrumentation pipework

pipework required for the proper functioning of the ancillaries installed within the pressure regulating installation

EXAMPLES Sensing, measuring, auxiliary and sampling lines

3.5 Definitions relating to tests

3.5.1

strength test

specific procedure intended to verify that the pipework meets the requirements for mechanical strength

3.5.2

tightness test

specific procedure intended to verify that the pipework meets the requirements for tightness

3.5.3

leak detection fluid

specially formulated fluid and foaming product that gives a clear indication that a leak exists when applied to an element of pipework

3.6 Definitions relating to commissioning, operation and maintenance

3.6.1

admission of gas

operation of replacing the air or inert gas contained in pipework with distributed gas

3.6.2

purging from gas

operation of replacing the distributed gas in pipework with air or inert gas

3.6.3

purging

process for safety removing air or inert gas from pipework and/or pipeline components and replacing it with gas, or the reverse process. A distinction is made between the following methods:

- direct purging: the displacement of air by gas or vice versa;
- indirect purging: the displacement of air by inert gas followed by the displacement by gas or vice versa: alternatively by means of a barrier (a slug of inert gas or a pig) between the air and the gas or vice versa

3.6.4

commissioning

activities required to fill and to pressurise pipework, stations, equipment and assemblies with gas and to put them into operation