

# SVENSK STANDARD

## SS-ISO 17484-2:2009

Fastställt/Approved: 2009-01-21

Publicerad/Published: 2009-02-26

Utgåva/Edition: 1

Språk/Language: engelska/English

ICS: 23.040.20; 23.040.45; 91.140.40

---

### **Plaströrsystem – Flerlagriga rörsystem för gasinstallation inomhus –**

#### **Del 2: Riktlinjer (ISO 17484-2:2009, IDT)**

### **Plastics piping systems – Multilayer pipe systems for indoor gas installations –**

#### **Part 2: Code of practice (ISO 17484-2:2009, IDT)**

This preview is downloaded from [www.sis.se](http://www.sis.se). Buy the entire standard via <https://www.sis.se/std-68755>

# Hitta rätt produkt och ett leveranssätt som passar dig

## Standarder

Genom att följa gällande standard både effektiviserar och säkrar du ditt arbete. Många standarder ingår dessutom ofta i paket.

## Tjänster

Abonnemang är tjänsten där vi uppdaterar dig med aktuella standarder när förändringar sker på dem du valt att abonnera på.

På så sätt är du säker på att du alltid arbetar efter rätt utgåva.

e-nav är vår online-tjänst som ger dig och dina kollegor tillgång till standarder ni valt att abonnera på dygnet runt. Med e-nav kan samma standard användas av flera personer samtidigt.

## Leveranssätt

Du väljer hur du vill ha dina standarder levererade. Vi kan erbjuda dig dem på papper och som pdf.

## Andra produkter

Vi har böcker som underlättar arbetet att följa en standard. Med våra böcker får du ökad förståelse för hur standarder ska följas och vilka fördelar den ger dig i ditt arbete. Vi tar fram många egna publikationer och fungerar även som återförsäljare. Det gör att du hos oss kan hitta över 500 unika titlar. Vi har även tekniska rapporter, specifikationer och "workshop agreement".

Matriser är en översikt på standarder och handböcker som bör läsas tillsammans. De finns på [sis.se](http://sis.se) och ger dig en bra bild över hur olika produkter hör ihop.

## Standardiseringsprojekt

Du kan påverka innehållet i framtida standarder genom att delta i någon av SIS ca 400 Tekniska Kommittéer.

# Find the right product and the type of delivery that suits you

## Standards

By complying with current standards, you can make your work more efficient and ensure reliability. Also, several of the standards are often supplied in packages.

## Services

Subscription is the service that keeps you up to date with current standards when changes occur in the ones you have chosen to subscribe to. This ensures that you are always working with the right edition.

e-nav is our online service that gives you and your colleagues access to the standards you subscribe to 24 hours a day. With e-nav, the same standards can be used by several people at once.

## Type of delivery

You choose how you want your standards delivered. We can supply them both on paper and as PDF files.

## Other products

We have books that facilitate standards compliance. They make it easier to understand how compliance works and how this benefits you in your operation. We produce many publications of our own, and also act as retailers. This means that we have more than 500 unique titles for you to choose from. We also have technical reports, specifications and workshop agreements.

Matrices, listed at [sis.se](http://sis.se), provide an overview of which publications belong together.

## Standardisation project

You can influence the content of future standards by taking part in one or other of SIS's 400 or so Technical Committees.

Den internationella standarden ISO 17484-2:2009 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av ISO 17484-2:2009.

The International Standard ISO 17484-2:2009 has the status of a Swedish Standard. This document contains the official English version of ISO 17484-2:2009.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), tel +46 8 555 520 00.

Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

SIS Förlag AB, SE 118 80 Stockholm, Sweden. Tel: +46 8 555 523 10. Fax: +46 8 555 523 11.

E-mail: [sis.sales@sis.se](mailto:sis.sales@sis.se) Internet: [www.sis.se](http://www.sis.se)

**SS-ISO 17484-2:2009 (E)**

<b>Contents</b>	<b>Page</b>
Foreword.....	iv
Introduction .....	v
1 Scope .....	1
2 Normative references .....	1
3 Terms and definitions.....	1
4 Design .....	2
4.1 Reference to installation standards.....	2
4.2 Pipework components.....	2
5 Location of pipework.....	2
5.1 General requirements for location of pipework.....	2
5.2 Protection in case of fire.....	3
5.3 Additional safety devices.....	3
6 Materials and components .....	3
7 Construction.....	4
8 Jointing procedures .....	4
8.1 General.....	4
8.2 Installation process .....	5
9 Pressure testing and commissioning.....	5
9.1 General recommendations .....	5
9.2 Recommendations relating to the safety of persons and property during testing .....	5
9.3 Tightness testing .....	5
9.4 Test fluids .....	6
9.5 Test conditions .....	6
9.6 Strength testing .....	6
10 Storage and handling .....	7
10.1 General.....	7
10.2 Storage.....	7
10.3 Handling.....	7
Bibliography .....	8

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 17484-2 was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 4, *Plastics pipes and fittings for the supply of gaseous fuels*.

ISO 17484 consists of the following parts, under the general title *Plastics piping systems — Multilayer pipe systems for indoor gas installations*:

- *Part 1: Specifications for systems*
- *Part 2: Code of practice*

## SS-ISO 17484-2:2009 (E)

### Introduction

ISO 17484 applies to multilayer pipe systems intended to be installed inside buildings.

The scope of this part of ISO 17484 has been limited to a maximum operating pressure (MOP) of 5 bar (500 kPa).

Although these materials are able to withstand higher pressures, a lower maximum working pressure has been selected taking into account use for gas within buildings. Therefore, a rather high safety factor has been incorporated into the functional requirements. Currently, in some countries multilayer piping is installed only under specific conditions, but this is not the case everywhere. Generally, interest in multilayer pipe systems has been increasing. Cost-effective material installation cost is a good argument for the reconsideration of conventional installation techniques. Compared with traditional materials and installation techniques, multilayer systems offer ease of installation and are more cost-effective.

The working pressure of gas in buildings for domestic or commercial use is usually not more than 100 mbar (10 kPa). Only in very rare cases is a higher working pressure applied.

When higher pressures are applied, it is very important to take into account national regulations for the fitting of (industrial) gas installations.

It is likely that new pipe constructions or materials like multilayer pipe and PEX systems will be accepted in more countries in the coming years. At present, in the majority of countries only steel and copper pipework are permitted for gas supply within buildings, other materials being forbidden explicitly. However, it would be expected that national standards and laws will be changed in favour of the application of new installation techniques.

# Plastics piping systems — Multilayer pipe systems for indoor gas installations —

## Part 2: Code of practice

### 1 Scope

This part of ISO 17484 specifies the recommended practice for the installation of multilayer pipe systems in accordance with ISO 17484-1.

It is applicable to pipe systems used in buildings to supply gas with a maximum operating pressure (MOP) up to and including 5 bar<sup>1)</sup>.

This part of ISO 17484 specifies common basic principles for indoor gas systems. Users of this part of ISO 17484 should be aware that more detailed national standards and/or codes of practice can exist in ISO member countries. These existing regulations, as well as new national regulations, take precedence over this part of ISO 17484. It is intended to be applied in association with these national standards and/or codes of practice setting out the above-mentioned basic principles.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 17484-1, *Plastics piping systems — Multilayer pipe systems for indoor gas installations with a maximum operating pressure up to and including 5 bar (500 kPa) — Part 1: Specifications for systems*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 17484-1 and the following apply.

#### 3.1

##### **equipotential bond**

means of ensuring that metallic gas pipework and other metallic parts of the building are at the same potential

NOTE For safety reasons, this equipotential bonding is connected to earth.

---

1) 1 bar = 0,1 MPa = 0,1 N/mm<sup>2</sup> = 10<sup>5</sup> N/m<sup>2</sup>.

## SS-ISO 17484-2:2009 (E)

### 4 Design

#### 4.1 Reference to installation standards

This part of ISO 17484 gives functional recommendations for the design of gas pipework within buildings. In addition to this part of ISO 17484, more detailed national standards shall be applied.

NOTE 1 Installation techniques differ from country to country. These different techniques are often based on "installation tradition", differences in the construction of buildings, differences in climatic conditions, etc. For these reasons it is difficult to produce a general standard for installation. This is also why EN 1775 gives only functional recommendations. In many cases EN 1775 offers more than one solution. Each national standards body may select the most appropriate possibility that could be described in a more detailed way in a national standard.

National restrictions relative to the MOP shall be taken into account.

NOTE 2 Additional safety devices are required by some national standards bodies, for example excess flow valves, thermal valves or overpressure valves.

#### 4.2 Pipework components

The pipework components shall be appropriate for:

- the types of gases being distributed;

NOTE Particular attention should be given to the content of hydrogen sulfide, and to water content, dust content and water/hydrocarbon dew point with respect to materials, drainage of low points and filtration.

- the pipework design pressure;
- the location of the pipework;
- the pipework temperature under normal operating conditions.

### 5 Location of pipework

#### 5.1 General requirements for location of pipework

The location of the pipework shall minimize the risk of damage caused by, for example mechanical impact, UV exposure, accelerated corrosion, chemical attack, extreme temperatures and lightning, or else additional safety measures shall be applied.

The route and location of pipework built within the internal structure shall be such that third party damage is minimized and that any building movement does not lead to failure.

The route of pipework in buildings should be located in ventilated spaces.

Ventilation shall be adequate to safely dilute any small gas leak taking due account of the density of the gas (heavier than air, e.g. LPG, or lighter than air, e.g. natural gas).

Where it is not possible to achieve adequate ventilation, other solutions shall be applied, e.g. ventilated sleeves, ducts, pipes or the filling of the space around the pipe with inert materials, etc.

The route of the pipework shall be as short as practicable and the number of joints kept to a minimum.

The use of diagonal routes should always be avoided.

Where pipework is concealed, particular attention shall be given to the mode of construction and to corrosion protection of the pipework.