

SVENSK STANDARD

SS-EN 1264-3:2009

Fastställt/Approved: 2009-09-15
Publicerad/Published: 2009-10-21
Utgåva/Edition: 2
Språk/Language: engelska/English
ICS: 91.140.10

Vattenburet system för uppvärmning och kylning – Del 3: Dimensionering

Water based surface embedded heating and cooling systems – Part 3: Dimensioning

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-71009>

Hitta rätt produkt och ett leveranssätt som passar dig

Standarder

Genom att följa gällande standard både effektiviserar och säkrar du ditt arbete. Många standarder ingår dessutom ofta i paket.

Tjänster

Abonnemang är tjänsten där vi uppdaterar dig med aktuella standarder när förändringar sker på dem du valt att abonnera på.

På så sätt är du säker på att du alltid arbetar efter rätt utgåva.

e-nav är vår online-tjänst som ger dig och dina kollegor tillgång till standarder ni valt att abonnera på dygnet runt. Med e-nav kan samma standard användas av flera personer samtidigt.

Leveranssätt

Du väljer hur du vill ha dina standarder levererade. Vi kan erbjuda dig dem på papper och som pdf.

Andra produkter

Vi har böcker som underlättar arbetet att följa en standard. Med våra böcker får du ökad förståelse för hur standarder ska följas och vilka fördelar den ger dig i ditt arbete. Vi tar fram många egna publikationer och fungerar även som återförsäljare. Det gör att du hos oss kan hitta över 500 unika titlar. Vi har även tekniska rapporter, specifikationer och "workshop agreement".

Matriser är en översikt på standarder och handböcker som bör läsas tillsammans. De finns på sis.se och ger dig en bra bild över hur olika produkter hör ihop.

Standardiseringsprojekt

Du kan påverka innehållet i framtida standarder genom att delta i någon av SIS ca 400 Tekniska Kommittéer.

Find the right product and the type of delivery that suits you

Standards

By complying with current standards, you can make your work more efficient and ensure reliability. Also, several of the standards are often supplied in packages.

Services

Subscription is the service that keeps you up to date with current standards when changes occur in the ones you have chosen to subscribe to. This ensures that you are always working with the right edition.

e-nav is our online service that gives you and your colleagues access to the standards you subscribe to 24 hours a day. With e-nav, the same standards can be used by several people at once.

Type of delivery

You choose how you want your standards delivered. We can supply them both on paper and as PDF files.

Other products

We have books that facilitate standards compliance. They make it easier to understand how compliance works and how this benefits you in your operation. We produce many publications of our own, and also act as retailers. This means that we have more than 500 unique titles for you to choose from. We also have technical reports, specifications and workshop agreements.

Matrices, listed at sis.se, provide an overview of which publications belong together.

Standardisation project

You can influence the content of future standards by taking part in one or other of SIS's 400 or so Technical Committees.

Europastandarden EN 1264-3:2009 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 1264-3:2009.

Denna standard ersätter SS-EN 1264-3, utgåva 1 och SS-EN 15377-2:2008, utgåva 1.

The European Standard EN 1264-3:2009 has the status of a Swedish Standard. This document contains the official English version of EN 1264-3:2009.

This standard supersedes the Swedish Standard SS-EN 1264-3, edition 1 and SS-EN 15377-2:2008, edition 1.

! © Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

! © Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00.

Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), tel +46 8 555 520 00.

Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

SIS Förlag AB, SE 118 80 Stockholm, Sweden. Tel: +46 8 555 523 10. Fax: +46 8 555 523 11.

E-mail: sis.sales@sis.se Internet: www.sis.se

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 1264-3

September 2009

ICS 91.140.10

Supersedes EN 1264-3:1997, EN 15377-2:2008

English Version

Water based surface embedded heating and cooling systems - Part 3: Dimensioning

Systèmes de surfaces chauffantes et rafraîchissantes
hydrauliques intégrées - Partie 3 : Dimensionnement

Raumflächenintegrierte Heiz- und Kühlsysteme mit
Wasserdurchströmung - Teil 3: Auslegung

This European Standard was approved by CEN on 1 August 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

| | |
|--|-----------|
| Foreword..... | 3 |
| 1 Scope | 4 |
| 2 Normative References | 4 |
| 3 Terms, definitions and symbols..... | 4 |
| 4 Heating systems | 5 |
| 4.1 Floor heating systems..... | 5 |
| 4.1.1 Basic principles | 5 |
| 4.1.2 Boundary conditions | 6 |
| 4.1.3 Design | 7 |
| 4.1.4 Peripheral areas | 9 |
| 4.2 Ceiling heating systems..... | 9 |
| 4.2.1 Basic principles | 9 |
| 4.2.2 Boundary conditions | 10 |
| 4.2.3 Design | 10 |
| 4.3 Wall heating systems | 11 |
| 4.3.1 Basic principles | 11 |
| 4.3.2 Boundary conditions | 11 |
| 4.3.3 Design | 11 |
| 5 Cooling systems | 12 |
| 5.1 General..... | 12 |
| 5.1.1 Basic principles | 12 |
| 5.1.2 Temperature differences..... | 12 |
| 5.1.3 Regional dew point and standard indoor room temperature..... | 12 |
| 5.1.4 Temperature difference between room and cooling water | 12 |
| 5.1.5 Characteristic curves | 13 |
| 5.1.6 Field of characteristic curves | 13 |
| 5.1.7 Limit curve..... | 13 |
| 5.1.8 Thermal insulation..... | 13 |
| 5.2 Design | 13 |
| 5.2.1 Design value of specific cooling load | 13 |
| 5.2.2 Determination of the design flow (inlet) temperature and the design specific thermal output..... | 13 |
| 5.2.3 Determination of design cooling water flow rate | 15 |
| Annex A (normative) Figures | 16 |

Foreword

This document (EN 1264-3:2009) has been prepared by Technical Committee CEN/TC 130 "Space heating appliances without heat sources", the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2010, and conflicting national standards shall be withdrawn at the latest by March 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1264-3:1997. Together with EN 1264-4, this document also supersedes EN 15377-2.

The series of European Standards EN 1264 "*Water based surface embedded heating and cooling systems*" consists of the following parts:

- Part 1: Definitions and symbols;
- Part 2: Floor heating : Prove methods for the determination of the thermal output using calculation and test methods
- Part 3: Dimensioning;
- Part 4: Installation;
- Part 5: Heating and cooling surfaces embedded in floors, ceilings and walls — Determination of the thermal output.

The main change with respect to EN 1264-3:1997 is the expansion of the scope beyond floor heating, with the addition of ceiling and wall heating as well as cooling surfaces in floors, ceilings and walls.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard applies to heating and cooling systems embedded into the enclosure surfaces of the room to be heated or to be cooled.

This document deals with the use in practical engineering of the results coming from part 2 and 5 and is applicable to floor-, ceiling- and wall heating systems, as well floor-, ceiling- and wall cooling systems.

For heating systems, physiological limitations are taken into account when specifying the surface temperatures. In the case of floor heating systems the limitations are realised by a design based on the characteristic curves and limit curves determined in accordance with part 2 of this Standard.

For cooling systems, only a limitation with respect to the dew point is taken into account. In predominating practice, this means that physiological limitations are included as well.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1264-1:1997, *Water based surface embedded heating and cooling systems - Part 1: Definitions and symbols*

EN 1264-2, *Water based surface embedded heating and cooling systems - Part 2: Floor heating: Prove methods for the determination of the thermal output using calculation and test methods*

EN 1264-4, *Water based surface embedded heating and cooling systems - Part 4: Installation*

EN 1264-5, *Water based surface embedded heating and cooling systems — Part 5: Heating and cooling surfaces embedded in floors, ceilings and walls — Determination of the thermal output*

EN 12831, *Heating systems in buildings — Method for calculation of the design heat load*

EN 15243, *Ventilation for buildings — Calculation of room temperatures and of load and energy for buildings with room conditioning systems*

EN ISO 7730, *Ergonomics of the thermal environment - Analytical determination and interpretation of thermal comfort using calculation of the PMV and PPD indices and local thermal comfort criteria (ISO 7730:2005)*

3 Terms, definitions and symbols

For the purposes of this document, the definitions and symbols given in EN 1264-1:1997 apply.

4 Heating systems

4.1 Floor heating systems

4.1.1 Basic principles

4.1.1.1 Temperature difference between heating water and room

The temperature difference between the heating water and the room is calculated using equation (1), see EN 1264-2. In this equation, the effect of the temperature drop of the heating water is taken into account.

$$\Delta\vartheta_H = \frac{\vartheta_V - \vartheta_R}{\ln \frac{\vartheta_V - \vartheta_i}{\vartheta_R - \vartheta_i}} \quad (1)$$

4.1.1.2 Characteristic curve

The characteristic curve describes the relationship between the specific thermal output q of a system and the required temperature difference between heating water and room $\Delta\vartheta_H$. For a simplification, the specific thermal output is taken directly proportional to the temperature difference:

$$q = K_H \cdot \Delta\vartheta_H \quad (2)$$

where the gradient is $K_H = B \prod_i (a_i^{m_i})$, calculated in accordance with clause 6 of part 2 of this Standard, or the gradient K_H is experimentally determined in accordance with clause 9 of part 2 of this European Standard.

4.1.1.3 Field of characteristic curves

The field of characteristic curves of a floor heating system with a specific pipe spacing T shall at least contain the characteristic curves for values of the thermal resistance $R_{\lambda, B} = 0$, $R_{\lambda, B} = 0,05$, $R_{\lambda, B} = 0,10$ and $R_{\lambda, B} = 0,15$ ($\text{m}^2 \text{K}/\text{W}$) in accordance with part 2 of this European Standard (see Figure A.1). Values of $R_{\lambda, B} > 0,15$ ($\text{m}^2 \text{K}/\text{W}$) shall not be used if possible.

4.1.1.4 Limit curves

The limit curves in the field of characteristic curves describe in accordance with part 2 of this European Standard the relationship between the specific thermal output q and the temperature difference $\Delta\vartheta_H$ between the heating water and the room in the case where the physiologically agreed limit values of surface temperatures $\vartheta_{F, \max} = 29$ °C (occupied area) or $\vartheta_{F, \max} = 35$ °C (peripheral area) are reached¹. For bathrooms ($\vartheta_i = 24$ °C) the limit curve for $(\vartheta_{F, \max} - \vartheta_i) = 9$ K also applies. For design purposes, i.e. the determination of design values of the specific thermal output and the associated temperature difference between heating water and room, the limit curves are valid for the temperature drop σ of the heating water in a range of

$$0 \text{ K} < \sigma \leq 5 \text{ K}.$$

The limit curves are used to specify the maximum permissible flow temperature (refer to clause 4.1.3.2 and Figure A.4).

¹) National regulations may limit these temperatures to lower values.

4.1.1.5 Thermal inertia

The difference between the minimum and the maximum surface temperature of a floor heating system is low. This means for design purposes that no consideration of thermal inertia is required.

4.1.2 Boundary conditions

4.1.2.1 Flow pipes to adjacent rooms

The heat output of service pipes, not serving rooms through which they pass, must be limited by careful design, or by use of thermal insulation coverings, so that any room temperature should not be increased substantially. The heat output of service pipes passing through the room in question to adjacent rooms is taken into account if the same type of room usage can be assumed.

4.1.2.2 Downwards thermal insulation

To limit the heat flow through the floor to rooms below, the required thermal resistance of the insulating layer $R_{\lambda,ins}$ (see Figure A.5) shall be at minimum in accordance with Table 1 of EN 1264-4². It is calculated according to equation (3).

$$R_{\lambda,ins} = \frac{s_{ins}}{\lambda_{ins}} \quad (3)$$

where

s_{ins} is the thickness of the insulating layer in m, and

λ_{ins} is the thermal conductivity of the insulating layer in W/(m•K).

Depending on the construction of the floor heating system, the effective thickness of the insulating layer s_{ins} is determined differently:

For floor heating systems with flat thermal insulating panels (see Figure A.2), s_{ins} is identical with the thickness of the thermal insulating panel.

For floor heating systems with profiled thermal insulating panels (see Figure A.3), a surface-related weighted calculation is made for the effective thickness of the insulating layer s_{ins} :

$$s_{ins} = \frac{s_h \cdot (T - D) + s_l \cdot D}{T} \quad (4)$$

For profiled thermal insulating panels shaped differently from that shown in Figure A.3, the average effective thickness of the insulating layer shall be mathematically verified with an accordant application of equation (4).

NOTE In cases where formula (4) is non-applicable, an accordant calculation method shall be applied. For instance, in the case of system plates with attachment studs, the accordant calculation is given through: $s_{ins} = (\text{Volume of plate with studs included, divided by } A_F)$.

²⁾ National regulations may vary the requirements given in Table 1 of EN 1264-4.

4.1.3 Design

4.1.3.1 Design value of specific thermal output

The design value q_{des} to design a floor heating system for a room is equal to the standard heat load $Q_{N,f}$ (see part 1 of this Standard) divided by the heating surface A_F :

$$q_{des} = \frac{Q_{N,f}}{A_F} \quad (5)$$

The standard heat load $Q_{N,f}$ shall be calculated in accordance with EN 12831. Normally, the heat output Q_F of the floor heating system shall be equivalent to the standard heat load $Q_{N,f}$. If this is not possible, additional heating surfaces shall be used, see equation (12).

The design thermal output Q_F of the entire heating surface A_F is calculated as follows:"

$$Q_F = q \cdot A_F \quad (6)$$

Where peripheral area is used, q shall be distributed between the peripheral area A_R and the occupied area A_A according to a surface weighted calculation (see also clause 4.1.4):

$$q = \frac{A_R}{A_F} \cdot q_R + \frac{A_A}{A_F} \cdot q_A \quad (7)$$

where:

q_A is the specific thermal output of the occupied area

q_R is the specific thermal output of the peripheral area

4.1.3.2 Determination of the design flow temperature

The design flow temperature is determined for the room (or the rooms respectively) with the highest value $q_{max} = q_{des}$ of the specific thermal output (bathrooms excepted). In the rooms being heated, it is assumed that floor coverings with an uniform thermal conduction resistance are used. Generally for the design of floor heating systems in residential rooms, uniform floor coverings with $R_{\lambda,B} = 0,10 \text{ (m}^2 \cdot \text{K)/W}$ are assumed. In the case of using higher values $R_{\lambda,B}$, these values shall be taken.

For the room used for design, the temperature drop of the heating water is specified to $\sigma \leq 5 \text{ K}$. If necessary, a subdivision of this room into heating circuits should be performed. Under these conditions, the maximum value q_{max} may reach until the limit value q_G of the specific thermal output (see Figure A.4)³.

For the room with q_{max} , a pipe spacing is chosen with which q_{max} remains less or equal to the limit value q_G ($q_{max} \leq q_G$, see Figure A.4). For this, small pipe spacing is recommended. In case of $q_{max} \leq q_G$, design values of the temperature difference between flow heating water and room $\Delta\vartheta_{V,des} \leq \Delta\vartheta_{H,G} + 2,5 \text{ K}$ are permitted (see Figure A.4). The maximum permissible temperature difference between flow and room comes to:

$$\Delta\vartheta_{V,des} = \Delta\vartheta_{H,des} + \sigma / 2 \quad \text{where } \Delta\vartheta_{H,des} \leq \Delta\vartheta_{H,G} \quad (8)$$

The temperature drop σ in equation (8) and in equation (9), in figure A.4 is designated σ_{des} .

Equation (8) is valid for $\sigma/\Delta\vartheta_H \leq 0,5$.

³) This means that above the flow pipe the maximum floor temperature $\vartheta_{F,max}$ can be exceeded compared with the centre of the room, corresponding to the higher heating water temperature by $\sigma/2$.