

SVENSK STANDARD

SS-EN 1366-4:2006+A1:2010



Fastställt/Approved: 2010-04-26

Publicerad/Published: 2010-05-19 (Korrigerad version/Corrected version July 2010)

Utgåva/Edition: 1

Språk/Language: engelska/English

ICS: 13.220.50

Provning av brandmotstånd – Installationer i byggnader – Del 4: Linjära tätningar

Fire resistance tests for service installations – Part 4: Linear joint seals

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-73902>

Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.



Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 1366-4:2006+A1:2010 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 1366-4:2006+A1:2010.

Denna standard ersätter SS-EN 1366-4:2006, utgåva 1.

The European Standard EN 1366-4:2006+A1:2010 has the status of a Swedish Standard. This document contains the official English version of EN 1366-4:2006+A1:2010.

This standard supersedes the Swedish Standard SS-EN 1366-4:2006, edition 1.

I denna korrigerade version har följande ändring gjorts:

Referens till ersättande dokument på ENs förstasida och i foreword är rättat.

This corrected version contains the following correction:

The reference to the superseded document has been corrected on EN title page and in the foreword.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Uppllysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna uppllysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Standarden är framtagen av kommittén för Brandsäkerhet, SIS/TK 181.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 1366-4:2006+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2010

ICS 13.220.50

Supersedes EN 1366-4:2006

English Version

Fire resistance tests for service installations - Part 4: Linear joint seals

Essai de résistance au feu des installations de service -
Partie 4: Calfeutrements de joints linéaires

Feuerwiderstandsprüfungen für Installationen - Teil 4:
Abdichtungssysteme für Bauteilfugen

This European Standard was approved by CEN on 17 April 2006 and includes Amendment 1 approved by CEN on 4 March 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
Introduction	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Test equipment	8
5 Test conditions	8
5.1 Heating conditions.....	8
5.2 Pressure conditions	8
6 Test specimen	8
6.1 General.....	8
6.2 Size	9
6.3 Number of test specimens	9
7 Installation of test specimen	9
7.1 General.....	9
7.2 Supporting construction.....	9
7.2.1 General.....	9
7.2.2 Standard supporting construction.....	9
7.3 Test construction.....	10
7.4 Splice locations.....	10
7.5 Induced movement	11
8 Conditioning.....	11
9 Application of instrumentation.....	11
9.1 General.....	11
9.2 Thermocouples	11
9.2.1 Furnace thermocouples	11
9.2.2 Unexposed face thermocouples	11
9.2.3 Roving thermocouple.....	12
9.3 Deformation and deflection	12
9.4 Integrity measurement	12
10 Test procedure	12
10.1 General.....	12
10.2 Installation of test construction	12
10.3 Mechanically induced movement of the test specimen.....	12
10.4 Measurements and observations.....	12
11 Performance criteria	13
11.1 Insulation	13
11.2 Integrity.....	13
11.3 Expression of results	13
12 Test report	13
13 Field of direct application of test results	13
13.1 Orientation	13
13.2 Supporting construction.....	14
13.3 Seal position.....	15
13.4 Mechanically induced movement.....	15

Annex A (normative) Standard condition for linear joint seals with no mechanically induced movement of the joint faces	28
A.1 Standard condition	28
A.2 Test procedure.....	28
Annex B (normative) Standard condition for linear joint seals with mechanically induced movement of the joint faces	29
B.1 General	29
B.2 Standard condition(s)	29
B.2.1 Standard conditions for lateral movement	29
B.2.2 Standard condition for shear movement	30
B.3 Conditions for other movements	30
Annex C (informative) Guidance on the use of this European Standard	33
C.1 General	33
C.2 Application of the test.....	33
C.3 Test conditions	33
C.4 Specimen preparation.....	34
C.5 Notes on general performance criteria	34
C.6 Notes on validity of test results	34
C.7 Notes on Annex B.....	34

Foreword

This European Standard (EN 1366-4:2006+A1:2010) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2010, and conflicting national standards shall be withdrawn at the latest by October 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1366-4:2006.

This document includes Amendment 1, approved by CEN on 2010-03-04.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** **A1**.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Construction Products Directive.

EN 1366 'Fire resistance tests for service installations' consists of the following Parts:

- Part 1: Ducts
- Part 2: Fire dampers
- Part 3: Penetration seals
- Part 4: Linear joint seals
- Part 5: Service ducts and shafts
- Part 6: Raised access and hollow core floors
- Part 7: Conveyor systems and their closures
- Part 8: Smoke extraction ducts
- Part 9: Single compartment smoke extraction ducts
- Part 10: Smoke control dampers
- Part 11: Fire protection system for essential services (in course of preparation)¹⁾

¹⁾ To be published.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Introduction

Linear joint seals are positioned in joints, voids, gaps or other discontinuities within one or between two or more construction elements.

Normally such openings are denoted as linear because their length is greater than their width - defined by a typical ratio of at least 10:1 in practice.

Joints are present in buildings due to the following:

- a) acceptable dimensional tolerances between two or more building elements, e.g. between non-load bearing walls and floors;
- b) by design to accommodate various movements induced by thermal differentials, seismicity and movement induced by wind loads;
- c) as a result of inadequate design, inaccurate assembly, repairs or damage to the building.

The purpose of the tests in this European Standard is to assess:

- d) the effect of a linear joint seal on the integrity and insulation of the construction;
- e) the integrity and insulation performance of the linear joint seal;
- f) the effect of movement within the supporting construction on the fire performance of linear joint seals (see Annex B).

The results of these tests are one factor in assessing the fire performance of joint seals.

Annex A describes the principles of standard conditions for linear joint seals where no mechanically induced relative movement occurs between the joint faces.

Annex B provides standard conditions for joints with mechanically induced movement of opposing joint faces during the fire resistance test.

CAUTION The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, during their testing and during the disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard specifies a method for determining the fire resistance of linear joint seals based on their intended end use. This European Standard is used in conjunction with EN 1363-1.

The following tests are included in this European Standard:

- no mechanically induced movement;
- mechanically induced movement, either prior to or during fire exposure.

This European Standard does not provide quantitative information on the rate of leakage of smoke and/or hot gases, or on the transmission or generation of fumes.

The load-bearing capacity of a linear joint seal is not addressed in this European Standard.

2 Normative references

The following referenced documents are indispensable for the application of this European Standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 1363-1:1999 and EN ISO 13943:2000 and the following apply.

3.1

linear joint

linear void having a length to width ratio of at least 10:1 within one or between two or more juxtaposed construction elements

NOTE Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs.

3.2

linear joint seal

system designed to maintain the fire separating function and, if relevant, to accommodate a specified degree of movement within the linear joint

3.3

movement capability

maximum amount of movement the joint seal is able to tolerate as stated by the manufacturer or the sponsor, expressed as a percentage of the nominal width

NOTE The movement capability is usually the same over the entire range of the nominal widths.

3.4

nominal joint width

specified width of a joint seal, to be selected by the manufacturer or test sponsor