

# SVENSK STANDARD

## SS-EN 54-5:2017+A1:2018

Fastställt/Approved: 2018-08-16  
Utgåva/Edition: 1  
Språk/Language: engelska/English  
ICS: 13.220.20



---

### **Brand och räddning – Branddetekterings- och brandlarmsystem – Del 5: Värmedetektorer av punkttyp**

### **Fire detection and fire alarm systems – Part 5: Heat detectors – Point heat detectors**



# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Europastandarden EN 54-5:2017+A1:2018 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 54-5:2017+A1:2018.

Denna standard ersätter SS-EN 54-5:2017, utgåva 3.

The European Standard EN 54-5:2017+A1:2018 has the status of a Swedish Standard. This document contains the official version of EN 54-5:2017+A1:2018.

This standard supersedes the SS-EN 54-5:2017, edition 3.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna upplysningar om svensk och utländsk standard.*

*Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS, who can also provide general information about Swedish and foreign standards.*

Denna standard är framtagen av kommittén för Branddetektorer, brandlarmsystem, SIS/TK 360/AG 02.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.



EUROPEAN STANDARD

**EN 54-5:2017+A1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2018

ICS 13.220.20

Supersedes EN 54-5:2017

English Version

## Fire detection and fire alarm systems - Part 5: Heat detectors - Point heat detectors

Systèmes de détection et d'alarme incendie - Partie 5 :  
DéTECTEURS de chaleur - DéTECTEURS ponCTUELS

Brandmeldeanlagen - Teil 5: Wärmemelder -  
Punktförmige Melder

This European Standard was approved by CEN on 23 October 2016 and includes Amendment 1 approved by CEN on 10 April 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

<b>Contents</b>	<b>Page</b>
European foreword .....	5
<b>1 Scope</b> .....	<b>7</b>
<b>2 Normative references</b> .....	<b>7</b>
<b>3 Terms, definitions and abbreviations</b> .....	<b>8</b>
3.1 Terms and Definitions .....	8
3.2 Abbreviations.....	8
<b>4 Product characteristics</b> .....	<b>8</b>
4.1 General .....	8
4.1.1 Heat Response Categories .....	8
4.2 Operational reliability .....	9
4.2.1 Position of heat sensitive elements.....	9
4.2.2 Individual alarm indication .....	9
4.2.3 Connection of ancillary devices.....	10
4.2.4 Monitoring of detachable detectors.....	10
4.2.5 Manufacturer's adjustments.....	10
4.2.6 On-site adjustment of response behaviour .....	10
4.2.7 Software controlled detector (when provided).....	10
4.3 Nominal activation conditions/sensitivity.....	12
4.3.1 Directional dependence .....	12
4.3.2 Static response temperature .....	12
4.3.3 Response times from typical application temperature .....	12
4.3.4 Response times from 25 °C.....	12
4.3.5 Response times from high ambient temperature .....	12
4.3.6 Reproducibility.....	12
4.4 Response delay (response time) .....	13
4.4.1 Additional tests for suffix S detectors .....	13
4.4.2 Additional tests for suffix R detectors.....	13
4.5 Tolerance to supply voltage - Variation in supply parameters.....	13
4.6 Durability of Nominal activation conditions/sensitivity .....	13
4.6.1 Temperature resistance.....	13
4.6.2 Humidity resistance.....	13
4.6.3 Corrosion resistance: Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance) .....	14
4.6.4 Vibration resistance .....	14
4.6.5 Electrical stability: Electromagnetic Compatibility (EMC), Immunity tests (operational) .....	14
<b>5 Testing, assessment and sampling methods</b> .....	<b>14</b>
5.1 General .....	14
5.1.1 Atmospheric conditions for tests.....	14
5.1.2 Operating conditions for tests .....	15
5.1.3 Mounting arrangements.....	15
5.1.4 Tolerances.....	15
5.1.5 Measurement of response time .....	15
5.1.6 Provision for tests .....	16
5.1.7 Test schedule.....	16

5.2	Operational reliability .....	20
5.2.1	Position of heat sensitive elements.....	20
5.2.2	Individual alarm indication .....	20
5.2.3	Connection of ancillary devices.....	20
5.2.4	Monitoring of detachable detectors.....	21
5.2.5	Manufacturer's adjustments.....	21
5.2.6	On-site adjustment of response behaviour .....	21
5.2.7	Software controlled detectors (when provided).....	21
5.3	Nominal activation conditions/sensitivity .....	21
5.3.1	Directional dependence .....	21
5.3.2	Static response temperature .....	22
5.3.3	Response times from typical application temperature .....	22
5.3.4	Response times from 25 °C.....	23
5.3.5	Response times from high ambient temperature .....	24
5.3.6	Reproducibility.....	25
5.4	Response delay (response time) .....	25
5.4.1	Additional tests for suffix S detectors .....	25
5.4.2	Additional test for suffix R detectors.....	27
5.5	Tolerance to supply voltage.....	28
5.5.1	Variation in supply parameters .....	28
5.6	Durability of Nominal activation conditions/sensitivity .....	29
5.6.1	Temperature resistance.....	29
5.6.2	Humidity resistance.....	31
5.6.3	Corrosion resistance.....	33
5.6.4	Vibration resistance .....	34
5.6.5	Electrical stability.....	38
6	Assessment and verification of constancy of performance (AVCP).....	40
6.1	General .....	40
6.2	Type testing .....	40
6.2.1	General .....	40
6.2.2	Test samples, testing and compliance criteria.....	41
6.2.3	Test reports .....	41
6.3	Factory production control (FPC).....	41
6.3.1	General .....	41
6.3.2	Requirements.....	42
6.3.3	Product specific requirements .....	44
6.3.4	Initial inspection of factory and FPC.....	45
6.3.5	Continuous surveillance of FPC .....	45
6.3.6	Procedure for modifications.....	46
6.3.7	One-off products, pre-production products, (e.g. prototypes) and products produced in very low quantities .....	46
7	Classification .....	47
8	Marking, labelling and packaging.....	47
<b>Annex A (normative) Heat tunnel for response time and response temperature measurements .....</b>		<b>48</b>
<b>Annex B (informative) Information concerning the construction of the heat tunnel.....</b>		<b>49</b>
<b>Annex C (informative) Derivation of upper and lower limits of response times.....</b>		<b>52</b>
<b>Annex D (informative) Apparatus for impact test .....</b>		<b>55</b>
<b>Annex E (informative) Data supplied with point heat detectors.....</b>		<b>57</b>

**SS-EN 54-5:2017+A1:2018 (E)**

<b>Annex ZA (informative) Relationship of this European Standard with Regulation (EU) No.305/2011 .....</b>	<b>58</b>
<b>ZA.1 Scope and relevant characteristics .....</b>	<b>58</b>
<b>ZA.2 System of Assessment and Verification of Constancy of Performance (AVCP) .....</b>	<b>60</b>
<b>ZA.3 Assignment of AVCP tasks .....</b>	<b>60</b>
<b>Bibliography .....</b>	<b>62</b>



## European foreword

This document (EN 54-5:2017+A1:2018) has been prepared by Technical Committee CEN/TC 72 "Fire detection and fire alarm systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2019, and conflicting national standards shall be withdrawn at the latest by August 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights."

This document includes Amendment 1 approved by CEN on 2018-04-10.

This document supersedes  $\boxed{A_1}$  EN 54-5:2017  $\langle A_1 \rangle$ .

The start and finish of text introduced or altered by amendment is indicated in the text by tags  $\boxed{A_1}$   $\langle A_1 \rangle$ .

EN 54-5 has been revised as follows:

Inclusion of new clauses and annexes:

- Clause 6 Assessment and verification of constancy of performance (AVCP)
- Clause 7 Classification and designation
- Clause 8 Marking, labelling and packaging
- Annex E (informative) Data supplied with point heat detectors

The main technical changes are as follows:

- Applying the latest EN 50130-4:2011 EMC for immunity tests.

The editorial changes are as follows:

- Changes from classes to Categories
- Editorial changes in a number of clauses, such as software and General, in order to conform to the regulation.

This document has been prepared under a standardization request given to CEN/CENELEC by the European Commission and the European Free Trade Association, and supports the basic requirements of Regulation (EU) 305/2011.

For relationship with EU Regulation, see informative Annex ZA, which is an integral part of this document.

EN 54, *Fire detection and fire alarm systems*, consists of the following parts:

- Part 1: Introduction
- Part 2: Control and indicating equipment

**SS-EN 54-5:2017+A1:2018 (E)**

- Part 3: Fire alarm devices – Sounders
- Part 4: Power supply equipment
- Part 5: Heat detectors – Point heat detectors
- Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization
- Part 10: Flame detector – Point detectors
- Part 11: Manual call points
- Part 12: Smoke detectors – Line detector using an optical light beam
- Part 13: Compatibility assessment of system components
- Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance (CEN/TS)
- Part 16: Voice alarm control and indicating equipment
- Part 17: Short circuit isolators
- Part 18: Input/output devices
- Part 20: Aspirating smoke detectors
- Part 21: Alarm transmission and fault warning routine equipment
- Part 22: Line-type heat detectors
- Part 23: Fire alarm devices – Visual alarms
- Part 24: Components of voice alarm systems – Loudspeakers
- Part 25: Components using radio links and system requirements
- Part 26: Carbon monoxide detectors – Point detectors
- Part 27: Duct smoke detectors
- Part 28: Non-resettable (digital) line type heat detectors
- Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors
- Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors
- Part 31: Multi-sensor detector – Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors
- Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems (CEN/TS)

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to [www.cen.eu](http://www.cen.eu).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## 1 Scope

This European Standard specifies the requirements, test methods and performance criteria for point heat detectors intended for use in fire detection and fire alarm systems installed in and around buildings (see EN 54-1:2011).

This European Standard provides for the assessment of verification of constancy of performance (AVCP) of point heat detectors to this EN.

For other types of heat detector, or for detectors intended for use in other environments, this standard should only be used for guidance.

Heat detectors with special characteristics and developed for specific risks are not covered by this standard.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems - Part 1: Introduction*

EN 50130-4:2011, *Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:1994, *Environmental testing - Part 1: General and guidance (IEC 60068-1:1988)*

EN 60068-2-1:2007, *Environmental testing - Part 2-1: Tests - Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-2:2007, *Environmental testing - Part 2-2: Tests - Test B: Dry heat (IEC 60068-2-2:2007)*

EN 60068-2-6:2008, *Environmental testing - Part 2-6: Tests - Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:2008)*

EN 60068-2-27:2009, *Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock (IEC 60068-2-27:2009)*

EN 60068-2-30:2005, *Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

EN 60068-2-42:2003, *Environmental testing - Part 2-42: Tests - Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-78:2013, *Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state (IEC 60068-2-78:2012)*

ISO 209:2007, *Aluminium and aluminium alloys — Chemical composition*