

# Teknisk rapport


## SIS-CEN/TR 12101-4:2009

Publicerad/Published: 2018-09-18  
Utgåva/Edition: 1  
Språk/Language: engelska/English  
ICS: 13.220.20;23.120

---

### **System och komponenter för rök- och brandgaser – Del 4: Installation, komponenter, underhåll mm.**

### **Smoke and heat control systems – Part 4: Installed SHEVS systems for smoke and heat ventilation**



# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Denna tekniska rapport är inte en svensk standard. Detta dokument innehåller den engelska språkversionen av CEN/TR 12101-4:2009.

This Technical Report is not a Swedish Standard. This document contains the English version of CEN/TR 12101-4:2009.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Uppllysningar om sakinnehållet i detta dokument lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna uppllysningar om nationell och internationell standard.*

*Information about the content of this document is available from the SIS, Swedish Standards Institute, telephone +46 8 555 520 00. Standards may be ordered from SIS, who can also provide general information about national and international standards.*

Dokumentet är framtaget av kommittén för Brandgasventilation, SIS/TK 360/AG 06.

Har du synpunkter på innehållet i det här dokumentet, vill du delta i ett kommande revideringsarbete eller vara med och ta fram standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.



ICS 13.220.99

English Version

## Smoke and heat control systems - Part 4: Installed SHEVS systems for smoke and heat ventilation

Systèmes pour le contrôle des fumées et de la chaleur -  
Partie 4 : Systèmes SEFCV installés pour l'évacuation de  
fumées et de chaleur par ventilation

Rauch- und Wärmefreihaltung - Teil 4: Anlagen zur Rauch-  
und Wärmefreihaltung im eingebauten Zustand

This Technical Report was approved by CEN on 9 September 2008. It has been drawn up by the Technical Committee CEN/TC 191.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: rue de Stassart, 36 B-1050 Brussels**

# Contents

Page

Foreword.....	5
Introduction .....	6
1 Scope .....	7
2 Normative references .....	7
3 Terms and definitions .....	8
4 Description of the principles of operation for smoke and heat control systems .....	11
4.1 Smoke and heat control systems which rely on the principle of the creation of a smoke layer.....	11
4.1.1 Smoke layers exhausted by natural vents .....	11
4.1.2 Layers of smoke exhausted by powered vents .....	11
4.2 Smoke free areas by differential pressure systems.....	11
4.3 Air renewal of the room with fresh air by dilution of smoke.....	11
5 Description of the combination of products for construction of SHEVS .....	12
5.1 General.....	12
5.2 General requirements.....	12
5.3 Requirements for smoke layer systems with natural ventilators .....	13
5.4 Requirements for smoke layer systems with powered ventilators .....	13
5.4.1 Requirements for power supplies for powered smoke and heat exhaust ventilation systems.....	13
5.4.2 Requirements for powered smoke and heat exhaust systems.....	14
5.5 Requirements for smoke free area systems by differential pressure .....	14
5.6 Requirements for smoke control by air renewal of the room with fresh air by dilution of smoke.....	14
6 Air Inlet.....	14
6.1 General requirements.....	14
6.2 Fire behaviour requirements .....	15
6.2.1 Performance parameters under fire conditions .....	15
6.2.2 Reaction to fire.....	15
6.2.3 Resistance to fire .....	15
6.3 Geometric areas for natural air inlets .....	15
7 Tubes, cables and accessories .....	16
7.1 General requirements.....	16
7.2 Fire behaviour requirements .....	16
7.2.1 Performance parameters under fire conditions .....	16
7.2.2 Reaction to fire of cables and tubes .....	17
7.2.3 Resistance to fire of cables and tubes .....	17
7.3.2 Requirements for electrical supplies.....	17
7.3.3 Isolators and switches on power lines.....	17
7.3.4 Enclosures for electrical components.....	17
7.3.5 Extra low voltage operated components .....	17
7.3.6 Sizing of electrical cables and related equipment .....	17
7.4 Requirements for pneumatic supplies .....	18
7.4.1 Requirements for pneumatic supplies using compressors.....	18
7.4.2 Requirements for pneumatic lines.....	18
7.4.3 Mechanical cables .....	18
8 Requirements for installation.....	18
8.1 General requirements for installation.....	18

8.2	Requirements for installation of a SHEVS .....	18
8.3	Requirements for installation of power supplies .....	19
8.4	Requirements for installation of controls .....	19
8.5	Access to components .....	19
8.6	Requirements for installation of powered SHEVS .....	20
8.7	Requirements for installation of air inlets .....	20
8.8	General requirements for installation of smoke barriers .....	20
8.8.1	Fastenings and adjacent surfaces .....	20
8.8.2	Maximum gaps .....	20
8.8.3	Response time .....	21
8.9	Functional test .....	21
9	Handing-over and commissioning .....	21
9.1	Requirements for commissioning of the system .....	21
9.2	Requirements for acceptance report of the system .....	22
9.3	Technical information report .....	22
9.4	Specific requirements for powered smoke ventilation systems .....	22
10	Routine checking .....	23
11	Maintenance .....	23
11.1	General .....	23
11.2	Scope of maintenance .....	23
11.3	Functional test .....	23
11.4	Maintenance operations .....	23
11.5	Availability .....	23
<b>Annex A (normative) Pneumatic system leakage testing .....</b>		<b>25</b>
<b>Annex B (normative) Air flow measurements .....</b>		<b>26</b>
B.1	Air flow requirements in powered ventilation systems .....	26
B.2	Measurement of air flow for ducted systems .....	26
B.2.1	Selection of measurement method .....	26
B.2.2	Selection of cross section .....	26
B.2.3	Measurement of air flow .....	26
<b>Annex C (informative) Drawings of example systems .....</b>		<b>27</b>
<b>Annex D (informative) Detailed engineering plan .....</b>		<b>38</b>
D.1	Detailed engineering plan for smoke flow and pressure control within the premises .....	38
D.1.1	General .....	38
D.1.2	Requirements for SHEVS intended to form a smoke layer .....	38
D.1.3	Requirements for natural smoke and heat exhaust ventilation systems .....	38
D.1.4	Requirements for powered smoke exhaust systems .....	39
D.1.5	Functioning and requirements for differential pressure systems .....	39
D.1.6	Requirements for differential pressure systems .....	39
D.2	Requirements for assembly, commissioning, inspection, testing and maintenance of natural smoke exhaust systems .....	40
<b>Annex E (informative) Requirements specific to powered smoke exhaust systems (powered fans, dampers, ducts etc) – Mounting and testing .....</b>		<b>41</b>
E.1	Requirements for mounting and commissioning .....	41
E.1.1	General .....	41
E.1.2	Mounting of powered smoke and heat exhaust systems .....	41
E.1.3	Mounting of the operating devices .....	43
E.1.4	Mounting of control devices and circuits .....	43
E.1.5	Mounting of components of powered smoke exhaust systems .....	45
E.2	Requirements for acceptance and testing .....	46
E.2.1	General .....	46
E.2.2	Acceptance and testing of powered smoke and heat exhaust system .....	47
E.3	Requirements for routine checking .....	49
E.4	Requirements for maintenance .....	50
E.4.1	General .....	50

**SIS-CEN/TR 12101-4:2009 (E)**

<b>E.4.2</b>	<b>Scope of maintenance</b> .....	<b>50</b>
<b>E.4.3</b>	<b>Functional test</b> .....	<b>50</b>
<b>E.4.4</b>	<b>Maintenance operations</b> .....	<b>50</b>
<b>E.4.5</b>	<b>Availability</b> .....	<b>50</b>
	<b>Bibliography</b> .....	<b>51</b>



## Foreword

This document (CEN/TR 12101-4:2009) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European document (Technical Report) has the general title "*Smoke and heat control systems*" and consists of the following separate parts:

- *Part 1: Specifications for smoke barriers*
- *Part 2: Specification for natural smoke and heat exhaust ventilators*
- *Part 3: Specification for powered smoke and heat exhaust ventilators*
- *Part 4: Installed SHEVS systems for smoke and heat ventilation*
- *Part 5: Guidelines on functional recommendations and calculation methods for smoke and heat exhaust ventilation systems (published as CEN/TR 12101-5)*
- *Part 6: Specification for pressure differential systems - Kits*
- *Part 7: Smoke control ducts*
- *Part 8: Smoke control dampers*
- *Part 9: Control panels*
- *Part 10: Power supplies*

**SIS-CEN/TR 12101-4:2009 (E)****Introduction**

Smoke and heat exhaust ventilation systems (SHEVS) create a smoke free layer above the floor by removing smoke and thus improve the conditions for the safe escape and/or rescue of people and animals. It contributes to the protection of property and permits the fire to be fought while still in its early stages. They also exhaust hot gases released by a fire in the developing stage.

The use of smoke and heat exhaust ventilation systems to create smoke free areas beneath a buoyant smoke layer has become widespread. Their value in assisting in the evacuation of people from construction works, reducing fire damage and financial loss by preventing smoke logging, facilitating fire fighting, reducing roof temperatures and retarding the lateral spread of fire is firmly established. For these benefits to be obtained it is essential that smoke and heat exhaust ventilators operate fully and reliably whenever called upon to do so during their installed life. A heat and smoke exhaust ventilation system is a scheme of safety equipment intended to perform a positive role in a fire emergency.

Components for smoke and heat exhaust ventilation systems should be installed as part of a properly designed smoke and heat exhaust ventilation system.

Smoke and heat exhaust ventilation systems help to:

- keep the escape and access routes free from smoke;
- facilitate fire fighting operations by creating a smoke free layer;
- delay and/or prevent flashover and thus full development of the fire;
- protect equipment and furnishings;
- reduce thermal effects on structural components during a fire;
- reduce damages caused by thermal decomposition products and hot gases.

A powered smoke exhaust system can also be used for the realisation of the following purposes:

- creation of a negative pressure differential facing the direction of escape for the prevention of the spread of smoke;
- local dilution of smoke within occupied zones.

Natural smoke and heat exhaust ventilators are devices fitted into the roof and/or upper walls of a construction works to allow smoke and fire gases to be exhausted from the construction works when driven by thermal buoyancy inherent in those gases. It is essential that they are able to open, and/or to remain open in the event of a fire and to fulfil their function even when climatic and weather conditions are unfavourable.

Depending on the building geometry and siting of the building with regard to neighbouring buildings, and design criteria, natural smoke and heat exhaust ventilators can be used instead of powered smoke and heat ventilators.

This Technical Report sets down the testing requirements for the system when installed to ensure that it operates in a safe and reliable manner. Commissioning, periodic maintenance and servicing requirements are stated as well as the users' responsibilities for ensuring that the system is always for use in case of fire.

Components of the SHEVS should be designed or chosen to meet the specific performance requirement of the system.

Without proper installation of all of its components, the SHEVS could not operate correctly nor meet the performance targets for which it has been designed.

Commissioning is necessary to check the SHEVS operates in accordance with its design. The system has to be permanently available for operation. This can only be achieved when checked and maintained.

## 1 Scope

This Technical Report applies to SHEVS when installed in a building. This Technical Report specifies the ability of the system to meet the required performances of the SHEVS as specified by the design of the system. This Technical Report is to help to translate the detailed engineering plan into an installed system, but it does not state how the design is made. This Technical Report also covers requirements for components and compatibility between components to ensure that the requirements on the installed system will be met. This Technical report includes requirements for the assembly, installation, commissioning, function testing, maintenance, periodic servicing and routine testing of SHEVS.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1366-8, *Fire resistance tests for service installations — Part 8: Smoke extraction ducts*

EN 1366-9, *Fire resistance tests for service installations — Part 9: Single compartment smoke extraction ducts*

prEN 1366-10, *Fire resistance tests for service installations — Part 10: Smoke control dampers*

EN 12101-1, *Smoke and heat control systems — Part 1: Specification for smoke barriers*

EN 12101-2, *Smoke and heat control systems — Part 2: Specification for natural smoke and heat exhaust ventilators*

EN 12101-3, *Smoke and heat control systems — Part 3: Specification for powered smoke and heat exhaust ventilators*

EN 12101-6, *Smoke and heat control systems — Part 6: Specification for pressure differential systems — Kits*

prEN 12101-9, *Smoke and heat control systems — Part 9: Control panels*

EN 12101-10, *Smoke and heat control systems — Part 10: Power supplies*

EN 13501-1, *Fire classification of construction products and building elements — Part 1: Classification using test data from reaction to fire tests*

EN 13501-2, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 13501-3, *Fire classification of construction products and building elements — Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

EN 13501-4, *Fire classification of construction products and building elements — Part 4: Classification using data from fire resistance tests on components of smoke control systems*

EN 60529, *Degrees of protection provided by enclosures (IP code)* (IEC 60529:1989)

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements* (ISO 5167-1:2003)

ISO 2408, *Steel wire ropes for general purposes — Minimum requirements*