

# Teknisk specifikation


## SIS-ISO/CIE TS 22012:2019

Publicerad/Published: 2019-03-21  
Utgåva/Edition: 1  
Språk/Language: engelska/English  
ICS: 12.020

---

### **Ljus och belysning – Bestämmande av bibehållningsfaktor – Arbetsmetod**

### **Light and lighting – Maintenance factor determination – Way of working**



# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.


## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Denna tekniska specifikation är inte en svensk standard. Detta dokument innehåller den engelska språkversionen av ISO/CIE TS 22012:2019, utgåva 1.

This Technical Specification is not a Swedish Standard. This document contains the English language version of ISO/CIE TS 22012:2019, edition 1.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Uppllysningar om sakinnehållet i detta dokument lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna uppllysningar om nationell och internationell standard.*

*Information about the content of this document is available from the SIS, Swedish Standards Institute, telephone +46 8 555 520 00. Standards may be ordered from SIS, who can also provide general information about national and international standards.*

Detta dokument är framtaget av kommittén för Ljus och belysning, SIS/TK 380/AG 03.

Har du synpunkter på innehållet i det här dokumentet, vill du delta i ett kommande revideringsarbete eller vara med och ta fram standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.

SIS-ISO/CIE TS 22012:2019 (E)

Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Symbols and units</b> .....	<b>3</b>
<b>5 Influencing factors</b> .....	<b>4</b>
5.1 Luminaire and/or light source characteristics.....	4
5.2 Recoverable external factors.....	4
5.3 Non-recoverable external factors.....	4
5.4 Maintenance period, cleaning, replacement and surface refurbishment interval.....	4
<b>6 Maintenance factor determination</b> .....	<b>5</b>
6.1 Basic description of the method.....	5
6.2 Luminous flux factor.....	5
6.2.1 Luminous flux factor determination — General.....	5
6.2.2 Luminous flux factor determination — Special case: Constant light output (CLO).....	6
6.3 Survival factor.....	8
6.3.1 Survival factor description.....	8
6.3.2 Spot replacement regime.....	8
6.3.3 Group replacement regime.....	8
6.3.4 Regime combinations.....	9
6.4 Luminaire maintenance factor.....	9
6.4.1 Luminaire maintenance factor description.....	9
6.4.2 Indoor luminaires.....	10
6.4.3 Outdoor luminaires.....	10
6.5 Surface maintenance factor.....	10
<b>7 Use of the maintenance factor</b> .....	<b>10</b>
7.1 Lighting design using the maintenance factor.....	10
7.2 Documentation.....	11
7.2.1 Documentation of maintenance factor determination.....	11
7.2.2 Documentation of maintenance schedules.....	11
7.3 Lighting verification using the maintenance factor.....	11
<b>Annex A (informative) Maintenance factor determination examples</b> .....	<b>13</b>
<b>Annex B (informative) Luminous flux factor <math>f_{LF}</math> tables (Typical examples)</b> .....	<b>17</b>
<b>Annex C (informative) Luminaire maintenance factor <math>f_{LM}</math> determination examples</b> .....	<b>19</b>
<b>Annex D (informative) Surface maintenance factor <math>f_{SM}</math> examples</b> .....	<b>24</b>
<b>Bibliography</b> .....	<b>28</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

ISO collaborates closely with the International Commission on Illumination (CIE) on all matters of standardization for light and lighting.

This document was prepared by Technical Committee ISO/TC 274, *Light and lighting*. The document has been jointly prepared with CIE JTC 11, *Light and Lighting — Maintenance factor — Way of working*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

**SIS-ISO/CIE TS 22012:2019 (E)**

## Introduction

Continuous maintenance of lighting installations is essential as it ensures that the performance of a system stays within the design limits and promotes safety and efficient use of energy. In the design phase this is taken into account through the use of the maintenance factor. The maintenance factor combines several different factors such as the assumed product/installation behaviour, the environmental parameters and maintenance and cleaning schedules.

The methodology of determining the maintenance factor has been extensively documented by CIE (see [Clause 2](#) and bibliography). However, as the focus of these technical reports was predominantly on incandescent and gas discharge light sources, more clarity is needed to ensure the proper use/translation of the existing methodology towards technologies such as light emitting diodes (LED).

Technologies such as LED distinguish themselves from other technologies by their long lifetime, low failure rate and their integration of components which were previously seen as separate components. As such the previous methods used to determine the depreciation and survival of luminaires might seem unusable and cause uncertainty. However, based on work by IEC (see [Clause 2](#)) the luminous flux depreciation and light source failure parameters have now been (re)established for LED-based light sources and allow for translation into an updated way of working to determine the maintenance factor using the existing CIE methodology and data for luminaire and surface dirt depreciation.

This document combines insights from IEC standards with regard to product performance of luminaires and light sources currently in the market with the existing determination methodology from CIE Technical Reports. Furthermore, it references the data in the CIE Technical Reports with regard to the impact of the environment on luminaires (accumulation of dirt on surfaces and luminaires).

This document provides the following:

- background information with respect to the principles of the maintenance factor and the relevant parameters for indoor and outdoor applications;
- a detailed way of working on how to apply the maintenance factor determination method (as described in CIE 154:2003 and CIE 097:2005) for outdoor and indoor lighting designs using the technologies available in the market;
- explanation and examples on how to apply the maintenance factor and how to ensure proper operation over time corresponding to the determined values.

# Light and lighting — Maintenance factor determination — Way of working

## 1 Scope

This document specifies a standardized way of working for determining the maintenance factor for both outdoor and indoor lighting installations using the methodology as described in CIE 154:2003 and CIE 097:2005.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CIE 097:2005, *Maintenance of Indoor Electric Lighting Systems*

CIE 154:2003, *Maintenance of Outdoor Lighting Systems*

CIE S 017, *ILV International Lighting Vocabulary*

IEC 62722-2-1, *Luminaire performance — Part 2-1: Particular requirements for LED luminaires*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in CIE S 017 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

### 3.1

#### **abrupt failure value**

#### **AFV**

percentage of LED based products failing to operate at median useful life ( $L_x$ )

[SOURCE: IEC 62717:2014+AMD1:2015, modified — generalized to products]

### 3.2

#### **cleaning interval**

planned time between cleaning of (parts of) the products and/or components

### 3.3

#### **CLO lifetime**

time over which the CLO (3.5) feature ensures a constant luminous flux

### 3.4

#### **component replacement interval**

planned time between replacement of one or more specified luminaire component(s)

**SIS-ISO/CIE TS 22012:2019 (E)****3.5****CLO****constant light output**

functionality to constantly adjust the luminous flux of the light source based on the known or predicted depreciation behaviour of the light source to enable a constant luminous flux over time

**3.6****failure probability** $p_f$ 

probability that the component (e.g. light source, luminaire) catastrophically fails

Note 1 to entry: Failure probability is expressed as a factor.

**3.7****installation lifetime**

time over which the installation is expected to function as designed

**3.8****maintenance period**

total time over which the maintenance is planned

Note 1 to entry: Within a single maintenance period different maintenance cycles can be planned for different activities (e.g. cleaning, light source replacement).

Note 2 to entry: The maintenance period is often expressed in years.

**3.9****median useful life** $L_x$ 

length of time until 50 % of a population of operating LED products reaches gradual light output degradation of a percentage  $x$

**3.10****surface refurbishment interval**

planned time between surface refurbishment instances where the reflecting properties of the room or area surfaces are restored to their original state, including cleaning or painting of interior surfaces such as walls and ceilings

Note 1 to entry: The concept 'surface refurbishment interval' does not refer to surfaces which are an integral part of the luminaire.

**3.11****survival probability** $p_s$ 

probability that a component continues to operate at a certain point in time

Note 1 to entry: Survival probability is expressed as a factor.

Note 2 to entry: The component can be e.g. a light source, a luminaire.

Note 3 to entry: There is a distinct difference between the survival factor (see [6.3](#)) and the survival probability. The survival probability describes the performance of an individual component whereas the survival factor describes the outcome of the determination process as described in [6.3](#).



**3.12  
useful life**

$L_{x,By}$ <sup>1)</sup>

<of LED luminaires> length of time until a percentage  $y$  of a population of operating LED luminaires reaches gradual light output degradation of a percentage  $x$ , expressed in general in the ' $L_{x,By}$ ' format

Note 1 to entry: Useful life can be specified on different product levels such as on individual LED, LED module or LED luminaire level. As for example luminaire design impacts thermal design, the useful life of the LED module might be different from the useful life of the luminaire.

[SOURCE: IEC 62717:2014+AMD1:2015, modified — specifier <of LED luminaires> and quantity symbol added to the term]

**4 Symbols and units**

The symbols and units in [Table 1](#) apply.

**Table 1 — Symbols and units**

Symbol	Term	Unit
$E_A$	measured illuminance	lx
$E_{A,c}$	corrected measured illuminance	lx
$E_m$	maintained illuminance	lx
$E_{in}$	initial illuminance	lx
$f_{LF}$	luminous flux factor (see <a href="#">6.2</a> )	1
$f_{LLM}$	lamp luminous flux maintenance factor	1
$f_{LM}$	luminaire maintenance factor (see <a href="#">6.4</a> )	1
$f_m$	maintenance factor (see <a href="#">6.1</a> ) NOTE In this document the term "maintenance factor" is used for luminaires either with integrated or separate light sources, in contrast to CIE 97 and CIE 154 where the light source is generally seen as separate from the luminaire.	1
$f_S$	survival factor (see <a href="#">6.3</a> )	1
$f_{SM}$	surface maintenance factor (see <a href="#">6.5</a> )	1
$\Phi_L$	luminaire luminous flux	lm
$\Phi_{CLO}$	CLO-corrected luminaire luminous flux	lm
$\Phi_S$	standard luminaire luminous flux	lm
$\Phi_e$	end-of-life luminaire luminous flux	lm
$\Phi_i$	initial luminaire luminous flux	lm
$L_x$	median useful life (see <a href="#">3.8</a> ) for $x$ % remaining luminous flux	h
$L_{x,By}$	useful life	h
$p_f$	failure probability	1
$p_s$	survival probability	1

1) Note that in the source IEC 62717 the expression " $L_{x,By}$ " is incorrectly presented as a quantity symbol for the term "useful life". As such, this document introduces the symbol  $L_{x,By}$  for the term "useful life" for use in this document and further usage.

## SIS-ISO/CIE TS 22012:2019 (E)

### 5 Influencing factors

#### 5.1 Luminaire and/or light source characteristics

Depreciation of the luminaire and/or light source due to regular ageing and/or product-related characteristics shall be taken into account. This includes the following components:

- luminous flux depreciation (either of the light source or the luminaire, depending on the luminaire design) (see [6.2](#));
- light source and/or luminaire catastrophic failure (depending on luminaire design) (see [6.3](#)).

#### 5.2 Recoverable external factors

Recoverable factors concern those external factors, causing depreciation of the lighting installation performance, of which the effects can be economically reversed or mitigated during service and/or routine maintenance. The following factors shall be taken into account:

- removable pollution in/on the luminaire (see [6.4](#));
- depreciation of room or area surface characteristics relevant to the lighting installation (i.e. reduction of reflectance due to degradation of walls or ceiling finishes) (see [6.5](#)).

#### 5.3 Non-recoverable external factors

Influencing external factors are classified as non-recoverable when they are caused by external (environmental) factors and cannot be reversed during normal maintenance or are uneconomical to restore. These factors include the ageing/fading of (non-replaceable) components due to the environmental conditions and/or the irreversible soiling of components in applications due to specific (aggressive) substances.

Although these factors should be taken into account during the design and maintenance planning phase, they are not included in the maintenance factor as described in this document.

#### 5.4 Maintenance period, cleaning, replacement and surface refurbishment interval

The choice of maintenance period, cleaning and replacement interval has a large impact on the maintenance factor. Prior to determination of the maintenance factor, the following information shall be determined:

- maintenance period (often expressed in years);
- cleaning interval of luminaires (often expressed in years);
- component replacement interval (often expressed in burning hours) and
- surface refurbishment interval (often expressed in years).

## 6 Maintenance factor determination

### 6.1 Basic description of the method

The maintenance factor  $f_m$  is determined using the [Formula \(1\)](#).

$$f_m = f_{LF} \cdot f_S \cdot f_{LM} \cdot f_{SM} \quad (1)$$

where

$f_{LF}$  is the luminous flux factor (see [6.2](#));

$f_S$  is the survival factor (see [6.3](#));

$f_{LM}$  is the luminaire maintenance factor (see [6.4](#));

$f_{SM}$  is the surface maintenance factor (see [6.5](#)).

[Annex A](#) provides examples demonstrating the determination of these factors.

**NOTE** The methodology described in this document is a replacement of the methodology as described in CIE 097:2005 and CIE 154:2003. Terminology has been changed to suit a more generalized approach for luminaires either with integrated or separate light sources. Terminology changes are further specified in the relevant paragraphs.

### 6.2 Luminous flux factor

#### 6.2.1 Luminous flux factor determination — General

The luminous flux factor,  $f_{LF}$ , expresses the depreciation of the luminous flux over time due to ageing of the light source or luminaire during regular operation (this excludes external factors). This is defined as the ratio of depreciated luminous flux to the initial luminous flux.

For luminaires with an integrated light source the luminous flux factor,  $f_{LF}$ , shall be determined for the (full) luminaire. For luminaires with a non-integrated light source the luminous flux factor,  $f_{LF}$ , shall be determined for the light source (i.e. lamp).

**NOTE 1** In CIE 097:2005 and CIE 154:2003 the equivalent of the luminous flux factor,  $f_{LF}$ , is the lamp luminous flux maintenance factor ( $f_{LLM}$ , abbreviation: LLMF). See Note in [6.1](#) for further information.

**NOTE 2** The luminous flux factor,  $f_{LF}$ , determined at luminaire level will better reflect reality as this includes all components and operating conditions. Therefore, this is the default method for all types of luminaires. However, for luminaires with non-integrated light sources it is often not possible to determine this for the full luminaire as data is only available for the light source and as such the luminous flux factor,  $f_{LF}$ , on light source level is accepted for luminaires with non-integrated light sources.

For LED-based luminaires the luminous flux factor,  $f_{LF}$ , shall be determined based upon the light source or luminaire replacement interval and shall be provided by the luminaire supplier according to the definitions in IEC 62722-2-1.

The replacement interval can correspond to the median useful life,  $L_x$ . In this case the luminous flux factor,  $f_{LF}$ , equals  $x/100$ .

**EXAMPLE 1**  $L_{80} = 50\,000$  h translates to 80 % remaining luminous flux at 50 000 h. If the luminaire or light source is also planned to be replaced at 50 000 h this would result in a luminous flux factor  $f_{LF} = 0,80$ .