

# SVENSK STANDARD

## SS-EN ISO 14644-16:2019



Fastställt/Approved: 2019-07-01  
Utgåva/Edition: 1  
Språk/Language: engelska/English  
ICS: 13.040.35

---

**Renhetsteknik – Renrum och tillhörande renhetskontrollerade miljöer –  
Del 16: Allmänna riktlinjer för att förbättra energieffektiviteten i renrum och i enheter för ren luft (ISO 14644-16:2019)**

**Cleanrooms and associated controlled environments –  
Part 16: Energy efficiency in cleanrooms and clean air devices  
(ISO 14644-16:2019)**

This preview is downloaded from [www.sis.se](http://www.sis.se). Buy the entire standard via <https://www.sis.se/std-80012663>

# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Europastandarden EN ISO 14644-16:2019 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN ISO 14644-16:2019.

The European Standard EN ISO 14644-16:2019 has the status of a Swedish Standard. This document contains the official version of EN ISO 14644-16:2019.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna upplysningar om svensk och utländsk standard.*

*Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS, who can also provide general information about Swedish and foreign standards.*

Denna standard är framtagen av kommittén för Renhetsteknik, SIS/TK 108.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](https://www.sis.se) - där hittar du mer information.



EUROPEAN STANDARD

**EN ISO 14644-16**

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2019

ICS 13.040.35

English Version

**Cleanrooms and associated controlled environments - Part  
16: Energy efficiency in cleanrooms and separative devices  
(ISO 14644-16:2019)**

Salles propres et environnements maîtrisés apparentés  
- Partie 16: Efficacité énergétique dans les salles  
propres et les dispositifs séparatifs (ISO 14644-  
16:2019)

Reinräume und zugehörige Reinraumbereiche - Teil  
16: Energieeffizienz von Reinräumen und  
Reinluftgeräten (ISO 14644-16:2019)

This European Standard was approved by CEN on 30 May 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**



# Contents

Page

- Foreword ..... v
- Introduction ..... vi
- 1 Scope ..... 1**
- 2 Normative references ..... 1**
- 3 Terms and definitions ..... 1**
  - 3.1 General terms ..... 1
  - 3.2 Terms related to installation ..... 3
  - 3.3 Terms related to energy efficiency ..... 4
  - 3.5 Abbreviated terms ..... 4
- 4 Energy reduction evaluation and implementation process ..... 5**
  - 4.1 General ..... 5
  - 4.2 New or existing cleanrooms ..... 6
  - 4.3 Energy performance comparison ..... 7
    - 4.3.1 General ..... 7
    - 4.3.2 Compare energy performance ..... 7
    - 4.3.3 Determine the business case ..... 7
    - 4.3.4 Monitor and review ..... 7
  - 4.4 Existing cleanroom retrofit or renovation ..... 7
  - 4.5 Process for existing cleanrooms ..... 8
    - 4.5.1 Select project team ..... 8
    - 4.5.2 Review user requirements and project scope ..... 8
    - 4.5.3 Collate information on cleanroom performance criteria ..... 9
  - 4.6 Process for design/construction of new build or updating cleanrooms ..... 9
    - 4.6.1 Review user requirements and project scope ..... 9
    - 4.6.2 Undertake energy performance design review ..... 9
  - 4.7 Comparative review of cleanroom environmental performance ..... 9
  - 4.8 Identify energy reduction opportunities ..... 10
  - 4.9 Assess the impact of energy reduction opportunities ..... 10
  - 4.10 Select energy reduction opportunities for implementation ..... 10
  - 4.11 Implementation ..... 10
  - 4.12 Monitor, review and feedback ..... 11
  - 4.13 Decommissioning ..... 11
- 5 Impact of user requirement specification (URS) on energy consumption ..... 11**
  - 5.1 Principle ..... 11
  - 5.2 Garment levels ..... 11
- 6 Airflow volume and compensating factors ..... 12**
  - 6.1 Fresh air supply ..... 12
  - 6.2 Airflow volume rate ..... 12
  - 6.3 Source strength and airflow rate calculation for non-unidirectional rooms ..... 12
    - 6.3.1 Determining air volume flow rate ..... 12
    - 6.3.2 Ventilation effectiveness index ..... 13
    - 6.3.3 Compensation factors ( $C_f$ ) ..... 13
  - 6.4 Flexible procedure for airflow rate estimation in non-UDAF rooms ..... 14
    - 6.4.1 General ..... 14
    - 6.4.2 Design stage ..... 14
    - 6.4.3 Testing stage ..... 15
    - 6.4.4 Operational stage ..... 15
  - 6.5 Air velocity reduction for unidirectional air flow systems ..... 15
- 7 Power management: turn-down, turn-off and recovery ..... 15**
  - 7.1 Turn-down ..... 15
  - 7.2 Turn-off ..... 16

**SS-EN ISO 14644-16:2019 (E)**

<b>8</b>	<b>Adaptive control</b> .....	<b>16</b>
<b>9</b>	<b>Heating and cooling loads</b> .....	<b>17</b>
<b>10</b>	<b>Fan and filter selection</b> .....	<b>17</b>
	10.1 Air movement fans.....	17
	10.2 Selection of air filters.....	17
<b>11</b>	<b>Lighting levels</b> .....	<b>18</b>
<b>12</b>	<b>Training</b> .....	<b>18</b>
<b>13</b>	<b>Operation</b> .....	<b>18</b>
<b>14</b>	<b>Maintenance</b> .....	<b>19</b>
<b>15</b>	<b>Decommissioning</b> .....	<b>20</b>
	<b>Annex A (informative) Source strength: Air volume and worked example</b> .....	<b>21</b>
	<b>Annex B (informative) Energy saving opportunities</b> .....	<b>26</b>
	<b>Annex C (informative) Impact assessment</b> .....	<b>32</b>
	<b>Annex D (informative) Benchmarking: Energy performance indicators for cleanrooms</b> .....	<b>33</b>
	<b>Annex E (informative) Useful measures to minimize excess heating and cooling losses or gains</b> .....	<b>38</b>
	<b>Annex F (informative) Critical area reduction example</b> .....	<b>40</b>
	<b>Bibliography</b> .....	<b>42</b>



## **European foreword**

This document (EN ISO 14644-16:2019) has been prepared by Technical Committee ISO/TC 209 "Cleanrooms and associated controlled environments" in collaboration with Technical Committee CEN/TC 243 "Cleanroom technology" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2019, and conflicting national standards shall be withdrawn at the latest by December 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## **Endorsement notice**

The text of ISO 14644-16:2019 has been approved by CEN as EN ISO 14644-16:2019 without any modification.

## SS-EN ISO 14644-16:2019 (E)

### Introduction

Cleanrooms and associated controlled environments are widely used in many industries, such as life-sciences (including pharmaceutical, medical device), micro-electronics, aerospace, food processing, nuclear and hospitals. Operational size ranges from tens to thousands of square metres, most with unique design and operational characteristics based on their function. Their development has involved rapid expansion and progress for several decades, mirrored by an increasing energy demand. This document embraces the accumulated experiences and practices in cleanroom design, operation and maintenance, formulated to reduce their energy consumption and the global impact of this dramatic growth.

Users are also referred to ISO 50001 for energy management.

Although varying greatly in function and size, the energy consumption of cleanrooms can be over 10 times higher than that for offices of similar size. A considerable amount of energy is required to provide large amounts of filtered and conditioned air to achieve specific levels of air cleanliness. Air movement fans can account for 35 % to 50 % of the HVAC consumption of cleanrooms due to the power required to overcome the high pressure differentials needed to operate high-efficiency filters and other circulation components in the cleanroom system. Production of this type of high-quality air can consume up to 80 % of the total energy used in a typical manufacturing facility.

Additional energy is also used to achieve temperature and relative humidity control for processes in the cleanroom, for personnel comfort and to achieve the requisite pressurization of the cleanroom space. There is therefore significant potential for energy saving by diligent design in the installation of new cleanrooms, and by retrofit improvements and upgrades to existing facilities. This document sets out the measures that can be taken to introduce these techniques and applies to the full spectrum of “cleanroom technology”, from cleanrooms to clean air devices, including isolators, glove boxes and mini-environments as described in ISO 14644-7[1]. This document is based on actual experience, practice and tests supported by theoretical calculations for the purpose of clear and scientific description of the effects of energy saving.

The energy saving methods and techniques used in this document are all general ones applicable to varied environments and situations. They are not process-specific and exclude related production processes such as water treatment, and oven, autoclave and stress cycling operations. Their specific application depends on the actual conditions of cleanroom operation as agreed between the customer, the supplier and the installation engineers.

At each stage in the cleanroom life cycle, opportunities exist to optimize system performance and reduce energy consumption. Energy saving measures implemented at the design stage achieve the most effective results for new cleanrooms, but similar energy savings can also be achieved for those currently in operation. Cleanrooms can be used singly or as a group, based on practical conditions on site.

During design, when information about the finished building and process is at its minimum, conservatism can dictate the oversizing of systems and the mandating of overly tight specifications. At this stage, challenging these specifications and design considerations is valuable for energy efficiency.

When setting the system to work and executing performance testing, there is an opportunity to adjust the system to accommodate the actual conditions as built to optimize the system performance and minimize energy usage.

During the operating life of the facility, analysis of monitoring data can and should be used to further optimize system performance and minimize energy usage.

# Cleanrooms and associated controlled environments —

## Part 16:

# Energy efficiency in cleanrooms and separative devices

## 1 Scope

This document gives guidance and recommendations for optimizing energy usage and maintaining energy efficiency in new and existing cleanrooms, clean zones and separative devices. It provides guidance for the design, construction, commissioning and operation of cleanrooms.

This document covers all cleanroom-specific features and can be used in different areas to optimize energy use in electronic, aerospace, nuclear, pharmaceutical, hospital, medical device, food industries and other clean air applications.

It also introduces the concept of benchmarking for the performance assessment and comparison of cleanroom energy efficiencies, while maintaining performance levels to ISO 14644 requirements<sup>[2][3]</sup>.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 50001, *Energy management systems — Requirements with guidance for use*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 50001 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

### 3.1 General terms

#### 3.1.1

#### **air-handling unit**

#### **AHU**

unit or plant, comprising fan, filtration, heating, cooling and mixing of fresh air and recirculated air, that delivers conditioned air to a room or facility

#### 3.1.2

#### **classification**

method of assessing level of cleanliness against a specification for a *cleanroom* (3.1.4), *clean zone* (3.1.5), controlled zone or a defined location therein

Note 1 to entry: Levels should be expressed in terms of an ISO Class, which represents maximum allowable concentrations of particles in a unit volume of air.

[SOURCE: ISO 14644-1:2015, 3.1.4, modified — In the definition, the part after “clean zone” has been added.]