


SVENSK STANDARD

SS-ISO 23467:2020

Isolering (stopp av vattenflöde) av system på kärnkraftverk genom frysning av isplugg (ISO 23467:2020, IDT)

Ice plug isolation of piping in nuclear power plant (ISO 23467:2020, IDT)



**sis** Svenska  
Institutet för  
Standarder

Language: engelska/English

Edition: 1

This preview is downloaded from [www.sis.se](http://www.sis.se). Buy the entire standard via <https://www.sis.se/std-80026592>

Den här standarden kan hjälpa dig att effektivisera och kvalitetssäkra ditt arbete. SIS har fler tjänster att erbjuda dig för att underlätta tillämpningen av standarder i din verksamhet.

#### **SIS Abonnemang**

Snabb och enkel åtkomst till gällande standard med SIS Abonnemang, en prenumerationstjänst genom vilken din organisation får tillgång till all världens standarder, senaste uppdateringarna och där hela din organisation kan ta del av innehållet i prenumerationen.

#### **Utbildning, event och publikationer**

Vi erbjuder även utbildningar, rådgivning och event kring våra mest sålda standarder och frågor kopplade till utveckling av standarder. Vi ger också ut handböcker som underlättar ditt arbete med att använda en specifik standard.

#### **Vill du delta i ett standardiseringsprojekt?**

Genom att delta som expert i någon av SIS 300 tekniska kommittéer inom CEN (europeisk standardisering) och/eller ISO (internationell standardisering) har du möjlighet att påverka standardiseringsarbetet i frågor som är viktiga för din organisation. Välkommen att kontakta SIS för att få veta mer!

#### **Kontakt**

Skriv till [kundservice@sis.se](mailto:kundservice@sis.se), besök [sis.se](https://www.sis.se) eller ring 08 - 555 523 10

---

© Copyright/Upphovsrätten till denna produkt tillhör Svenska institutet för standarder, Stockholm, Sverige. Upphovsrätten och användningen av denna produkt regleras i slutanvändarlicensen som återfinns på [sis.se/slutanvandarlicens](https://www.sis.se/slutanvandarlicens) och som du automatiskt blir bunden av när du använder produkten. För ordlista och förkortningar se [sis.se/ordlista](https://www.sis.se/ordlista).

© Copyright Svenska institutet för standarder, Stockholm, Sweden. All rights reserved. The copyright and use of this product is governed by the end-user licence agreement which you automatically will be bound to when using the product. You will find the licence at [sis.se/enduserlicenseagreement](https://www.sis.se/enduserlicenseagreement).

Upplysningar om sakinnehållet i standarden lämnas av Svenska institutet för standarder, telefon 08 - 555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna upplysningar om svensk och utländsk standard.

Standarden är framtagen av kommittén för Kärnenergi, SIS/TK 405.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](https://www.sis.se) - där hittar du mer information.

Den internationella standarden ISO 23467:2020 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av ISO 23467:2020.

The International Standard ISO 23467:2020 has the status of a Swedish Standard. This document contains the official English version of ISO 23467:2020.

## LÄSANVISNINGAR FÖR STANDARDER

I dessa anvisningar behandlas huvudprinciperna för hur regler och yttre begränsningar anges i standardiseringsprodukter.

### Krav

Ett krav är ett uttryck i ett dokumentets innehåll som anger objektivet verifierbara kriterier som ska uppfyllas och från vilka ingen avvikelse tillåts om efterlevnad av dokumentet ska kunna åberopas. Krav uttrycks med hjälpverbet ska (eller ska inte för förbud).

### Rekommendation

En rekommendation är ett uttryck i ett dokumentets innehåll som anger en valmöjlighet eller ett tillvägagångssätt som bedöms vara särskilt lämpligt utan att nödvändigtvis nämna eller utesluta andra. Rekommendationer uttrycks med hjälpverbet bör (eller bör inte för avrådanden).

### Instruktion

Instruktioner anges i imperativ form och används för att ange hur något görs eller utförs. De kan underordnas en annan regel, såsom ett krav eller en rekommendation. De kan även användas självständigt, och är då att betrakta som krav.

### Förklaring

En förklaring är ett uttryck i ett dokumentets innehåll som förmedlar information. En förklaring kan uttrycka tillåtelse, möjlighet eller förmåga. Tillåtelse uttrycks med hjälpverbet får (eller motsatsen behöver inte). Möjlighet och förmåga uttrycks med hjälpverbet kan (eller motsatsen kan inte).

## READING INSTRUCTIONS FOR STANDARDS

These instructions cover the main principles for the use of provisions and external constraints in standardization deliverables.

### Requirement

A requirement is an expression, in the content of a document, that conveys objectively verifiable criteria to be fulfilled, and from which no deviation is permitted if conformance with the document is to be claimed. Requirements are expressed by the auxiliary shall (or shall not for prohibition).

### Recommendation

A recommendation is an expression, in the content of a document, that conveys a suggested possible choice or course of action deemed to be particularly suitable, without necessarily mentioning or excluding others. Recommendations are expressed by the auxiliary should (or should not for dissuasion).

### Instruction

An instruction is expressed in the imperative mood and is used in order to convey an action to be performed. It can be subordinated to another provision, such as a requirement or a recommendation. It can also be used independently and is then to be regarded as a requirement.

### Statement

A statement is an expression, in the content of a document, that conveys information. A statement can express permission, possibility or capability. Permission is expressed by the auxiliary may (its opposite being need not). Possibility and capability are expressed by the auxiliary can (its opposite being cannot).

# Contents

Page

<b>Foreword</b> .....	<b>vi</b>
<b>Introduction</b> .....	<b>vii</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 General requirements</b> .....	<b>2</b>
4.1 Personnel .....	2
4.2 Equipment .....	2
4.3 Preconditions .....	2
4.4 Requirements of process .....	3
4.4.1 Material of pipe .....	3
4.4.2 Freezing medium.....	3
4.4.3 Position of ice plug .....	3
4.4.1 Ice plug jacket.....	4
<b>5 Preparation before operation</b> .....	<b>4</b>
5.1 Working environment.....	4
5.2 Construction plan .....	4
5.3 Tools of construction.....	5
5.4 Protective measures .....	5
5.5 Pipe testing before operation .....	5
<b>6 Ice plug construction</b> .....	<b>5</b>
6.1 Generation of ice plug.....	5
6.2 Judgment of ice plug generation .....	5
6.3 Removal of ice plug .....	6
<b>7 Quality assurance (QA) on ice plugging</b> .....	<b>6</b>
7.1 QA before ice plug performance .....	6
7.2 QA during ice plug performance .....	6
7.3 QA after ice plug performance .....	7
<b>8 Records and reports</b> .....	<b>7</b>
<b>Annex A (informative) Reference table of ice plug jacket length</b> .....	<b>8</b>
<b>Annex B (informative) Ice plug jacket types</b> .....	<b>9</b>
<b>Annex C (informative) Flow chart to performance of ice plug isolation measure (construction plan)</b> .....	<b>14</b>
<b>Bibliography</b> .....	<b>15</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 6, *Reactor technology*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## Introduction

This document provides terms and definitions for basic concepts of nuclear energy, nuclear technologies, and radiological protection. Terminological data are taken from ISO standards developed by ISO/TC 85 sub-committees and other technically validated documents.

In the field of nuclear power, when the equipment or pipeline is to be disassembled or removed to overhaul, it is often necessary to isolate the equipment or pipeline. Under normal circumstances, the upstream and downstream of the equipment will be isolated or the internal media will be sprinkled. Taking into account the safety (some reactor systems like the hot trap needs to be filled at any time and care need to be taken as some liquid systems are radioactive) and economy (system mass, sparse for a long time, heavy water degradation, etc.) during the maintenance it is necessary that there will be no isolation equipment or isolation equipment near the equipment or pipeline.

Based on years of practical experience, the development of this document is feasible. At the theoretical level, the relevant literature has been studied and reported on the ice plug isolation technology. In the actual maintenance work, the use of ice plug technology to the pipeline equipment isolation achieve good results. Based on these theoretical and practical experiences, it is recommended that some technical indicators in the process of ice plug operation be standardized.

This document is designed to provide a standardized procedure for on-line isolation through the freezing of the internal medium of the pipeline. This document includes methods for technologies to isolate equipment without isolation facilities by ice plug technology. Standardized ice plug isolation technology will facilitate the maintenance work.





# Ice plug isolation of piping in nuclear power plant

## 1 Scope

This document specifies requirements for the ice plug technique with liquid nitrogen or dry ice as refrigerant (cryogenic medium) on metal pipes of nuclear power plants. The freezing liquid can be water or water mixture (e.g. boric acid mixture).

This document specifies technical requirements of ice plug generation, formation judgment and removal, measures before, during and after ice plugging and requirements for personnel and non-destructive testing.

The application of the ice plug isolation technique is principally not allowed on clad pipes or pipes with internal coatings. The application for pressure test is not in the scope of this document and will be qualified separately.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3452 (all parts), *Non-destructive testing — Penetrant testing*

ISO 9934 (all parts), *Non-destructive testing — Magnetic particle testing*

ISO 16810, *Non-destructive testing — Ultrasonic testing — General principles*

ISO 17637, *Non-destructive testing of welds — Visual testing of fusion-welded joints*

ISO 20769 (all parts), *Non-destructive testing — Radiographic inspection of corrosion and deposits in pipes by X- and gamma rays*

## 3 Terms and definitions

For the purposes of this document the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <https://www.iso.org/obp>

— IEC Electropedia: available at <http://www.electropedia.org/>

### 3.1

#### **ice plug**

solid block of ice in the pipe that can withstand a certain system pressure to isolate the pipeline temporarily

Note 1 to entry: The ice plug can be used for the convenience of maintaining downstream pipelines, valves and other equipment.

### 3.2

#### **ice plug jacket**

set of device wrapped outside the pipe and containing a refrigerant capable of freezing internal medium of the pipe to form an *ice plug* (3.1) for a period necessary for the isolation

Note 1 to entry: The length of jacket depends on the diameter of pipe. See [Annex A](#) for the length of jacket.

## SS-ISO 23467:2020 (E)

- 3.3 ice plug area**  
defined area on the pipe excluding the ice plug affected zone
- 3.4 refrigerant**  
cryogenic medium  
medium which is used to generate an *ice plug* (3.1) inside of the pipes
- 3.5 freezing medium**  
**freezing liquid**  
medium inside of pipes and components which have to be frozen
- 3.6 UT**  
**ultrasonic testing**  
non-destructive testing of solid material using ultrasonic waves, for defects such as cavities, nonbonding, and strength variations
- 3.7 RT**  
**radiographic testing**  
non-destructive testing method of inspecting materials for hidden flaws by using the ability of short wavelength electromagnetic radiation (high energy photons) to penetrate various materials

## 4 General requirements

### 4.1 Personnel

Managers and operators engaged in ice plug isolation construction shall undergo professional training and safety training. For the implementation, only qualified and trained personnel should be deployed (e.g. workers from specialized companies).

### 4.2 Equipment

**4.2.1** Special ice plug jacket, other equipment (such as liquid nitrogen chamber, hoses, joints, antifreeze gloves, protective masks, protective glasses) and tools shall be used. Measurement tools (such as thermometers, pressure gauges, oxygen meters, etc.) shall be calibrated and validated.

**4.2.2** Anti-freezing, anti-asphyxia and other related safety protection products shall be provided.

### 4.3 Preconditions

**4.3.1** Pipes shall be filled with any fluids that can be frozen, and free of air.

**4.3.2** The flow rate of liquid in the pipe should be as low as possible, preferably close to zero. Excessive flow rate is not conducive to the formation of ice plug.

**4.3.3** When the ambient temperature is lower than 43 °C, the surface temperature of pipe shall be lower than 50 °C. If the refrigerant is liquid nitrogen and shall be lower than 30 °C if the refrigerant is dry ice. This is not required if validity is confirmed by mock-up test.

**4.3.4** The distance between ice plug and heat source nearby (including welding parts) shall be determined based on heat input and pipe diameter.

**4.3.5** The pipe to be isolated with an ice plug shall not be affected by the vibration and shock during the operation.

**4.3.6** Ice plug operation is prohibited for the pipe sections containing the following defects:

- a) Crack affecting the strength;
- b) Pitting affecting the strength;
- c) Thickness of pipe thinned to an unacceptable level;
- d) Breach;
- e) Other conditions that could cause a burst of the pipe.

**4.3.7** Ice plug operation is prohibited in the following pipe structures or fittings:

- a) Pipe parts, such as plugs, thermocouples;
- b) Pipe fittings, such as movable joints.

## **4.4 Requirements of process**

### **4.4.1 Material of pipe**

The pipe shall be made of metal (carbon steel or stainless steel). Welds are not allowed in the area of the ice plug (no circumferential neither longitudinal weld). Unless it can be demonstrated that there is no better solution, and that there are no defects in the welds, ice plug operations on welds can be done. Cast copper pipe, cast iron pipe, clad pipe and lining pipe shall not be subject to ice plugging isolation.

Material inspection certificate or alternative consideration should be confirmed in order to avoid low temperature brittle fracture, when applying ice plugs on carbon steel piping, which is connected to most important components or piping for safety.

Vibration and external shock like falling parts (e.g. tools) or mechanical stress (e.g. moving of valves, starting of pumps) shall be avoided during ice plug generation. In addition, stainless steel pipe shall be protected from contact with halogen-containing medium to prevent stress corrosion.

### **4.4.2 Freezing medium**

The freezing medium shall be selected in accordance with the following principles, depending on pipe diameter and medium temperature. This is not required if validity is confirmed by mock-up test. It is also allowed to refer to local regulations if local regulations have higher diameter limit.

Liquid nitrogen: the working temperature of liquid nitrogen is  $-196\text{ }^{\circ}\text{C}$ , suitable for ferritic pipe equal or less than DN 400 (16") or for austenitic steel equal or less than DN 300 (12").

Dry ice: the working temperature of dry ice is  $-78\text{ }^{\circ}\text{C}$ , suitable for pipe equal or less than DN 100 (4").

Freon and its substitutes: it is suitable for the ice plug of pipe with outer diameter of less than 60,3 mm.

### **4.4.3 Position of ice plug**

**4.4.3.1** The distance between the ice plug from extensions (valve, pump, flange, movable joint, weld, tee, elbow, etc.) should be greater than 20 times the outer diameter ( $>20 \times Da$ ) or 600 mm, whichever is greater, to avoid stress effects caused by temperature gradients. If both extensions are fixed points, one of them shall be loosened. This is not required if validity is confirmed by mock-up test.