

# SVENSK STANDARD

## SS-EN 54-22:2015



Fastställt/Approved: 2015-05-26  
Publicerad/Published: 2015-05-28  
Utgåva/Edition: 1  
Språk/Language: engelska/English  
ICS: 13.220.10; 13.220.20

---

### **Brand och räddning – Branddetekterings- och brandlarmsystem – Del 22: Återställningsbara linjära värmedetektorer**

### **Fire detection and fire alarm systems – Part 22: Resettable line-type heat detectors**



# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Europastandarden EN 54-22:2015 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 54-22:2015.

The European Standard EN 54-22:2015 has the status of a Swedish Standard. This document contains the official English version of EN 54-22:2015.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Uppllysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna uppllysningar om svensk och utländsk standard.*

*Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.*

Denna standard är framtagen av kommittén för Branddetektorer, brandlarmsystem, SIS/TK 360/AG 2.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.



EUROPEAN STANDARD

**EN 54-22**

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2015

---

ICS 13.220.20; 13.220.10

English Version

## Fire detection and fire alarm systems - Part 22: Resettable line-type heat detectors

Systèmes de détection et d'alarme incendie - Partie 22:  
DéTECTEURS DE CHALEUR DE TYPE LINÉAIRE RÉENCLANCHABLES

Brandmeldeanlagen - Teil 22: Rücksetzbare linienförmige  
Wärmemelder

This European Standard was approved by CEN on 19 March 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

**Contents**

Page

Foreword.....4

Introduction .....6

1 Scope .....7

2 Normative references .....7

3 Terms, definitions and abbreviations .....8

3.1 Terms and definitions .....8

3.2 Abbreviations .....9

4 Product characteristics .....9

4.1 General.....9

4.2 Nominal activation conditions/sensitivity ..... 10

4.3 Operational reliability ..... 11

4.4 Tolerance to supply voltage ..... 13

4.5 Performance parameters under fire conditions ..... 13

4.6 Durability of nominal activation conditions/sensitivity ..... 14

5 Testing, assessments and sampling methods ..... 15

5.1 General..... 15

5.2 Test procedures nominal activation conditions/sensitivity ..... 19

5.3 Test procedures operational reliability..... 20

5.4 Tolerance to supply voltage ..... 22

5.5 Performance parameters under fire conditions ..... 23

5.6 Durability of nominal activation conditions/sensitivity ..... 27

6 Assessment and verification of constancy of performance (AVCP) ..... 47

6.1 General..... 47

6.2 Type testing ..... 48

6.3 Factory production control (FPC) ..... 49

7 Classification..... 54

8 Marking, labelling and packaging ..... 54

8.1 General..... 54

8.2 Marking of sensor control unit ..... 55

8.3 Marking of sensing element ..... 55

8.4 Marking of functional units ..... 55

Annex A (normative) Arrangement of the sensing element in the fire test room ..... 56

A.1 General..... 56

A.2 Fire test room arrangement ..... 56

A.3 Sensing element outside the fire test room ..... 56

Annex B (normative) Flaming liquid test fires (TF6F, TF6 and TF6S) ..... 58

B.1 General..... 58

B.2 Arrangement..... 58

B.3 Ignition ..... 58

B.4 End of test condition ..... 58

B.5 Test validity criteria ..... 59

<b>Annex C (normative) Test arrangement for the sensing element of linear heat detector in the heat tunnel</b> .....	<b>60</b>
<b>C.1 General</b> .....	<b>60</b>
<b>C.2 Test arrangement for the sensing element</b> .....	<b>60</b>
<b>Annex D (informative) Apparatus for mounting of the sensing element of linear heat detector in the heat tunnel</b> .....	<b>61</b>
<b>D.1 General</b> .....	<b>61</b>
<b>D.2 Test apparatus</b> .....	<b>61</b>
<b>Annex E (normative) Mounting of the sensing element of multipoint RLTHD in the heat tunnel</b> .....	<b>62</b>
<b>E.1 General</b> .....	<b>62</b>
<b>E.2 Mounting arrangement of multipoint sensing element</b> .....	<b>62</b>
<b>Annex F (normative) Heat tunnel for response time and response temperature measurements</b> .....	<b>64</b>
<b>F.1 General</b> .....	<b>64</b>
<b>F.2 Description of the heat tunnel</b> .....	<b>64</b>
<b>Annex G (informative) Construction of the heat tunnel</b> .....	<b>65</b>
<b>G.1 General</b> .....	<b>65</b>
<b>G.2 Heat tunnel construction</b> .....	<b>65</b>
<b>Annex H (normative) Test arrangement for vibration tests for sensing element</b> .....	<b>67</b>
<b>H.1 General</b> .....	<b>67</b>
<b>H.2 Test setup</b> .....	<b>67</b>
<b>Annex I (normative) Test apparatus for impact test on the sensing element</b> .....	<b>68</b>
<b>I.1 General</b> .....	<b>68</b>
<b>I.2 Test apparatus</b> .....	<b>68</b>
<b>I.3 Test setup</b> .....	<b>68</b>
<b>Annex J (informative) Data supplied with resettable line-type heat detectors</b> .....	<b>71</b>
<b>Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation</b> .....	<b>72</b>
<b>ZA.1 Scope and relevant characteristics</b> .....	<b>72</b>
<b>ZA.2 Procedure for assessment and verification of constancy of performance (AVCP) of resettable line-type heat detectors</b> .....	<b>74</b>
<b>ZA.2.1 System of AVCP</b> .....	<b>74</b>
<b>ZA.2.2 Declaration of performance (DoP)</b> .....	<b>75</b>
<b>ZA.2.2.1 General</b> .....	<b>75</b>
<b>ZA.2.2.2 Content</b> .....	<b>75</b>
<b>ZA.2.2.3 Example of DoP</b> .....	<b>76</b>
<b>ZA.3 CE marking and labelling</b> .....	<b>79</b>
<b>Bibliography</b> .....	<b>83</b>

## Foreword

This document (EN 54-22:2015) has been prepared by Technical Committee CEN/TC 72 “Fire detection and fire alarm systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2015, and conflicting national standards shall be withdrawn at the latest by May 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports the basic requirements of Regulation (EU) 305/2011.

For relationship with EU Directive(s), see informative Annex ZA which is an integral part of this document.

EN 54 "Fire detection and fire alarm systems" consists of the following parts:

Part 1: Introduction

Part 2: Control and indicating equipment

Part 3: Fire alarm devices – Sounders

Part 4: Power supply equipment

Part 5: Heat detectors – Point detectors

Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization

Part 10: Flame detectors – Point detectors

Part 11: Manual call points

Part 12: Smoke detectors – Line detector using an optical light beam

Part 13: Compatibility assessment of system components

Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance

Part 15: Point detectors using a combination of detected phenomena

Part 16: Voice alarm control and indicating equipment

Part 17: Short circuit isolators

Part 18: Input/output devices

Part 20: Aspirating smoke detectors

Part 21: Alarm transmission and fault warning routine equipment

Part 22: Resettable line-type heat detectors



Part 23: Fire alarm devices – Visual alarms

Part 24: Components of voice alarm systems – Loudspeakers

Part 25: Components using radio links and system requirements

Part 26: Carbon monoxide detectors – Point detectors (in preparation)

Part 27: Duct smoke detectors (in preparation)

Part 28: Non-resettable line-type heat detectors (in preparation)

Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors

Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors

Part 31: Multi-sensor detector – Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors

Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to [www.cen.eu](http://www.cen.eu).

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

Resettable line-type heat detectors (RLTHD) have been incorporated into fire alarm systems for a considerable number of years. These detectors are typically used in areas where point type heat detectors are presented with challenging environmental characteristics and also where access to the detectors may significantly influence the fire alarm system design.

This standard defines the minimum system functionality for RLTHD products. RLTHD are based upon many unique operating principles. It is the intention of this standard to define common operating characteristics for each type of RLTHD in conjunction with existing EN 54 detector standards, so that resettable line-type heat detectors have a response behaviour comparable to that of point type heat detectors.

Due to the various applications for RLTHD, it is necessary to devise separate environmental classification tests for the sensing element and the sensor control units of these systems. It is not the purpose of this standard to define applications or how RLTHD should be used in applications. However, the standard indicates two general fields of application, room protection and secondly local protection. The standard defines separate response test classifications for these two fields.

Generally there are two functional principles employed by RLTHD: non-integrating and integrating systems. Therefore separated subclasses have been created for non integrating systems and for integrating systems.

## 1 Scope

This European Standard applies to resettable line-type heat detectors consisting of a sensing element using an optical fibre, a pneumatic tube or an electrical sensor cable connected to a sensor control unit, either directly or through an interface module, intended for use in fire detection and fire alarm systems installed in and around buildings and other civil engineering works (see EN 54-1:2011).

This European Standard specifies the requirements and performance criteria, the corresponding test methods and provides for the Assessment and Verification of Constancy of Performance (AVCP) of resettable line-type heat detectors to this EN.

This European Standard also covers resettable line-type heat detectors intended for use in the local protection of plant and equipment.

Resettable line-type heat detectors with special characteristics and developed for specific risks are not covered by this EN.

This European Standard does not cover line-type heat detectors that are based on non-resettable, fixed temperature electrical cables (so called “digital” systems).

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems — Part 1: Introduction*

EN 54-7:2000, *Fire detection and fire alarm systems — Part 7: Smoke detectors — Point detectors using scattered light, transmitted light or ionization*

EN 50130-4:2011, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:1994, *Environmental testing — Part 1: General and guidance (IEC 60068-1:1988 + Corrigendum 1988 +A1:1992)*

EN 60068-2-1:2007, *Environmental testing — Part 2-1: Tests — Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-2:2007, *Environmental testing — Part 2-2: Tests — Test B: Dry heat (IEC 60068-2-2:2007)*

EN 60068-2-27:2009, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock (IEC 60068-2-27:2009)*

EN 60068-2-30:2005, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

EN 60068-2-42:2003, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-6:2008, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal) (IEC 60068-2-6:2008)*

EN 60068-2-75:1997, *Environmental testing — Part 2-75: Tests — Test Eh: Hammer tests (IEC 60068-2-75:1997)*