

SVENSK STANDARD

SS-EN 124-4:2015

Fastställt/Approved: 2015-06-14
Publicerad/Published: 2015-06-16
Utgåva/Edition: 1
Språk/Language: engelska/English
ICS: 13.060.30; 93.080.30

Avloppsteknik – Brunnsbeteckningar för trafikområden – Del 4: Brunnslock och lock till nedstigningsbrunnar gjorda av stålförstärkt betong

**Gully tops and manhole tops for vehicular and pedestrian
areas –
Part 4: Gully tops and manhole tops made of steel reinforced
concrete**



Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.



Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.



Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 124-4:2015 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 124-4:2015.

Denna standard ersätter SS-EN 124, utgåva 1.

The European Standard EN 124-4:2015 has the status of a Swedish Standard. This document contains the official English version of EN 124-4:2015.

This standard supersedes the Swedish Standard SS-EN 124, edition 1.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Uppllysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna uppllysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Denna standard är framtagen av kommittén för Avloppsteknik, SIS/TK 198/AG 165.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 124-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2015

ICS 93.080.30

Supersedes EN 124:1994

English Version

Gully tops and manhole tops for vehicular and pedestrian areas - Part 4: Gully tops and manhole tops made of steel reinforced concrete

Dispositifs de couronnement et de fermeture pour les zones
de circulation utilisées par les piétons et les véhicules -
Partie 4: Dispositifs de couronnement et de fermeture en
béton armé d'acier

Aufsätze und Abdeckungen für Verkehrsflächen - Teil 4:
Aufsätze und Abdeckungen aus stahlbewehrtem Beton

This European Standard was approved by CEN on 11 March 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Materials	6
4.1 General.....	6
4.2 Exposure classes.....	6
4.3 Resistance against freeze - thaw with de-icing salts	7
4.4 Compressive strength	7
4.5 Water content of concrete	7
4.6 Cement content of concrete	7
4.7 Chloride content of concrete.....	7
4.8 Water absorption of concrete.....	7
5 Requirements	7
5.1 Design and performance requirements.....	7
5.2 Material specific characteristics for gully tops and manhole tops made of steel reinforced concrete	9
5.2.1 Edge and contact surfaces protection for manhole tops and gully tops	9
5.2.2 Crack width.....	9
5.2.3 Reinforcement and concrete cover.....	9
5.2.4 Reaction to fire.....	10
5.2.5 Durability	10
5.2.6 Dangerous substances	11
6 Testing	11
6.1 General.....	11
6.2 Concrete strength	11
6.3 Edge and contact surface protection	11
6.4 Freeze–thaw with de-icing salts	11
6.5 Concrete cover for the reinforcement	11
7 Assessment and verification of constancy of performance – AVCP	11
7.1 General.....	11
7.2 Type testing.....	12
7.2.1 General.....	12
7.2.2 Test samples, testing and compliance criteria.....	12
7.2.3 Test reports	14
7.2.4 Shared other party results	14
7.3 Factory production control (FPC)	15
7.3.1 General.....	15
7.3.2 Requirements	15
7.3.3 Product specific requirements	19
7.3.4 Initial inspection of factory and of FPC	20
7.3.5 Continuous surveillance of FPC	21
7.3.6 Procedure for modifications.....	21
8 Designation	21
9 Marking	22

Annex ZA (informative) Clauses of this European Standard addressing the provisions of the EU Construction Products Regulation	24
ZA.1 Scope and relevant characteristics	24
ZA.2 Procedures for AVCP of gully tops and manhole tops made of steel reinforced concrete	26
ZA.3 CE marking and labelling.....	30
Bibliography.....	32

Foreword

This document (EN 124-4:2015) has been prepared by Technical Committee CEN/TC 165 “Wastewater engineering”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2015 and conflicting national standards shall be withdrawn at the latest by March 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

Together with EN 124-1:2015, EN 124-2:2015, EN 124-3:2015, EN 124-5:2015 and EN 124-6:2015, this document will supersede EN 124:1994.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Regulation (EU) No. 305/2011.

For relationship with EU Regulations, see informative Annex ZA, which is an integral part of this document.

EN 124, *Gully tops and manhole tops for vehicular and pedestrian areas*, consists of the following parts:

- *Part 1: Definitions, classification, general principles of design, performance requirements and test methods;*
- *Part 2: Gully tops and manhole tops made of cast iron;*
- *Part 3: Gully tops and manhole tops made of steel or aluminium alloys;*
- *Part 4: Gully tops and manhole tops made of steel reinforced concrete;*
- *Part 5: Gully tops and manhole tops made of composite materials;*
- *Part 6: Gully tops and manhole tops made of polypropylene (PP), polyethylene (PE) or unplasticized poly(vinyl chloride) (PVC-U).*

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard is applicable to precast gully tops and manhole tops made of steel reinforced concrete with a clear opening up to and including 1 000 mm for covering gullies, manholes and inspection chambers for installation within areas subjected to pedestrian and/or vehicular traffic.

It is applicable to manhole tops and gully tops for use in

- areas which can only be used by pedestrians and pedal cyclists (at least class A 15),
- pedestrian areas and comparable areas, car parks or car parking decks (at least class B 125),
- the area of kerbside channels of roads which, when measured from the kerb edge, extends a maximum of 0,5 m into the carriageway and a maximum of 0,2 m into the pedestrian area (at least class C 250),
- carriageways of roads (including pedestrian streets), hard shoulders and parking areas, for all types of road vehicles (at least class D 400),
- areas imposing high wheel loads, e.g. docks, aircraft pavements (at least class E 600),
- areas imposing particularly high wheel loads, e.g. aircraft pavements (Group 6, class F 900).

This European Standard is not applicable in isolation but only in combination with EN 124-1 and gives guidance for combinations of covers/gratings made of steel reinforced concrete with frames according to EN 124-2, EN 124-3, EN 124-5 and EN 124-6.

This European Standard is not applicable to:

- concave gratings for class D 400 installed in carriageways of roads or hard shoulders and concave gratings for classes F 900 and E 600;
- gratings/covers as part of prefabricated drainage channels according to EN 1433;
- floor and roof gullies in buildings which are specified in EN 1253 (all parts); and
- surface boxes.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 124-1:2015, *Gully tops and manhole tops for vehicular and pedestrian areas — Part 1: Definitions, classification, general principles of design, performance requirements and test methods*

EN 124-2:2015, *Gully tops and manhole tops for vehicular and pedestrian areas — Part 2: Gully tops and manhole tops made of cast iron*

EN 124-3:2015, *Gully tops and manhole tops for vehicular and pedestrian areas — Part 3: Gully tops and manhole tops made of steel or aluminium alloys*

EN 124-5:2015, *Gully tops and manhole tops for vehicular and pedestrian areas — Part 5: Gully tops and manhole tops made of composite materials*

SS-EN 124-4:2015 (E)

EN 124-6:2015, *Gully tops and manhole tops for vehicular and pedestrian areas — Part 6: Gully tops and manhole tops made of polypropylene (PP), polyethylene (PE) or unplasticized poly(vinyl chloride) (PVC-U)*

EN 206:2013, *Concrete — Specification, performance, production and conformity*

EN 1339:2003, *Concrete paving flags — Requirements and test methods*

EN 1992-1-1:2004, *Eurocode 2: Design of concrete structures — Part 1-1: General rules and rules for buildings*

EN 13369:2013, *Common rules for precast concrete products*

EN ISO 1461, *Hot dip galvanized coatings on fabricated iron and steel articles — Specifications and test methods (ISO 1461)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 124-1:2015 apply.

4 Materials

4.1 General

Precast manhole tops and gully tops according to this European Standard shall be made from steel reinforced concrete. The concrete quality of any element shall be dense, homogenous and conform to the requirements given in 4.2 to 4.6. For general aspects, constituent materials of concrete and reinforcing steel, EN 13369:2013, 4.1, shall apply.

Any element made of the materials specified in Clause 4 can be used in combination with elements of materials specified in EN 124-2, EN 124-3, EN 124-5 or EN 124-6. In such cases the manhole tops or gully tops shall comply with the relevant design and performance and testing requirements as listed in Table 1.

In addition, elements shall comply with the requirements for the material related EN 124-2, EN 124-3, EN 124-5 or EN 124-6, as applicable. Each element shall be marked accordingly. The load class to be declared for the combined product shall be restricted to the lower class determined for any constituent element according to the relevant part of EN 124 series.

EXAMPLE Where a cover is made of steel reinforced concrete, class D 400, and the frame is made of steel, class C 250, the manhole top or gully top is marked with EN 124-4 and the class to be declared for the combined product is the class of the frame according to EN 124-3 for steel.

4.2 Exposure classes

Manhole tops and gully tops according to this standard shall be at least suitable for use in “wet and dry” conditions and a slightly aggressive chemical environment, i.e. normal conditions for domestic sewage and treated industrial effluent, and for most natural soils and ground-waters. If more severe conditions are expected, additional requirements for corrosion protection can be necessary.

The exposure class determined in accordance with EN 206:2013 shall be a minimum of XC2.

Where resistance against freeze/thaw or chemical attack on concrete is required, the composition and properties of the concrete shall meet the requirements for XF, XD or XA classes taking into account the relevant description of the environment in accordance with EN 206:2013.

If more severe conditions are expected higher exposure classes can be necessary. In such cases the higher class shall be declared.

4.3 Resistance against freeze - thaw with de-icing salts

When manhole tops and gully tops are used in specific conditions of use (corresponding to frequent contact of a surface, partially or entirely made with concrete, with standing water containing de-icing salts in frost conditions) the concrete shall not show a mean mass loss higher than 1,5 kg/m² with no individual result higher than 2,0 kg/m² when tested according to 6.4. Products complying with this requirement shall be marked with “+R”.

4.4 Compressive strength

The compressive strength class of the concrete shall conform to the specific environmental conditions in accordance with 4.2 but not be less than C35/45 according to EN 13369, except for class A 15 covers, where the minimum compressive strength shall not be less than C25/30 according to EN 13369.

4.5 Water content of concrete

The ratio of water to cement plus any pozzolanic or latent hydraulic addition in the fully compacted state shall not be greater than 0,5 and shall conform to the specific environmental conditions in accordance with 4.2.

4.6 Cement content of concrete

Concrete shall have such a composition that the minimum content of cement plus any pozzolanic latent addition in the fully compacted state is consistent with the serviceability conditions of 4.2 and 4.7 for the exposure classes.

4.7 Chloride content of concrete

The maximum amount of chloride ion in the concrete shall be evaluated by calculation in accordance with EN 206:2013, 5.2.8.

4.8 Water absorption of concrete

When determined in accordance with EN 13369:2013, 5.1.2, the water absorption of concrete shall not exceed 6 % by mass.

5 Requirements

5.1 Design and performance requirements

Manhole tops and, gully tops made of concrete shall comply with the design and performance and testing requirements in accordance with EN 124-1, as listed in Table 1.

Table 1 — Design, performance and testing requirements specified in EN 124–1 for gully tops and manhole tops made of steel reinforced concrete

Characteristic	Requirements acc. to EN 124-1: 2015 Clause	Testing acc. to EN 124-1: 2015 Clause	Relevant for class					
			A 15	B 125	C 250	D 400	E 600	F 900
<i>Related to the design</i>								
Vents in covers	6.1	8.4.1	x	x	x	x	x	x
Clear opening of manhole tops for man entry	6.2	8.4.2	x	x	x	x	x	x