

SVENSK STANDARD

SS-EN 1366-2:2015



Fastställt/Approved: 2015-06-28
Publicerad/Published: 2015-06-29
Utgåva/Edition: 2
Språk/Language: engelska/English
ICS: 13.220.50

Provning av brandmotstånd för installationer i byggnader – Del 2: Brandspjäll

Fire resistance tests for service installations – Part 2: Fire dampers

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-8014759>

Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 1366-2:2015 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 1366-2:2015.

Denna standard ersätter SS-EN 1366-2, utgåva 1.

The European Standard EN 1366-2:2015 has the status of a Swedish Standard. This document contains the official English version of EN 1366-2:2015.

This standard supersedes the Swedish Standard SS-EN 1366-2, edition 1.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Denna standard är framtagen av kommittén för Brandsäkerhet, SIS/TK 181.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 1366-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2015

ICS 13.220.50

Supersedes EN 1366-2:1999

English Version

Fire resistance tests for service installations - Part 2: Fire dampers

Essais de résistance au feu des installations techniques -
Partie 2 : Clapets résistant au feu

Feuerwiderstandsprüfungen für Installationen - Teil 2:
Brandschutzklappen

This European Standard was approved by CEN on 3 April 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents		Page
Foreword.....		4
Introduction		6
1 Scope		7
2 Normative references		7
3 Terms and definitions		7
4 Test equipment		8
4.1 General.....		8
4.2 Connecting duct.....		8
4.3 Volume flow measuring station.....		9
4.4 Condensing unit.....		9
4.5 Gas temperature measuring devices.....		9
4.6 Exhaust fan system		9
5 Test conditions		9
6 Test specimen		10
6.1 Size.....		10
6.2 Number of tests.....		10
6.2.1 General.....		10
6.2.2 Supporting construction		10
6.2.3 Method of installation in the supporting construction		10
6.2.4 Method of installation on to the supporting construction.....		11
6.2.5 Method of installation away from the supporting construction.		11
6.2.6 Blade pivot axis.....		11
6.2.7 Application with no ducting on one or both sides, where additional evidence of insulation in such applications is required		11
6.3 Design		11
6.3.1 General.....		11
6.3.2 Orientation to be tested		12
6.3.3 Fire dampers installed within a wall or floor opening.....		12
6.3.4 Fire dampers mounted on to the face of a wall or floor.....		12
6.3.5 Fire dampers mounted remote from a wall or floor		12
6.3.6 Application with no ducting on one or both sides, where additional evidence of insulation in such applications is required		12
6.3.7 Temperature sensing element.....		13
7 Installation of test specimen		13
7.1 General.....		13
7.2 Supporting construction		13
7.3 Minimum separation		14
8 Conditioning.....		14
8.1 General.....		14
8.2 Water-based sealing materials		14
9 Application of instrumentation.....		14
9.1 Thermocouples		14
9.1.1 Furnace thermocouples (plate thermometers)		14
9.1.2 Unexposed surface temperature		14
9.2 Furnace pressure.....		15

9.2.1	General.....	15
9.2.2	Pressure differential measurement, furnace and connecting duct.....	15
10	Test procedure.....	15
10.1	Determination of leakage of connecting duct and measuring station.....	15
10.2	Opening and closing test.....	15
10.3	Determination of leakage at ambient temperature.....	16
10.4	Fire test procedure.....	16
11	Performance criteria.....	17
12	Test report.....	18
13	Field of direct application of test results.....	19
13.1	Size of fire damper.....	19
13.2	Fire dampers installed within structural openings.....	19
13.3	Fire dampers installed onto the face of a wall or a floor.....	19
13.4	Fire dampers remote from a wall or floor.....	19
13.5	Fire from above.....	20
13.6	Separation between fire dampers and between fire dampers and construction elements.....	20
13.7	Supporting constructions.....	20
13.8	Blade pivot axis.....	20
	Bibliography.....	34

Foreword

This document (EN 1366-2:2015) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2015, and conflicting national standards shall be withdrawn at the latest by December 2015.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1366-2:1999.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

EN 1366, *Fire resistance tests for service installations* consists of the following parts:

- *Part 1: Ventilation ducts;*
- *Part 2: Fire dampers (the present document);*
- *Part 3: Penetration seals;*
- *Part 4: Linear joint seals;*
- *Part 5: Service ducts and shafts;*
- *Part 6: Raised access and hollow core floors;*
- *Part 7: Conveyor systems and their closures;*
- *Part 8: Smoke extraction ducts;*
- *Part 9: Single compartment smoke extraction ducts;*
- *Part 10: Smoke control dampers;*
- *Part 11: Fire protective systems for cable systems and associated components (currently at Enquiry stage);*
- *Part 12: Non-mechanical fire barrier for ventilation ductwork.*

This standard underwent a formal review process during 2009-2011. Various comments were considered and these were only considered when they added clarity to the procedure. No changes have been made that make historical data redundant. This was deliberately avoided where it was thought to be occurring. If there are some issues with this, consideration should be given to the spirit of the original test combined with the better clarity now given.

The following technical changes were made in this new edition:

- Changes include the fact that symmetry as a concept has been removed. This does not negate original tests, but may now mean that some additional tests are needed.
- The figures have been clarified to show some more detail. Testing away from a wall or floor now has an equal distance between damper and the supporting construction. In this instance, historical data is not negated but any testing done after the publication of this standard needs to be done to the new dimensions.

- Further information is given on thermocouple placement and the concepts of T_3 , T_4 , etc. have been added to make it clear which thermocouples should be considered and when. The description of details on additional thermocouples around discontinuities has been added for clarification.
- Additional information has been added to show the details for testing fire dampers to demonstrate insulation characteristics where a fire damper is to be used un-ducted, ducted on one side or ducted on both sides.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The purpose of the test is to evaluate the ability of a fire damper to prevent fire and smoke spreading from one fire compartment to another through the air ductwork system which may penetrate fire separating walls and floors.

The fire damper is attached (directly or remotely via a section of ducting), to a fire separating element in a manner representative of practice. Tests are performed starting with the fire damper in the open position to expose the temperature sensing element of the fire damper to furnace conditions.

Temperature and integrity measurements are carried out in various parts of the test construction during the test. The leakage of the fire damper system is measured (continuously during the test) by direct flow measurements whilst maintaining a constant pressure differential across the closed fire damper of 300 Pa. The leakage of the fire damper in the closed position is also measured at ambient temperature, when a reduced leakage classification needs to be achieved.

An additional test to prove insulation characteristics may be needed if the damper needs to be used un-ducted on one side or on both sides. This test is not needed where such evidence is not required, or if insulation is not a requirement of performance, in the specific application.

Caution

The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard specifies a method for determining the fire resistance of fire dampers installed in fire separating elements designed to withstand heat and the passage of fire, smoke and gases at high temperature. This European Standard is used in conjunction with EN 1363-1.

This standard is not suitable for testing fire dampers in suspended ceilings.

This standard is not suitable for testing non-mechanical fire dampers (see EN 1366-12).

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:2012, *Fire resistance tests — Part 1: General Requirements*

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN 13501-3, *Fire classification of construction products and building elements — Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements (ISO 5167-1)*

EN ISO 13943, *Fire safety — Vocabulary (ISO 13943)*

ISO 5221, *Air distribution and air diffusion — Rules to methods of measuring air flow rate in an air handling duct*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1:2012 and EN ISO 13943 and the following apply.

3.1
fire damper
device for use in heating, ventilation and air-conditioning (HVAC) systems at fire boundaries to maintain compartmentation and protect means of escape in case of fire

Note 1 to entry: It may have reduced smoke leakage characteristics.

3.2
insulated fire damper
fire damper which satisfies both the integrity and insulation criteria for the anticipated fire resistance period

3.3
uninsulated fire damper
fire damper which satisfies the integrity criteria for the anticipated fire resistance period, but which does not provide a long enough insulation period to gain an EI classification