

SVENSK STANDARD

SS-EN 13501-4:2016



Fastställt/Approved: 2016-06-28
Publicerad/Published: 2016-06-30
Utgåva/Edition: 2
Språk/Language: engelska/English
ICS: 13.220.50

Brandteknisk klassificering av byggprodukter och byggnadselement –

Del 4: Klassificering baserad på data från provning av brandmotstånd hos komponenter i system för rökkontroll

Fire classification of construction products and building elements –

Part 4: Classification using data from fire resistance tests on components of smoke control systems

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-8021137>

Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 13501-4:2016 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 13501-4:2016.

Denna standard ersätter SS-EN 13501-4:2007+A1:2009, utgåva 1.

The European Standard EN 13501-4:2016 has the status of a Swedish Standard. This document contains the official English version of EN 13501-4:2016.

This standard supersedes the Swedish Standard SS-EN 13501-4:2007+A1:2009, edition 1.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Denna standard är framtagen av kommittén för Brandsäkerhet, SIS/TK 181.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 13501-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2016

ICS 13.220.50

Supersedes EN 13501-4:2007+A1:2009

English Version

Fire classification of construction products and building elements - Part 4: Classification using data from fire resistance tests on components of smoke control systems

Classement au feu des produits et éléments de construction - Partie 4: Classement à partir des données d'essais de résistance au feu des composants de dispositifs de contrôle de fumée

Klassifizierung von Bauprodukten und Bauarten zu ihrem Brandverhalten - Teil 4: Klassifizierung mit den Ergebnissen aus den Feuerwiderstandsprüfungen von Anlagen zur Rauchfreihaltung

This European Standard was approved by CEN on 23 April 2016.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Fire scenarios	8
4.1 General.....	8
4.2 The standard temperature/time curve (post flash-over fire)	9
4.3 The slow heating curve (smouldering fire)	9
4.4 Constant temperature attack.....	9
4.5 Specific thermal actions.....	10
4.5.1 Smoke control ducts.....	10
4.5.2 Smoke control dampers.....	10
4.5.3 Smoke barriers.....	10
4.5.4 Powered smoke and heat control ventilators.....	10
4.5.5 Natural smoke and heat exhaust ventilators	10
5 Resistance to fire performance characteristics	11
5.1 General.....	11
5.2 Performance characteristics.....	11
5.2.1 E – Integrity	11
5.2.2 I – Insulation	12
5.2.3 S – Smoke leakage	12
5.2.4 D – Stability duration under constant temperature	12
5.2.5 DH – Stability duration under the standard time-temperature curve.....	12
5.2.6 F – Functionality of powered smoke and heat ventilators	13
5.2.7 B – Functionality of natural smoke and heat ventilators.....	13
6 Declaration of performance	13
6.1 Classification periods	13
6.2 Designatory letters.....	13
6.3 Declaration of performance	13
6.4 Declaration of classes in product standards	13
6.5 Number of tests required for classification	13
6.6 Presentation of classification	14
7 Classification procedure for fire resistance	14
7.1 General.....	14
7.1.1 Procedure.....	14
7.1.2 General rules for deducing the number of fire resistance tests.....	15
7.1.3 Field of application.....	15
7.2 Classification of smoke control ducts	16
7.2.1 General.....	16
7.2.2 Test methods and field of application rules	16
7.2.3 Tests to be performed	16
7.2.4 Performance criteria	17

7.2.5	Classes	18
7.3	Classification of smoke control dampers	19
7.3.1	General.....	19
7.3.2	Test method and field of application rules	19
7.3.3	Tests to be performed	19
7.3.4	Performance criteria	20
7.3.5	Classes	22
7.4	Classification of smoke barriers	23
7.4.1	General.....	23
7.4.2	Test method.....	23
7.4.3	Tests to be performed	23
7.4.4	Performance criteria	24
7.4.5	Classes	24
7.5	Classification of powered smoke and heat control ventilators	24
7.5.1	Test method.....	24
7.5.2	Tests to be performed	24
7.5.3	Performance criteria	24
7.5.4	Classes	25
7.6	Classification of natural smoke and heat exhaust ventilators.....	25
7.6.1	Test method.....	25
7.6.2	Tests to be performed	25
7.6.3	Performance criteria	25
7.6.4	Classes	25
	Annex A (normative) Classification report	26
A.1	General.....	26
A.2	Content and format.....	26

European foreword

This document (EN 13501-4:2016) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This document supersedes EN 13501-4:2007+A1:2009.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2016, and conflicting national standards shall be withdrawn at the latest by March 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

CEN, CENELEC and EOTA committees preparing technical specifications which contain performance requirements against fire resistance tests can make reference to the fire resistance classification given in this European Standard and not refer directly to any specific fire test method.

EN 13501 *Fire classification of construction products and building elements* consists of the following parts:

- *Part 1: Classification using data from reaction to fire tests*
- *Part 2: Classification using data from fire resistance tests, excluding ventilation services*
- *Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*
- *Part 4: Classification using data from fire resistance tests on components of smoke control systems*
- *Part 5: Classification using data from external fire exposure to roof tests*
- *Part 6: Classification using data from reaction to fire tests on electric cables*

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard defines a harmonized procedure for the classification for resistance to fire of construction products. This classification is based on the test procedures sited in the relevant documents listed in Clause 2 and the relevant field of application procedures.

This European Standard is prepared in support of the second basic requirement, in the EC Construction Products Regulation (305/2011) and is detailed in the Interpretative Document number 2 (ID2): Safety in case of fire (OJC62 Vol 37).

The Interpretative Document and the Commission Decision of 3 May 2000 specify performance and classes regarding fire resistance.

These classes are identified by designation letters, each of which refers to an important characteristic of fire resistance behaviour.

This European Standard provides for a common understanding for these requirements. It interprets the functional requirements for the different groups of building products/elements and explains the method for deriving their classification on the basis of test results and/or extended application results for individual products/elements.

NOTE Test reports constitute the basis for extended application reports as explained in EN 15725.

1 Scope

This European Standard specifies the procedure for classification of components of smoke control systems, using data from fire resistance tests which are within the field of application of the relevant test methods. Classification on the basis of extended application of test results is also included in the scope of this European Standard.

Products covered by this European Standard are:

- smoke control ducts;
- smoke control dampers;
- smoke barriers;
- powered smoke and heat control ventilators (fans), including connectors;
- natural smoke and heat exhaust ventilators.

Relevant documents which include the relevant test methods which have been prepared for these products are listed in Clause 2.

2 Normative references

The following documents, in whole, or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1366-1, *Fire resistance tests for service installations - Part 1: Ventilation ducts*

EN 1366-2, *Fire resistance tests for service installations - Part 2: Fire dampers*

EN 1366-8, *Fire resistance tests for service installations - Part 8: Smoke extraction ducts*

EN 1366-9, *Fire resistance tests for service installations - Part 9: Single compartment smoke extraction ducts*

EN 1366-10, *Fire resistance tests for service installations - Part 10: Smoke control dampers*

EN 12101-1:2005, *Smoke and heat control systems - Part 1: Specification for smoke barriers*

EN 12101-2, *Smoke and heat control systems - Part 2: Specification for natural smoke and heat exhaust ventilators*

EN 12101-3, *Smoke and heat control systems - Part 3: Specification for powered smoke and heat control ventilators (Fans)*

EN 15725, *Extended application reports on the fire performance of construction products and building elements*

EN ISO 13943:2010, *Fire safety - Vocabulary (ISO 13943:2008)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 13943:2010 and the following apply.

3.1

direct field of application

outcome of a process (involving the application of defined rules) whereby a test result is deemed to be equally valid for variations in one or more of the product properties and/or intended end use applications

3.2

extended field of application

outcome of a process (involving the application of defined rules that can incorporate calculation procedures) that predicts, for a variation of a product property and/or its intended end use application(s), a test result on the basis of one or more test results to the same test standard

3.3

test specimen

product provided for test purposes

3.4

smoke control duct

duct used in a system to control the movement and/or containment of smoke and heat

3.4.1

single compartment smoke control duct

smoke control duct designed to provide a degree of fire resistance for use within single fire compartment application

3.4.2

multi compartment smoke control duct

smoke control duct designed to provide a degree of fire resistance for use in multicompartment applications

3.5

smoke control dampers

device, open or closed in its operational position to control the flow of smoke and hot gasses, which is automatically or manually activated

3.5.1

single-compartment smoke control damper

device for use within a single compartment, associated with a single compartment smoke extraction duct conforming to EN 1366-9

3.5.2

multi-compartment fire resisting smoke control damper

smoke control damper for use in multi-compartment applications, associated with a smoke extraction duct conforming to EN 1366-8