

# SVENSK STANDARD

## SS-EN 12101-2:2017



Fastställt/Approved: 2017-04-03  
Publicerad/Published: 2017-04-07  
Utgåva/Edition: 2  
Språk/Language: engelska/English  
ICS: 13.220.20; 13.220.99

---

### **Brand och räddning – System och komponenter för rök- och brandgaser – Del 2: Krav för brandgasventilatorer – Termisk brandventilation**

### **Smoke and heat control systems – Part 2: Natural smoke and heat exhaust ventilators**



# Standarder får världen att fungera

*SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.*

## Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

## Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

## Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

**Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på [www.sis.se](http://www.sis.se) eller ta kontakt med oss på tel 08-555 523 00.**



# Standards make the world go round

*SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.*

## Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

## Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

## Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

**If you want to know more about SIS, or how standards can streamline your organisation, please visit [www.sis.se](http://www.sis.se) or contact us on phone +46 (0)8-555 523 00**



Europastandarden EN 12101-2:2017 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 12101-2:2017.

Denna standard ersätter SS-EN 12101-2, utgåva 1.

The European Standard EN 12101-2:2017 has the status of a Swedish Standard. This document contains the official version of EN 12101-2:2017.

This standard supersedes the Swedish Standard SS-EN 12101-2, edition 1.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

*Upplysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna upplysningar om svensk och utländsk standard.*

*Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.*

Denna standard är framtagen av kommittén för Brandgasventilation, SIS/TK 360/AG 06.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.



EUROPEAN STANDARD

EN 12101-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2017

ICS 13.220.99

Supersedes EN 12101-2:2003

English Version

## Smoke and heat control systems - Part 2: Natural smoke and heat exhaust ventilators

Systèmes pour le contrôle des fumées et de la chaleur -  
Partie 2 : Dispositifs d'évacuation naturelle de fumées  
et de chaleur

Rauch- und Wärmefreihaltung - Teil 2: Natürliche  
Rauch- und Wärmeabzugsgeräte

This European Standard was approved by CEN on 11 January 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

<b>Contents</b>		Page
European foreword.....		5
Introduction .....		6
<b>1</b>	<b>Scope .....</b>	<b>7</b>
<b>2</b>	<b>Normative references .....</b>	<b>7</b>
<b>3</b>	<b>Terms, definitions, symbols and abbreviations.....</b>	<b>7</b>
<b>3.1</b>	<b>Terms and definitions .....</b>	<b>7</b>
<b>3.2</b>	<b>Symbols and abbreviations .....</b>	<b>11</b>
<b>4</b>	<b>Requirements .....</b>	<b>13</b>
<b>4.1</b>	<b>Nominal activation conditions/sensitivity .....</b>	<b>13</b>
<b>4.1.1</b>	<b>Initiation device.....</b>	<b>13</b>
<b>4.1.2</b>	<b>Opening mechanism.....</b>	<b>14</b>
<b>4.1.3</b>	<b>Inputs and outputs.....</b>	<b>14</b>
<b>4.2</b>	<b>Response delay (response time) .....</b>	<b>14</b>
<b>4.2.1</b>	<b>Reliability.....</b>	<b>14</b>
<b>4.2.2</b>	<b>Opening under (snow/wind) load .....</b>	<b>14</b>
<b>4.2.3</b>	<b>Low ambient temperature .....</b>	<b>15</b>
<b>4.2.4</b>	<b>Opening under heat.....</b>	<b>15</b>
<b>4.3</b>	<b>Operational reliability.....</b>	<b>15</b>
<b>4.4</b>	<b>Effectiveness of smoke/hot gas extraction (aerodynamic free area) .....</b>	<b>15</b>
<b>4.5</b>	<b>Performance parameters under fire conditions.....</b>	<b>15</b>
<b>4.5.1</b>	<b>Resistance to heat .....</b>	<b>15</b>
<b>4.5.2</b>	<b>Mechanical stability .....</b>	<b>16</b>
<b>4.5.3</b>	<b>Reaction to fire.....</b>	<b>16</b>
<b>4.6</b>	<b>Performance under environmental conditions .....</b>	<b>16</b>
<b>4.6.1</b>	<b>Opening under load.....</b>	<b>16</b>
<b>4.6.2</b>	<b>Low ambient temperature .....</b>	<b>16</b>
<b>4.6.3</b>	<b>Stability under wind load .....</b>	<b>16</b>
<b>4.6.4</b>	<b>Resistance to wind-induced vibration.....</b>	<b>16</b>
<b>4.6.5</b>	<b>Resistance to heat .....</b>	<b>16</b>
<b>4.7</b>	<b>Durability .....</b>	<b>17</b>
<b>4.7.1</b>	<b>Response delay (response time) .....</b>	<b>17</b>
<b>4.7.2</b>	<b>Operational reliability.....</b>	<b>17</b>
<b>4.7.3</b>	<b>Performance parameters under fire conditions.....</b>	<b>17</b>
<b>5</b>	<b>Testing, assessment and sampling methods .....</b>	<b>17</b>
<b>6</b>	<b>Assessment and verification of constancy of performance - AVCP .....</b>	<b>19</b>
<b>6.1</b>	<b>General.....</b>	<b>19</b>
<b>6.2</b>	<b>Type Testing.....</b>	<b>19</b>
<b>6.2.1</b>	<b>General.....</b>	<b>19</b>
<b>6.2.2</b>	<b>Test samples, testing and compliance criteria .....</b>	<b>20</b>
<b>6.2.3</b>	<b>Test sequence .....</b>	<b>21</b>
<b>6.2.4</b>	<b>Test reports.....</b>	<b>22</b>
<b>6.2.5</b>	<b>Cascading determination of the product type results .....</b>	<b>22</b>
<b>6.3</b>	<b>Factory production control .....</b>	<b>23</b>
<b>6.3.1</b>	<b>General.....</b>	<b>23</b>

6.3.2	Requirements.....	23
6.3.3	NSHEV specific requirements.....	25
6.3.4	Initial inspection of factory and FPC.....	26
6.3.5	Continuous surveillance of FPC.....	26
6.3.6	Procedure for modifications.....	27
6.3.7	Pre-production prototypes.....	27
7	Marking, labelling and packaging.....	28
Annex A	(normative) Classification.....	29
A.1	Nominal activation condition/sensitivity.....	29
A.2	Response delay.....	29
A.3	Operational Reliability.....	29
A.4	Effectiveness of smoke/hot gas extraction (aerodynamic free area).....	29
A.5	Performance parameters under fire conditions.....	29
A.6	Performance under environmental conditions.....	30
A.7	Durability.....	31
A.7.1	Response delay (response time).....	31
A.7.2	Operational reliability.....	31
A.7.3	Performance parameters under fire conditions.....	31
Annex B	(normative) Effectiveness of smoke/hot gas extraction (aerodynamic free area).....	32
B.1	Determination of the aerodynamic free area.....	32
B.2	Simple assessment procedure.....	32
B.2.1	General.....	32
B.2.2	Roof mounted NSHEV.....	32
B.2.3	Wall mounted NSHEV.....	32
B.3	Experimental procedure.....	33
B.3.1	General.....	33
B.3.2	Test apparatus.....	33
B.3.3	Test specimen.....	34
B.3.4	Test procedure.....	35
B.3.5	Evaluation of test results.....	36
B.3.6	Calculation of the coefficient of discharge for a family of NSHEV.....	37
B.4	Test to check the aerodynamic test installations.....	38
B.4.1	General.....	38
B.4.2	Reference test without side wind.....	39
B.4.3	Reference tests with side wind.....	39
B.4.4	Evaluation of test results.....	39
Annex C	(normative) Test method for operational reliability and response time.....	54
C.1	Objective of test.....	54
C.2	Test conditions.....	54
C.3	Test apparatus.....	54
C.4	Test specimen.....	54
C.5	Test procedure.....	54
Annex D	(normative) Test method for opening under load.....	56
D.1	Objective of test.....	56
D.2	Test conditions.....	56
D.3	Test apparatus.....	56
D.4	Test specimen.....	57
D.5	Test procedure.....	57
Annex E	(normative) Test method for low ambient temperature.....	58
E.1	Objective of test.....	58

**SS-EN 12101-2:2017 (E)**

<b>E.2</b>	<b>Test apparatus</b> .....	<b>58</b>
<b>E.3</b>	<b>Test specimen</b> .....	<b>58</b>
<b>E.4</b>	<b>Test procedure</b> .....	<b>58</b>
<b>Annex F (normative) Test method for stability under wind load</b> .....		<b>59</b>
<b>F.1</b>	<b>Objective of test</b> .....	<b>59</b>
<b>F.2</b>	<b>Test conditions</b> .....	<b>59</b>
<b>F.3</b>	<b>Test apparatus</b> .....	<b>59</b>
<b>F.4</b>	<b>Test specimen</b> .....	<b>59</b>
<b>F.5</b>	<b>Test procedure</b> .....	<b>60</b>
<b>F.5.1</b>	<b>Wind load</b> .....	<b>60</b>
<b>F.5.2</b>	<b>Vibration</b> .....	<b>60</b>
<b>Annex G (normative) Test method for resistance to heat</b> .....		<b>61</b>
<b>G.1</b>	<b>Objective of the test</b> .....	<b>61</b>
<b>G.2</b>	<b>Test apparatus</b> .....	<b>61</b>
<b>G.2.1</b>	<b>Test furnace</b> .....	<b>61</b>
<b>G.2.2</b>	<b>Temperature measurement</b> .....	<b>61</b>
<b>G.2.3</b>	<b>NSHEV mount</b> .....	<b>61</b>
<b>G.3</b>	<b>Test specimen</b> .....	<b>62</b>
<b>G.3.1</b>	<b>General</b> .....	<b>62</b>
<b>G.3.2</b>	<b>NSHEV mounted to a glazed partition construction</b> .....	<b>62</b>
<b>G.3.3</b>	<b>Roof mounted NSHEV as part of a continuous rooflight</b> .....	<b>62</b>
<b>G.3.4</b>	<b>Wall mounted NSHEV</b> .....	<b>63</b>
<b>G.3.5</b>	<b>Roof mounted NSHEV</b> .....	<b>63</b>
<b>G.4</b>	<b>Test procedure</b> .....	<b>64</b>
<b>Annex H (normative) Mounting and fixing conditions for the SBI or small flame tests</b> .....		<b>72</b>
<b>H.1</b>	<b>General</b> .....	<b>72</b>
<b>H.2</b>	<b>Class E</b> .....	<b>73</b>
<b>H.2.1</b>	<b>General</b> .....	<b>73</b>
<b>H.2.2</b>	<b>Small flame test in accordance to EN ISO 11925-2</b> .....	<b>73</b>
<b>H.3</b>	<b>Class A2 to class D</b> .....	<b>73</b>
<b>H.3.1</b>	<b>General</b> .....	<b>73</b>
<b>H.3.2</b>	<b>Single Burning Item test (SBI)</b> .....	<b>74</b>
<b>H.4</b>	<b>Heat of combustion test</b> .....	<b>74</b>
<b>Annex I (normative) Handling changes affecting declared performances for NSHEV</b> .....		<b>75</b>
<b>I.1</b>	<b>General</b> .....	<b>75</b>
<b>I.2</b>	<b>Effectiveness of smoke/hot gas extraction</b> .....	<b>75</b>
<b>I.3</b>	<b>Reliability</b> .....	<b>75</b>
<b>I.4</b>	<b>Opening under load</b> .....	<b>76</b>
<b>I.5</b>	<b>Opening at low ambient temperatures</b> .....	<b>76</b>
<b>I.6</b>	<b>Wind load</b> .....	<b>77</b>
<b>I.7</b>	<b>Resistance to heat</b> .....	<b>77</b>
<b>Annex J (informative) Installation and maintenance information</b> .....		<b>78</b>
<b>J.1</b>	<b>Installation information</b> .....	<b>78</b>
<b>J.2</b>	<b>Maintenance information</b> .....	<b>78</b>
<b>Bibliography</b> .....		<b>88</b>



## European foreword

This document (EN 12101-2:2017) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2017, and conflicting national standards shall be withdrawn at the latest by December 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12101-2:2003.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this standard.

This European Standard is one of the parts of the European Standard EN 12101 covering smoke and heat control systems.

This European Standard has the general title *Smoke and heat control systems* and currently consists of the following parts:

- *Part 1: Specification for smoke barriers;*
- *Part 2: Natural smoke and heat exhaust ventilators* [the present document];
- *Part 3: Specification for powered smoke and heat exhaust ventilators;*
- *Part 4: Installed SHEVS systems for smoke and heat ventilation* [Technical Report CEN/TR 12101-4];
- *Part 5: Guidelines on functional recommendations and calculation methods for smoke and heat exhaust ventilation systems* [Technical Report CEN/TR 12101-5];
- *Part 6: Specification for pressure differential systems – Kits;*
- *Part 7: Smoke control sections;*
- *Part 8: Smoke control dampers;*
- *Part 10: Power supplies.*

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**SS-EN 12101-2:2017 (E)****Introduction**

In a fire situation, smoke and heat exhaust ventilation systems create and maintain a smoke free layer above the floor by removing smoke. They also serve simultaneously to exhaust hot gases released by a fire in the developing stages. The use of such systems to create smoke-free areas beneath a buoyant layer has become widespread. Their value in assisting in the evacuation of people from buildings and other construction works, reducing fire damage and financial loss by preventing smoke damage, facilitating access for firefighting by improving visibility, reducing roof temperatures and retarding the lateral spread of fire is firmly established. For these benefits to be obtained it is essential that natural smoke and heat exhaust ventilators (referred to in this standard as NSHEV) operate fully and reliably whenever called upon to do so during their installed life. A smoke and heat exhaust ventilation system (referred to in this standard as a SHEVS) is a system of safety equipment intended to perform a positive role in a fire emergency.

## 1 Scope

This European Standard applies to natural smoke and heat exhaust ventilators (NSHEV) operating as part of smoke and heat exhaust systems (SHEVS), placed on the market. This standard specifies requirements and gives test methods for natural smoke and heat exhaust ventilators which are intended to be installed in smoke and heat control systems in buildings.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-5:2017, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 54-7, *Fire detection and fire alarm systems - Part 7: Smoke detectors - Point detectors using scattered light, transmitted light or ionization*

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 12101-10, *Smoke and heat control systems - Part 10: Power supplies*

EN 13501-1, *Fire classification of construction products and building elements — Part 1: Classification using test data from reaction to fire tests*

EN 13823, *Reaction to fire tests for building products — Building products excluding floorings exposed to the thermal attack by a single burning item*

EN 60584-1, *Thermocouples — Part 1: EMF specifications and tolerances (IEC 60584-1)*

EN ISO 1182, *Reaction to fire tests for products - Non-combustibility test (ISO 1182)*

EN ISO 1716, *Reaction to fire tests for products - Determination of the gross heat of combustion (calorific value) (ISO 1716)*

EN ISO 11925-2, *Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test (ISO 11925-2)*

## 3 Terms, definitions, symbols and abbreviations

### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1.1

##### **aerodynamic free area**

geometric area multiplied by the coefficient of discharge

#### 3.1.2

##### **ambient**

word used to describe properties of the surroundings