

SVENSK STANDARD

SS-EN 15232-1:2017



Fastställt/Approved: 2017-06-09
Publicerad/Published: 2017-06-20
Utgåva/Edition: 1
Språk/Language: engelska/English
ICS: 91.120.10; 91.140.10; 97.120

Byggnaders energiprestanda – Del 1: Inverkan av byggnadsautomation, styrning och teknisk byggnadsdrift- Modul M10-4,5,6,7,8,9,10

Energy performance of buildings – Part 1: Impact of Building Automation, Controls and Building Management – Modules M10-4,5,6,7,8,9,10

This preview is downloaded from www.sis.se. Buy the entire standard via <https://www.sis.se/std-8026813>

Standarder får världen att fungera

SIS (Swedish Standards Institute) är en fristående ideell förening med medlemmar från både privat och offentlig sektor. Vi är en del av det europeiska och globala nätverk som utarbetar internationella standarder. Standarder är dokumenterad kunskap utvecklad av framstående aktörer inom industri, näringsliv och samhälle och befrämjar handel över gränser, bidrar till att processer och produkter blir säkrare samt effektiviserar din verksamhet.

Delta och påverka

Som medlem i SIS har du möjlighet att påverka framtida standarder inom ditt område på nationell, europeisk och global nivå. Du får samtidigt tillgång till tidig information om utvecklingen inom din bransch.

Ta del av det färdiga arbetet

Vi erbjuder våra kunder allt som rör standarder och deras tillämpning. Hos oss kan du köpa alla publikationer du behöver – allt från enskilda standarder, tekniska rapporter och standardpaket till handböcker och onlinetjänster. Genom vår webbtjänst e-nav får du tillgång till ett lättnavigerat bibliotek där alla standarder som är aktuella för ditt företag finns tillgängliga. Standarder och handböcker är källor till kunskap. Vi säljer dem.

Utveckla din kompetens och lyckas bättre i ditt arbete

Hos SIS kan du gå öppna eller företagsinterna utbildningar kring innehåll och tillämpning av standarder. Genom vår närhet till den internationella utvecklingen och ISO får du rätt kunskap i rätt tid, direkt från källan. Med vår kunskap om standarders möjligheter hjälper vi våra kunder att skapa verklig nytta och lönsamhet i sina verksamheter.

Vill du veta mer om SIS eller hur standarder kan effektivisera din verksamhet är du välkommen in på www.sis.se eller ta kontakt med oss på tel 08-555 523 00.



Standards make the world go round

SIS (Swedish Standards Institute) is an independent non-profit organisation with members from both the private and public sectors. We are part of the European and global network that draws up international standards. Standards consist of documented knowledge developed by prominent actors within the industry, business world and society. They promote cross-border trade, they help to make processes and products safer and they streamline your organisation.

Take part and have influence

As a member of SIS you will have the possibility to participate in standardization activities on national, European and global level. The membership in SIS will give you the opportunity to influence future standards and gain access to early stage information about developments within your field.

Get to know the finished work

We offer our customers everything in connection with standards and their application. You can purchase all the publications you need from us - everything from individual standards, technical reports and standard packages through to manuals and online services. Our web service e-nav gives you access to an easy-to-navigate library where all standards that are relevant to your company are available. Standards and manuals are sources of knowledge. We sell them.

Increase understanding and improve perception

With SIS you can undergo either shared or in-house training in the content and application of standards. Thanks to our proximity to international development and ISO you receive the right knowledge at the right time, direct from the source. With our knowledge about the potential of standards, we assist our customers in creating tangible benefit and profitability in their organisations.

If you want to know more about SIS, or how standards can streamline your organisation, please visit www.sis.se or contact us on phone +46 (0)8-555 523 00



Europastandarden EN 15232-1:2017 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 15232-1:2017.

Denna standard ersätter SS-EN 15232:2012, utgåva 2.

The European Standard EN 15232-1:2017 has the status of a Swedish Standard. This document contains the official version of EN 15232-1:2017.

This standard supersedes the Swedish Standard SS-EN 15232:2012, edition 2.

© Copyright/Upphovsrätten till denna produkt tillhör SIS, Swedish Standards Institute, Stockholm, Sverige. Användningen av denna produkt regleras av slutanvändarlicensen som återfinns i denna produkt, se standardens sista sidor.

© Copyright SIS, Swedish Standards Institute, Stockholm, Sweden. All rights reserved. The use of this product is governed by the end-user licence for this product. You will find the licence in the end of this document.

Uppllysningar om sakinnehållet i standarden lämnas av SIS, Swedish Standards Institute, telefon 08-555 520 00. Standarder kan beställas hos SIS Förlag AB som även lämnar allmänna uppllysningar om svensk och utländsk standard.

Information about the content of the standard is available from the Swedish Standards Institute (SIS), telephone +46 8 555 520 00. Standards may be ordered from SIS Förlag AB, who can also provide general information about Swedish and foreign standards.

Denna standard är framtagen av kommittén för Styrning av innemiljö (Installationer), SIS/TK 189/AG 03.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på www.sis.se - där hittar du mer information.

EUROPEAN STANDARD

EN 15232-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2017

ICS 91.120.10; 97.120

Supersedes EN 15232:2012

English Version

Energy Performance of Buildings - Energy performance of buildings - Part 1: Impact of Building Automation, Controls and Building Management - Modules M10-4,5,6,7,8,9,10

Performance énergétique des bâtiments - Partie 1: Impact de l'automatisation, de la régulation et de la gestion technique - Modules M10-4, 5, 6, 7, 8, 9, 10

Energieeffizienz von Gebäuden - Teil 1: Einfluss von Gebäudeautomation und Gebäudemanagement - Module M10-4, 5, 6, 7, 8, 9, 10

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

SS-EN 15232-1:2017 (E)

Contents	Page
European foreword.....	5
Introduction	6
1 Scope.....	7
2 Normative references.....	9
3 Terms and definitions	10
4 Symbols, subscripts and abbreviations.....	13
4.1 Symbols.....	13
4.2 Subscripts.....	13
5 Description of the method	14
5.1 Output of the method.....	14
5.2 General description of the method(s)	14
5.3 Selection criteria between the methods.....	14
5.4 BAC and TBM functions having an impact on the energy performance of buildings.....	15
5.5 BAC Efficiency Class.....	32
5.6 BAC and TBM functions assigned to the BAC efficiency classes	33
5.7 Applying BAC for EMS and maintaining BAC energy efficiency	46
5.7.1 General.....	46
5.7.2 Applying BAC for EMS.....	46
5.7.3 Maintaining BAC energy efficiency	46
6 Method 1 - Detailed calculation procedure of the BAC contribution to the energy performance of buildings (Detailed method).....	46
6.1 Output data.....	46
6.2 Calculation time steps	48
6.3 Input data - Source of data	48
6.4 Calculation procedure	48
6.4.1 Applicable timestep.....	48
6.4.2 Energy performance calculation	49
7 Method 2 - Factor based calculation procedure of the BAC impact on the energy performance of buildings (BAC factor method).....	51
7.1 Output data.....	51
7.2 Calculation interval	52
7.3 Calculation procedure - Energy calculation	52
8 Simplified input data correlations.....	56
9 Quality control	56
10 Compliance check.....	56
Annex A (informative) BAC efficiency factors.....	57
A.1 Overall BAC efficiency factors for the thermal energy $f_{BAC,th}$	57
A.2 Overall BAC efficiency factors for electric energy $f_{BAC,el}$	58
A.3 Detailed BAC efficiency factors for heating and cooling	59

A.4	Detailed BAC efficiency factors for DHW	60
A.5	Detailed BAC efficiency factors for lighting and auxiliary energy	61
	Annex B (informative) Minimum BAC function type requirements	62
	Annex C (informative) Determination of the BAC efficiency factors	67
C.1	Determination procedure	67
C.2	Detailed modelling approaches and user profiles	68
C.2.1	General	68
C.2.2	Efficiency class C (reference)	69
C.2.3	Efficiency class D	70
C.2.4	Efficiency class B	71
C.2.5	Efficiency class A	72
C.3	Boundary condition	72
C.3.1	General	72
C.3.2	Office	73
C.3.3	Hotel	74
C.3.4	Education, school	75
C.3.5	Lecture hall	76
C.3.6	Restaurant	77
C.3.7	Wholesale centre	78
C.3.8	Hospital	79
C.4	BAC efficiency classes - Domestic Hot Water (DHW)	80
C.5	Impact of geographical location on the BAC efficiency factors	80
C.6	Influence of the different user profiles on the BAC factors	83
	Annex D (informative) Examples of how to use the BAC function list of EN ISO 16484-3 to describe functions from this European Standard	85
D.1	General	85
D.2	Direct representation by a function defined in EN ISO 16484-3	85
D.2.1	Example 1 - Night cooling	85
D.2.2	Example 2 - h,x- directed control	85
D.3	Representation by a combination of functions defined in EN ISO 16484-3	86
D.3.1	Example 3 - Individual room automatic control	86
D.3.2	Example 4 - Outside temperature compensated control	86
	Annex E (informative) Applying BAC for EMS specified in EN ISO 50001	88
E.1	General	88
E.2	Guideline for using BACS for EMS	88
	Annex F (informative) Maintain BAC energy efficiency	102
F.1	General	102

SS-EN 15232-1:2017 (E)

F.2	Activity 1 - Maintain and improve the BAC efficiency class	102
F.2.1	General.....	102
F.2.2	Monitoring.....	102
F.2.3	Operation	102
F.2.4	Energy Efficiency.....	102
F.2.5	Modernizations, Upgrades and new Technologies	102
F.3	Activity 2 - Upgrading of the BAC efficiency class	103
F.3.1	General.....	103
F.3.2	Procedure for meeting an BAC efficiency class	103
	Annex G (informative) Control accuracy	105
	Bibliography.....	106

European foreword

This document (EN 15232-1:2017) has been prepared by Technical Committee CEN/TC 247 “Building Automation, Controls and Building Management”, the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2017, and conflicting national standards shall be withdrawn at the latest by November 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15232:2012.

The most important changes are:

- respect the presentation of this project in the frame EPB in accordance with the drafting rules;
- a structured updated list of Building Automation and Control (BAC) functions;
- a set of new BMS function introduced in the new EPBD standard EN 16947-1 has been added to the list of functions thus completing the former TBM functions.

This document has been prepared under a mandate [22] given to CEN by the European Commission and the European Free Trade Association.

This document is part of the set of standards on the energy performance of buildings (the set of EPB standards).

In case this standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements.

Further target groups are users of the voluntary common European Union certification scheme for the energy performance of non-residential buildings (EPBD art.11.9) and any other regional (e.g. Pan European) parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

SS-EN 15232-1:2017 (E)

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called “EPB set of standards”.

As part of the “EPB set of standards” it complies with the requirements for the set of basic EPB documents EN ISO 52000-1 (see Normative references), CEN/TS 16628 and CEN/TS 16629 (see Bibliography [2] and [3]) developed under a mandate given to CEN by the European Commission and the European Free Trade Association (Mandate M/480).

The standards issued by TC 247 for M/480 belong to the EPB set of standards and are in line with the over-arching standard (EN ISO 52000-1) and drafted in accordance with the basic principles and detailed technical rules developed in the Phase I of the mandate.

Also these standards are clearly identified in the modular structure developed to ensure a transparent and coherent EPB standard set. BAC (Building Automation and Control) is identified in the modular structure as Technical Building System M10. However, the standards of TC 247 deal with control accuracy, control functions and control strategies using standards communications protocol (these last standards do not belong to the EPB standards set).

To avoid a duplication of calculation due to the BAC (avoid double impact), no calculation are done in BAC EPB standard set, but in each underlying standard of EPB set of standards (from M1 to M9 in the Modular Structure), an IDENTIFIER developed and present in the M10 covered by EN 15232-1 is used where appropriate. These way of interaction is described in detailed in the Technical Report (CEN ISO/TR 52000-2) accompanying the over-arching standard. As consequence, the Annex A and Annex B concept as EXCEL sheet with the calculation formulas used in the EPB standards are not applicable for the standards issued by TC 247 for M/480.

The main target groups of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 15232-2 [5]).

1 Scope

This European Standard specifies:

- a structured list of control, building automation and technical building management functions which contribute to the energy performance of buildings; functions have been categorized and structured according to building disciplines and so called Building automation and control (BAC);
- a method to define minimum requirements or any specification regarding the control, building automation and technical building management functions contributing to energy efficiency of a building to be implemented in building of different complexities;
- a factor based method to get a first estimation of the effect of these functions on typical buildings types and use profiles;
- detailed methods to assess the effect of these functions on a given building.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively.

SS-EN 15232-1:2017 (E)

Table 1 — Position of this standard (in casu M10–4,5,6,7,8,9,10), within the modular structure of the set of EPB standards

	Over-arching	Building (as such)	Technical Building System									
Submodule	Descriptions	Descriptions	Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot waters	Lighting	Building automation and control	PV, wind, ..
sub1	M1	M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General	General	General									
2	Common terms and definitions; symbols, units and subscripts	Building Energy Needs	Needs									
3	Application	(Free) Indoor Conditions without Systems	Maximum Load and Power									
4	Ways to Express Energy Performance	Ways to Express Energy Performance	Ways to Express Energy Performance								x	
5	Building Functions and Building Boundaries	Heat Transfer by Transmission	Emission and control								x	
6	Building Occupancy and Operating Conditions	Heat Transfer by Infiltration and Ventilation	Distribution and control								x	
7	Aggregation of Energy Services and Energy Carriers	Internal Heat Gains	Storage and control								x	
8	Building Partitioning	Solar Heat Gains	Generation and control								x	
9	Calculated Energy Performance	Building Dynamics (thermal mass)	Load dispatching and operating conditions								x	
10	Measured Energy Performance	Measured Energy Performance	Measured Energy Performance								x	
11	Inspection	Inspection	Inspection									
12	Ways to Express Indoor Comfort		BMS									
13	External Environment Conditions											
14 ^a	Economic Calculation											

^a The shaded modules are not applicable.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13779, *Ventilation for non-residential buildings — Performance requirements for ventilation and room-conditioning systems*

EN 15193-1, *Energy performance of buildings — Energy requirements for lighting*

EN 15243:2007, *Ventilation for buildings — Calculation of room temperatures and of load and energy for buildings with room conditioning systems*

EN 15316 (all parts), *Heating systems in buildings — Method for calculation of system energy requirements and system efficiencies*

EN 15316-2, *Energy performance of buildings — Method for calculation of system energy requirements and system efficiencies — Part 2: Space emission systems (heating and cooling), Module M3-5, M4-5*

EN 15316-4-5, *Energy performance of buildings — Method for calculation of system energy requirements and system efficiencies — Part 4-5: District heating and cooling, Module M3-8-5, M4-8-5, M8-8-5, M11-8-5*

EN 16798-5-1, *Energy performance of buildings — Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8 — Ventilation for buildings — Calculation methods for energy requirements of ventilation and air conditioning systems — Part 5-1: Distribution and generation (revision of EN 15241) — Method 1*

EN 16798-7, *Energy performance of buildings — Part 7: Ventilation for buildings — Modules M5-1, M5-5, M5-6, M5-8 — Calculation methods for the determination of air flow rates in buildings including infiltration*

EN 16798-9, *Energy performance of buildings — Part 09: Ventilation for buildings — Module M4-1, M4-4, M4-9 — Calculation methods for energy requirements — Calculation methods for energy requirements of cooling systems — General*

EN 16798-13, *Energy performance of buildings — Part 13: Module M4-8 — Calculation of cooling systems — Generation*

EN 16798-15, *Energy performance of buildings — Part 15: Module M4-7 — Calculation of cooling systems — Storage — General*

EN 16947 series, *Energy Performance of Buildings — Building Management*

EN ISO 7345:1995, *Thermal insulation — Physical quantities and definitions (ISO 7345:1987)*

EN ISO 50001:2011, *Energy management systems — Requirements with guidance for use (ISO 50001:2011)*

EN ISO 52000-1:2017, *Energy performance of buildings — Overarching EPB assessment — Part 1: General framework and procedures (ISO 52000-1:2017)*

EN ISO 52016-1, *Energy performance of buildings — Energy needs for heating and cooling, internal temperatures and sensible and latent heat loads — Part 1: Calculation procedures (ISO 52016-1)*

SS-EN 15232-1:2017 (E)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 7345:1995, in EN ISO 52000-1:2017 and the following apply.

3.1 auxiliary energy

electrical energy used by technical building systems to support energy transformation to satisfy energy needs

Note 1 to entry: This includes energy for fans, pumps, electronics etc. Electrical energy input to the ventilation system for air transport and heat recovery is not considered as auxiliary energy, but as energy use for ventilation.

Note 2 to entry: In EN ISO 9488 the energy used for pumps and valves is called “parasitic energy”.

[SOURCE: EN ISO 52000-1]

3.2 building automation and control BAC

products, software, and engineering services for automatic controls, monitoring and optimization, human intervention, and management to achieve energy-efficient, economical, and safe operation of building services equipment

[SOURCE: EN ISO 52000-1:2017, modified – The symbol BAC was added.]

3.3 building automation and control system BACS

system, comprising all products, software and engineering services for automatic controls (including interlocks), monitoring, optimization, for operation, human intervention, and management to achieve energy-efficient, economical, and safe operation of building services

Note 1 to entry: BACS is also referred to as BMS (Building management system).

Note 2 to entry: The use of the word ‘control’ does not imply that the system/device is restricted to control functions. Processing of data and information is possible.

Note 3 to entry: If a building control system, building management system, or building energy management system complies with the requirements of the EN ISO 16484- series, it should be designated as a building automation and control system (BACS).

Note 4 to entry: Building services is divided in technical, infrastructural and financial building services and energy management is part of technical building management.

Note 5 to entry: Building energy management system is part of a BMS.

Note 6 to entry: Building energy management system comprising data collection, logging, alarming, reporting, and analysis of energy usage etc. The system is designed to reduce the energy consumption, improve the utilization, increase the reliability, and predict the performance of the technical building systems, as well as optimize energy usage and reducing its cost.

[SOURCE: EN ISO 16484-2:2004, modified – Notes 1, 4 and 5 have been added.]

3.4 building management BM

totality of services involved in the management operation and monitoring of buildings (including plants and installations)

Note 1 to entry: Building management can be assigned as part of facility management.

[SOURCE: CEN/TS 15379:2006, modified – Second part of the definition became Note 1 to entry.]

3.5 control function

BAC effect of programs and parameters

Note 1 to entry: BAC functions are referred to as control functions, I/O, processing, optimization, management and operator functions. They are listed in the BAC FL (function list) for a specification of work.

Note 2 to entry: Function is a program unit that delivers exactly one data element, which can be a multiple value (i.e. an array or a structure). Functions can be an operand in a program. [EN 61131-3]

3.6 delivered energy

energy, expressed per energy carrier, supplied to the technical building systems through the assessment boundary, to satisfy the uses taken into account or to produce the exported energy

Note 1 to entry: Delivered energy can be calculated for defined energy uses or it can be measured.

[SOURCE: EN ISO 52000-1]

3.7 energy carrier

substance or phenomenon that can be used to produce mechanical work or heat or to operate chemical or physical processes

[SOURCE: EN ISO 52000-1]

3.8 energy need for heating or cooling

heat to be delivered to or extracted from a thermally conditioned space to maintain the intended space temperature conditions during a given period of time

Note 1 to entry: The energy need can include additional heat transfer resulting from non-uniform temperature distribution and non-ideal temperature control, if they are taken into account by increasing (decreasing) the effective temperature for heating (cooling) and not included in the heat transfer due to the heating (cooling) system.

SS-EN 15232-1:2017 (E)

3.9 energy efficiency

ratio or other quantitative relationship between an output of performance, service, goods or energy, and an input of energy

EXAMPLE Efficiency conversion energy; energy required/energy used; output/input; theoretical energy used to operate/energy used to operate.

Note 1 to entry: Both input and output need to be clearly specified in quantity and quality, and be measurable.

[SOURCE: EN ISO 50001-1:2011 modified - Symbol removed]

3.10 energy efficiency improvement

increase in energy efficiency as a result of technological, behavioural or economic changes

[SOURCE: EN ISO 50001-1:2011]

3.11 integrated building automation and control systems

BACS designed to be interoperable and with the ability to be connected to one or more specified 3rd party building automation and control devices/systems through open data communication network or interfaces performed by standardized methods, special services and permitted responsibilities for system integration

EXAMPLE Interoperability between 3rd party BACS devices/systems for HVAC, domestic hot water, lighting, electrical power distribution, energy metering, elevators and escalators, other plants, as well as systems for communications, access control, security, life safety etc.

3.12 integrated function

BAC effect of programs, shared data points and parameters for multi-discipline interrelationships between various building services and technologies

3.13 measured energy performance

energy performance based on measured amounts of delivered and exported energy

Note 1 to entry: The measured rating is the weighted sum of all energy carriers used by the building, as measured by meters or derived from measured energy by other means. It is a measure of the in-use performance of the building after correction or extrapolation. This is particularly relevant to certification of actual energy performance.

Note 2 to entry: Also known as “operational rating”.

[SOURCE: EN ISO 52000-1]

3.14 set-point temperature of a conditioned zone

internal (minimum) temperature, as fixed by the control system in normal heating mode, or internal (maximum) temperature, as fixed by the control system in normal cooling mode

Note 1 to entry: The corrected value of a temperature setpoint is used for the calculation of energy performance. It enables the impact of the accuracy of the control system on the energy performance to be taken into account.

3.15
thermally activated building systems

TABS

massive building fabric actively heated or cooled by integrated air or water based systems

3.16
technical building management

TBM

process(es) and services related to operation and management of buildings and technical building system through the interrelationships between the different disciplines and trades

Note 1 to entry: The disciplines and trades comprise all technical building services for the purpose of optimized maintenance and energy consumption.

EXAMPLE Optimization of buildings through interrelationships ranging from heating, ventilation and air conditioning (HVAC) to lighting and day lighting to life safety and security to electric power systems and energy monitoring and metering; to its services, including communications and maintenance and to its management.

3.17
technical building system

technical equipment for heating, cooling, ventilation, humidification, dehumidification, domestic hot water, lighting and electricity production

Note 1 to entry: A technical building system can refer to one or to several building services (e.g. heating, heating and DHW).

Note 2 to entry: A technical building system is composed of different subsystems.

Note 3 to entry: Electricity production can include cogeneration and photovoltaic systems.

[SOURCE: EN ISO 52000-1]

4 Symbols, subscripts and abbreviations

4.1 Symbols

For the purposes of this document,, the symbols given in EN ISO 52000-1:2017, Clause 4 and Annex C and the specific symbols listed in Table 2 apply.

Table 2 — Symbols and units

Symbol	Quantity	Unit
a	normalized level, e.g. occupancy or gains	-
$\bar{\beta}$	mean part load	-
ϕ	heat flow rate, thermal power	kW

4.2 Subscripts

For the purposes of this document, the subscript given in EN ISO 52000-1:2017, Clause 4 and Annex C and the specific subscripts listed in Table 3 apply.

SS-EN 15232-1:2017 (E)**Table 3 — Subscripts**

Subscript	Term	Subscript	Term	Subscript	Term
amb	ambient	end	end	th	thermal
BAC	building automation and control	r	room	trans	transfer
cor	correction	ref	reference		
DHW	domestic hot water	sta	start		

5 Description of the method**5.1 Output of the method**

This standard describes two methods of how to calculate the contribution of building automation and controls to the energy performance of buildings. The two methods are:

- Detailed method: Output of the detailed method is a list of automation, control and management function types that is used to run a detailed calculation of building energy performance based on other EPBD standards. Beside this the detailed method would also allow classification of a building automation and control system according to a set of criteria defined in this standard. There is no limitation regarding the time step.
- Factor based method: Output of the factor based method is the energy demand of a building according to a given building automation and control classification. The time step of the output is a yearly step.


5.2 General description of the method(s)

Two methods are given:

- method 1, defined in Clause 6 “Method 1 – Detailed method”, is meant for a detailed energy performance analysis of a building in case detailed information about the building, the HVAC systems and especially the type of automation, control and management functions is available that can be applied in a holistic EPBD calculation method.
- method 2, defined in Clause 7 “Method 2 – Factor based method” is intended for easily calculating a rough estimate of the impact of building automation, control and management on the energy performance of a building just based on a given energy performance (either a consumption metered, or a demand calculated) correlated to a certain BAC efficiency classification of the building.

5.3 Selection criteria between the methods

For the calculation of the impact of building automation, control and management functions on the building energy performance the detailed method is method 1 in this standard. The following Figure 1 illustrates how to use the detailed method compared to the simplified BAC Factor method.



Key

a delivered energy is the total energy, expressed per energy carrier (gas, oil, electricity etc.) used for heating, cooling, ventilation, domestic hot water or lighting

NOTE Arrows illustrate only the calculation process and do not represent energy and/or mass flows.

Figure 1 — Detailed method in comparison with BAC Factor method

The detailed method should be used only when a sufficient knowledge about automation, control and management functions used for the building and the energy systems is available. The application of the detailed calculation procedure implies that all automation, control and management functions that have to be account for the operation of a building and its energy systems are known. Clause 6 gives a general survey of those functions and declares how to use them in the context of energy performance calculations.

5.4 BAC and TBM functions having an impact on the energy performance of buildings

Building Automation and Control (BAC) provide effective control functions for any building energy system, e.g. heating, ventilating, cooling, hot water and lighting appliances, that lead to improve operational and energy efficiencies. Complex and integrated energy saving functions and routines can be configured based on the actual use of a building, depending on real user needs, to avoid unnecessary energy use and CO₂ emissions.

Technical Building Management (TBM) functions as part of Building Management (BM) provide information about operation, maintenance, services and management of buildings, especially for energy management - measurement, recording trending, and alarming capabilities and diagnosis of unnecessary energy use. Energy management provides requirements for documentation, controlling, monitoring, optimization, determination and to support corrective action and preventive action to improve the energy performance of buildings. Standard EN 15232 can be used to evaluate the contribution of these building management functions to the energy performance of buildings.